

---

**2012 – 4<sup>th</sup> Quarter Report**  
**Support for Conducting Systems &**  
**Performance Audits of CASTNET Sites and**  
**NADP Monitoring Stations**

**EPA Contract No. EPW12019**

**Prepared for:**

**U. S. Environmental Protection Agency**

**Prepared by:**



**1128 NW 39<sup>th</sup> Drive**  
**Gainesville, FL 32605**

**January 2013**

---

## Table of Contents

<b>1.0 CASTNET Quarterly Report.....</b>	<b>1-1</b>
1.1 Introduction.....	1-1
1.2 Project Objectives .....	1-1
1.3 Sites Visited Fourth Quarter 2012.....	1-3
1.4 Audit Results.....	1-4
<b>2.0 NADP Quarterly Report .....</b>	<b>2-1</b>
2.1 Introduction.....	2-1
2.2 Project Objectives .....	2-1
2.3 Sites Visited Fourth Quarter 2012.....	2-2
2.4 Survey Results.....	2-2

### List of Appendices

- Appendix A** CASNET Audit Report Forms
- Appendix B** CASTNET Site Spot Report Forms
- Appendix C** CASTNET Ozone Performance Evaluation Forms

### List of Tables

<b>Table 1.</b> Performance Audit Challenge and Acceptance Criteria .....	1-2
<b>Table 2.</b> Site Audit Visits .....	1-3
<b>Table 3.</b> Site Ozone PE Visits .....	1-4
<b>Table 4.</b> Sites Surveyed – Fourth Quarter 2012 .....	2-2

## List of Acronyms and Abbreviations

% diff	percent difference
A/D	analog to digital converter
ARS	Air Resource Specialist, Inc.
ASTM	American Society for Testing and Materials
CASTNET	Clean Air Status and Trends Network
DAS	data acquisition system
DC	direct current
deg	degree
DVM	digital voltmeter
EEMS	Environmental, Engineering & Measurement Services, Inc.
EPA	U.S. Environmental Protection Agency
ESC	Environmental Systems Corporation
FSAD	Field Site Audit Database
GPS	geographical positioning system
lpm	liters per minute
MLM	Multilayer Model
m/s	meters per second
mv	milivolt
NIST	National Institute of Standards and Technology
NOAA	National Oceanic and Atmospheric Administration
NPS	National Park Service
QAPP	Quality Assurance Project Plan
SOP	standard operating procedure
TEI	Thermo Environmental Instruments
USNO	United States Naval Observatory
V	volts
WRR	World Radiation Reference

## **1.0 CASTNET Quarterly Report**

### **1.1 Introduction**

The Clean Air Status and Trends Network (CASTNET) is a national air monitoring program developed under mandate of the 1990 Clean Air Act Amendments. Each site in the network measures acidic gases and particles and other forms of atmospheric pollution using a continuous collection filter aggregated over a one week period. Hourly averages of surface ozone concentrations and selected meteorological variables are also measured.

Site measurements are used to estimate deposition rates of the various pollutants with the objective of determining relationships between emissions, air quality, deposition, and ecological effects. In conjunction with other national monitoring networks, CASTNET data are used to determine the effectiveness of national emissions control programs and to assess temporal trends and spatial deposition patterns in atmospheric pollutants. CASTNET data are also used for long-range transport model evaluations and effects research.

CASTNET pollutant flux estimates are calculated as the aggregate product of weekly measured chemical concentrations and model-estimated deposition velocities. Currently, the National Oceanic and Atmospheric Administration's multilayer inferential model (NOAA-MLM) described by Meyers et al. [1998] is used to derive deposition velocity estimates.

As of January 2012, the network is comprised of 82 active rural sampling sites across the United States and Canada, cooperatively operated by the Environmental Protection Agency (EPA), the National Park Service (NPS), Environment Canada, and several independent partners. AMEC is responsible for operating the EPA and Environment Canada sponsored sites, and Air Resource Specialist, Inc. (ARS) is responsible for operating the NPS sponsored sites.

### **1.2 Project Objectives**

The objectives of this project are to establish an independent and unbiased program of performance and systems audits for all CASTNET sampling sites. Ongoing Quality Assurance (QA) programs are an essential part of any long-term monitoring network.

Performance audits verify that all evaluated variables are consistent with the accuracy goals as defined in the CASTNET Quality Assurance Project Plan (QAPP). The parameter specific

accuracy goals are presented in Table 1. Only four EPA sponsored sites continue to operate meteorological sensors. Those sites are BEL116, BVL30, CHE185, and PAL190.

**Table 1. Performance Audit Challenge and Acceptance Criteria**

Sensor	Parameter	Audit Challenge	Acceptance Criteria
Precipitation	Response	10 manual tips	1 DAS count per tip
Precipitation	Accuracy	2 introductions of known amounts of water	$\leq \pm 10.0\%$ of input amount
Relative Humidity	Accuracy	Compared to reference instrument or standard solution	$\leq \pm 10.0\%$ RH
Solar Radiation	Accuracy	Compared to WRR traceable standard	$\leq \pm 10.0\%$ of daytime average
Surface Wetness	Response	Distilled water spray mist	Positive response
Surface Wetness	Sensitivity	1% decade resistance	N/A
Temperature	Accuracy	Comparison to 3 NIST measured baths (~ 0° C, ambient, ~ full-scale)	$\leq \pm 0.5^\circ$ C
Temperature Difference	Accuracy	Comparison to station temperature sensor	$\leq \pm 0.50^\circ$ C
Wind Direction	Orientation Accuracy	Parallel to alignment rod/crossarm, or sighted to distant point	$\leq \pm 5^\circ$ from degrees true
Wind Direction	Linearity	Eight cardinal points on test fixture	$\leq \pm 5^\circ$ mean absolute error
Wind Direction	Response Threshold	Starting torque tested with torque gauge	< 10 g-cm Climatronics; < 20 g-cm R.M. Young
Wind Speed	Accuracy	Shaft rotational speed generated and measured with certified synchronous motor	$\leq \pm 0.5$ mps below 5.0 mps input; $\leq \pm 5.0\%$ of input at or above 5.0 mps
Wind Speed	Starting Threshold	Starting torque tested with torque gauge	< 0.5 g-cm
Mass Flow Controller	Flow Rate	Comparison with Primary Standard	$\leq \pm 5.0\%$ of designated rate
Ozone	Slope	Linear regression of multi-point test gas concentration as measured with a certified transfer standard	$0.9000 \leq m \leq 1.1000$
Ozone	Intercept		$-5.0 \text{ ppb} \leq b \leq 5.0 \text{ ppb}$
Ozone	Correlation Coefficient		$0.9950 \leq r$
DAS	Accuracy	Comparison with certified standard	$\leq \pm 0.003$ VDC

Performance audits are conducted using standards that are traceable to the National Institute of Standards and Technology (NIST), or another authoritative organization, and certified as current.

Site systems audits are intended to provide a qualitative appraisal of the total measurement system. Site planning, organization, and operation are evaluated to ensure that good Quality Assurance/Quality Control (QA/QC) practices are being applied. At a minimum the following audit issues were addressed at each site systems audit:

- Site locations and configurations match those provided in the CASTNET QAPP.
- Meteorological instruments are in good physical and operational condition and are sited to meet EPA ambient monitoring guidelines (EPA-600/4-82-060).
- Sites are accessible, orderly, and if applicable, compliant with OSHA safety standards.
- Sampling lines are free of leaks, kinks, visible contamination, weathering, and moisture.
- Site shelters provide adequate temperature control.
- All ambient air quality instruments are functional, being operated in the appropriate range, and the zero air supply desiccant is unsaturated.
- All instruments are in current calibration.
- Site documentation (maintenance schedules, on-site SOPs, etc.) is current and log book records are complete.
- All maintenance and on-site SOPs are performed on schedule.
- Corrective actions are documented and appropriate for required maintenance/repair activity.
- Site operators demonstrate an adequate knowledge and ability to perform required site activities, including documentation and maintenance activities.

### 1.3 Sites Visited Fourth Quarter 2012

This report consists of the systems and performance audit results from the CASTNET sites audited during the fourth quarter (October through December) of 2012. The locations and dates of the audits are presented in Table 2.

**Table 2. Site Audit Visits**

Site ID	Sponsor Agency	Site Location	Visit dates
ACA416	NPS	Acadia NP	10/9/2012
HOW191	EPA	Howland-AmeriFlux	10/10/2012
HOW132	EPA	Howland	10/11/2012

Site ID	Sponsor Agency	Site Location	Visit dates
ASH135	EPA	Ashland	10/12/2012
WST109	EPA	Woodstock	10/22/2012
ABT147	EPA	Abington	10/23/2012
CAT175	EPA	Claryville	10/24/2012
ARE128	EPA	Arendtsville	10/30/2012
PSU 106	EPA	Penn State University	11/1/2012
BEL116	EPA	Beltsville	11/20/2012

In addition to the sites listed in Table 2. that were visited for complete audits, the sites listed in Table 3. were visited to conduct Through-The-Probe (TTP) ozone Performance Evaluations (PE).

**Table 3. Site Ozone PE Visits**

Site ID	Sponsor Agency	Site Location	Visit dates
CDR119	EPA	Cedar Creek St. Park	10/23/2012
PAR107	EPA	Parsons	10/24/2012
LRL117	EPA	Laurel Hill St. Park	10/25/2012
GRS420	NPS	Great Smoky Mountains NP	11/2/2012
SHN418	NPS	Shenandoah NP - Big Meadows	11/13/2012
BWR139	EPA	Blackwater NWR	11/17/2012
BFT142	EPA	Beaufort	11/29/2012
CND 125	EPA	Candor	11/29/2012

## 1.4 Audit Results

The observations and results of the systems and performance audits are included in Appendix A, *Audit Report Forms* by site, arranged by audit date.

One kilometer, five kilometer, and forty kilometer radius maps are only included for those sites not previously audited. Other photographs of site conditions are included within each systems report where necessary.

Copies of the spot reports that were sent immediately following the audit of each site are included as Appendix B, *Site Spot Report Forms*.

The Ozone PE results and observations are included in Appendix C, *Ozone Performance Evaluation Forms*.



## **2.0 NADP Quarterly Report**

### **2.1 Introduction**

The National Atmospheric Deposition Program (NADP) operates three precipitation chemistry networks and two atmospheric concentration networks. The National Trends Network (NTN) has been measuring acidic precipitation since 1978. The network currently has more than 200 sites. The Atmospheric Integrated Research Monitoring Network (AIRMoN) began operation in 1992 and currently measures event based precipitation events at 7 sites. The Mercury Deposition Network (MDN) measures total mercury in precipitation samples from more than 100 stations. The MDN began operation in 1996 and includes sites throughout the US and Canada. The Atmospheric Mercury Network (AMNet) and the Ammonia Monitoring Network (AMoN) measure ambient concentrations of mercury and ammonia, respectively.

The NADP and other long-term monitoring networks provide critical information to the EPA regarding evaluating the effectiveness of emission reduction control programs from the power industry.

The NADP Program Office operates and administers the three precipitation chemistry networks (NTN, MDN and AIRMoN), two atmospheric concentration networks (AMNet and AMoN), two analytical laboratories (the Central Analytical Laboratory (CAL) located at the University of Illinois/Illinois State Water Survey and the Mercury Analytical Laboratory (HAL) located at Frontier Global Sciences), and the network equipment depot (NED).

### **2.2 Project Objectives**

The objective of this project is to perform independent and unbiased evaluations of the sites along with its operations. These evaluations provide quality assurance pertaining to siting, sample collection and handling, equipment operation and maintenance, record keeping and field laboratory procedures.

More specifically, the surveys determine and report findings based on an established methodology consisting of completing a site questionnaire, testing the equipment and documenting with photographs the location, siting criteria, existing equipment, and any issues encountered that require such documentation.

### 2.3 Sites Visited Fourth Quarter 2012

This report covers the results from the NADP sites surveyed during the fourth quarter (October through December) of 2012. The station name and dates of the audits are presented in Table 4.

**Table 4. Sites Surveyed – Fourth Quarter 2012**

Side ID	Network	Survey Date	Station Name
ME96	MDN/NTN	10/3/2012	Casco Bay-Wolfe’s Neck Farm
ME09	MDN/NTN	10/15/2012	Greenville Station
ME04	MDN/NTN	10/16/2012	Carrabassett Valley
ME02	MDN/NTN	10/17/2012	Bridgton
ME08	NTN	10/18/2012	Gilead
WV18	AMoN	10/24/2012	Parsons
PA83	NTN	10/25/2012	Laurel Hill State Park
DE02	AIRMoN	10/26/2012	Lewes
PA71	NTN	10/31/2012	Little Buffalo State Park
PA98	NTN	10/31/2012	Frances Slocum State Park
TN11	MDN/NTN	11/1/2012	Great Smoky Mountains National Park-Elkmont
PA 37	MDN	11/2/2012	Waynesburg
PA 02	NTN	11/3/2012	Crooked Creek Lake
PA 72	MDN/NTN	11/4/2012	Milford
MD13	NTN	11/16/2012	UM Wye Center

### 2.4 Survey Results

Site survey results are entered into a relational database. The database in turn generates Site Spot Reports which are distributed among the interested parties as soon as all the site data has been entered. Database tables with all the data collected and reviewed are then sent to the NADP Program Office and to the U.S. EPA Project Officers.

Other items gathered during the surveys (i.e., photographs, Belfort charts, etc.) are uploaded to EEMS’ server where the NADP PO and the U.S. EPA POs can access them and download them as needed by login into the server site.

Given the volume of data generated, and the fact that data is distributed and/or is available through EEMS' server, no survey results are included in this report.

---

**APPENDIX A**

**CASNTET Audit Report Forms**

---

# Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>ACA416-Eric Hebert-10/09/2012</i>						
1	10/9/2012	Computer	Hewlett Packard	ACAD	6730b	CNU9335F7W
2	10/9/2012	DAS	Environmental Sys Corp	ACADIA1	8832	unknown2
3	10/9/2012	Delta Temperature	Climatronics	none	100093	3976
4	10/9/2012	Elevation	Elevation	None	1	None
5	10/9/2012	F460 translator	Climatronics	none	100163	683
6	10/9/2012	Filter pack flow pump	Thomas	none	107CAB11	119900011314
7	10/9/2012	Flow Rate	Tylan	none	FC280	AW9403021
8	10/9/2012	Infrastructure	Infrastructure	none	none	none
9	10/9/2012	Mainframe	Climatronics	01342	100081	1288
10	10/9/2012	Met tower	Climatronics	none	unknown	illegible
11	10/9/2012	MFC power supply	Tylan	00045	RO-32	FP902028
12	10/9/2012	Modem	US Robotics	none	33.6 fax modem	unknown
13	10/9/2012	Ozone	ThermoElectron Inc	90744	49C	49C-74536-376
14	10/9/2012	Ozone Standard	ThermoElectron Inc	none	49CPS	49CPS-75057-378
15	10/9/2012	Precipitation	Texas Electronics	02179	TR-525i-HT	illegible
16	10/9/2012	Printer	Hewlett Packard	none	842C	unknown
17	10/9/2012	Relative Humidity	Vaisala	none	HMP45AC	Illegible
18	10/9/2012	Sample Tower	Aluma Tower	none	B	AT-71103-7I-3
19	10/9/2012	Shelter Temperature	unknown	none	none	none
20	10/9/2012	Shield (10 meter)	Climatronics	none	100325	illegible
21	10/9/2012	Shield (2 meter)	Climatronics	none	100325	illegible
22	10/9/2012	Siting Criteria	Siting Criteria	None	1	None
23	10/9/2012	Solar Radiation	Licor	none	LI-200	illegible
24	10/9/2012	Solar Radiation Translator	Climatronics	none	100144	314
25	10/9/2012	Surface Wetness	RM Young	90725	58101	none
26	10/9/2012	Temperature	Climatronics	none	100093	5976
27	10/9/2012	Temperature Translator	Climatronics	03630	100088-2	401
28	10/9/2012	Wind Direction	Climatronics	none	100076	illegible

---

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
29	10/9/2012	Wind Speed	Climatronics	none	100075	1947
30	10/9/2012	Zero air pump	ThermoElectron Inc	none	111	111-30215-237

---

# DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	unknown2	ACA416	Eric Hebert	10/09/2012	DAS	Primary

**Das Date:**       **Audit Date:**   
**Das Time:**       **Audit Time:**   
**Das Day:**       **Audit Day:**   
**Low Channel:**      **High Channel:**  
**Avg Diff:**      **Max Diff:**      **Avg Diff:**      **Max Diff:**  
                 

<b>Mfg</b>	<input type="text" value="Datel"/>	<b>Parameter</b>	<input type="text" value="DAS"/>
<b>Serial Number</b>	<input type="text" value="4000392"/>	<b>Tfer Desc.</b>	<input type="text" value="Source generator (D"/>
<b>Tfer ID</b>	<input type="text" value="01321"/>		
<b>Slope</b>	<input type="text" value="1.00000"/>	<b>Intercept</b>	<input type="text" value="0.00000"/>
<b>Cert Date</b>	<input type="text" value="2/13/2012"/>	<b>CorrCoff</b>	<input type="text" value="1.00000"/>
<b>Mfg</b>	<input type="text" value="Fluke"/>	<b>Parameter</b>	<input type="text" value="DAS"/>
<b>Serial Number</b>	<input type="text" value="86590148"/>	<b>Tfer Desc.</b>	<input type="text" value="DVM"/>
<b>Tfer ID</b>	<input type="text" value="01310"/>		
<b>Slope</b>	<input type="text" value="1.00000"/>	<b>Intercept</b>	<input type="text" value="0.00000"/>
<b>Cert Date</b>	<input type="text" value="2/9/2012"/>	<b>CorrCoff</b>	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
2	0.0000	0.0000	0.0000	V	V	0.0000
2	0.1000	0.1000	0.0997	V	V	-0.0003
2	0.3000	0.3000	0.2993	V	V	-0.0007
2	0.5000	0.4999	0.4999	V	V	0.0000
2	0.7000	0.6999	0.6992	V	V	-0.0007
2	0.9000	0.8999	0.8999	V	V	0.0000
2	1.0000	1.0000	0.9998	V	V	-0.0002

# Flow Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
Tylan	AW9403021	ACA416	Eric Hebert	10/09/2012	Flow Rate	none

<b>Mfg</b>	Tylan
<b>SN/Owner ID</b>	FP902028 00045
<b>Parameter</b>	MFC power supply

<b>Mfg</b>	BIOS	<b>Parameter</b>	Flow Rate
<b>Serial Number</b>	122974	<b>Tfer Desc.</b>	BIOS 220-H
<b>Tfer ID</b>	01416		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	2/6/2012	<b>CorrCoff</b>	1.00000

<b>DAS 1:</b>	<b>DAS 2:</b>
<b>A Avg % Diff:</b>	<b>A Max % Di</b>
1.96%	2.09%

<b>Cal Factor Zero</b>	0.04
<b>Cal Factor Full Scale</b>	5.41
<b>Rotometer Reading:</b>	1.55

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	-0.01	-0.004	0.04	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.003	0.05	l/m	l/m	
primary	test pt 1	0.000	1.528	1.33	1.363	1.50	l/m	l/m	-1.85%
primary	test pt 2	0.000	1.530	1.33	1.363	1.50	l/m	l/m	-1.94%
primary	test pt 3	0.000	1.532	1.33	1.363	1.50	l/m	l/m	-2.09%

<b>Sensor Component</b>	Leak Test	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Filter Azimuth	<b>Condition</b>	135 Deg	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Depth	<b>Condition</b>	- 1.0 cm	<b>Status</b>	Fail
<b>Sensor Component</b>	Filter Position	<b>Condition</b>	Poor	<b>Status</b>	Fail
<b>Sensor Component</b>	Moisture Present	<b>Condition</b>	See comments	<b>Status</b>	pass
<b>Sensor Component</b>	Rotometer Condition	<b>Condition</b>	Clean and dry	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Tubing Condition	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Distance	<b>Condition</b>	6.0 cm	<b>Status</b>	pass



# Ozone Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
ThermoElectron Inc	49C-74536-376		ACA416	Eric Hebert	10/09/2012	Ozone	90744

<b>Slope:</b>	0.96212	<b>Slope:</b>	0.00000
<b>Intercept</b>	0.29896	<b>Intercept</b>	0.00000
<b>CorrCoff</b>	0.99993	<b>CorrCoff</b>	0.00000

<b>DAS 1:</b>	<b>DAS 2:</b>		
<b>A Avg % Diff:</b>	<b>A Max % Di</b>	<b>A Avg %Dif</b>	<b>A Max % Di</b>
3.2%	4.3%		

<b>Mfg</b>	ThermoElectron Inc	<b>Parameter</b>	ozone
<b>Serial Number</b>	517112175	<b>Tfer Desc.</b>	Ozone primary stan
<b>Tfer ID</b>	01111		
<b>Slope</b>	1.00987	<b>Intercept</b>	0.07483
<b>Cert Date</b>	3/23/2012	<b>CorrCoff</b>	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.42	0.34	0.00	ppb	
primary	2	33.78	33.37	31.95	ppb	-4.26%
primary	3	64.46	63.75	61.75	ppb	-3.14%
primary	4	82.51	81.62	80.35	ppb	-1.56%
primary	5	210.75	208.61	200.45	ppb	-3.91%

<b>Sensor Component</b>	Cell B Noise	<b>Condition</b>	0.6 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Tmp.	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Fullscale Voltage	<b>Condition</b>	9.9980	<b>Status</b>	pass
<b>Sensor Component</b>	Inlet Filter Condition	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Line Loss	<b>Condition</b>	Not tested	<b>Status</b>	pass
<b>Sensor Component</b>	Offset	<b>Condition</b>	0.1	<b>Status</b>	pass
<b>Sensor Component</b>	Span	<b>Condition</b>	1.082	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Freq.	<b>Condition</b>	93.2 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Sample Train	<b>Condition</b>	See comments	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Pressure	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Flow	<b>Condition</b>	0.73 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Tmp.	<b>Condition</b>	35.7 C	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Pressure	<b>Condition</b>	759 mmHg	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Noise	<b>Condition</b>	0.4 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Freq.	<b>Condition</b>	104.8 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Flow	<b>Condition</b>	0.73 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Battery Backup	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Zero Voltage	<b>Condition</b>	0.000	<b>Status</b>	pass

# Wind Speed Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
Climatronics	1947	ACA416	Eric Hebert	10/09/2012	Wind Speed	none

<b>Mfg</b>	Climatronics
<b>SN/Owner ID</b>	683 none
<b>Parameter</b>	F460 translator

**Prop or Cups SN**

**Prop or Cups Torque**  to

**Prop Correction Fact**

<b>Mfg</b>	RM Young	<b>Parameter</b>	wind speed
<b>Serial Number</b>	<input type="text"/>	<b>Tfer Desc.</b>	wind speed motor (h
<b>Tfer ID</b>	01262		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	1/13/2010	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	RM Young	<b>Parameter</b>	wind speed
<b>Serial Number</b>	<input type="text"/>	<b>Tfer Desc.</b>	wind speed motor (l
<b>Tfer ID</b>	01261		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	1/13/2010	<b>CorrCoff</b>	1.00000

	<b>DAS 1:</b>		<b>DAS 2:</b>	
	<b>Low Range</b>	<b>High Range</b>	<b>Low Range</b>	<b>High Range</b>
<b>Abs Avg Err</b>	<input type="text" value="0.20"/>	<input type="text" value="0.74%"/>	<input type="text"/>	<input type="text"/>
<b>Abs Max Er</b>	<input type="text" value="0.22"/>	<input type="text" value="1.64%"/>	<input type="text"/>	<input type="text"/>

UseDescription:	InputDevice:	Input RPM:	Input m/s:	Output V:	DAS m/s:	Diff/ %Diff:	Difference:
primary	none	0	0.20	0.000	0.0		-0.20
primary	01261	50	1.40	0.000	1.2		-0.20
primary	01261	100	2.57	0.000	2.4		-0.17
primary	01261	170	4.22	0.000	4.0		-0.22
primary	01261	250	6.10	0.000	6.0	-1.64%	
primary	01262	500	11.97	0.000	11.9	-0.58%	
primary	01262	800	19.02	0.000	19.0	0.05%	
primary	01262	2000	47.22	0.000	47.5	0.68%	

<b>Sensor Component</b>	System Memo	<b>Condition</b>	<input type="text"/>	<b>Status</b>	pass
<b>Sensor Component</b>	Sensor Plumb	<b>Condition</b>	Plumb	<b>Status</b>	pass
<b>Sensor Component</b>	Sensor Heater	<b>Condition</b>	Functioning	<b>Status</b>	pass
<b>Sensor Component</b>	Prop or Cups Condition	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Condition	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Torque	<b>Condition</b>	<input type="text"/>	<b>Status</b>	pass

# Wind Direction Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
Climatronics	illegible		ACA416	Eric Hebert	10/09/2012	Wind Direction	none

<b>Mfg</b>	Climatronics
<b>SN/Owner ID</b>	683 none
<b>Parameter</b>	F460 translator

**Vane SN:** 1230 **C. A. Align. deg. true:**

**Vane Torque** 5 to 7 180

<b>Mfg</b>	Ushikata	<b>Parameter</b>	wind direction
<b>Serial Number</b>	190037	<b>Tfer Desc.</b>	transit
<b>Tfer ID</b>	01265		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	1/4/2011	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	RM Young	<b>Parameter</b>	wind direction
<b>Serial Number</b>		<b>Tfer Desc.</b>	wind direction wheel
<b>Tfer ID</b>	01266		

<b>DAS 1:</b>	<b>DAS 2:</b>		
<b>Orientation</b>	<b>Linearity:</b>	<b>Orientation</b>	<b>Linearity:</b>
<b>Abs Avg Err</b>	3.4	1.3	
<b>Abs Max Er</b>	5	4	

UseDescription:	TferID:	Input Raw:	Linearity	Output V:	Output Deg.:	Difference:	Change:	Error:
primary	01266	0	<input checked="" type="checkbox"/>	0.000	4	4	45	0
primary	01266	45	<input checked="" type="checkbox"/>	0.000	47	2	43	-2
primary	01266	90	<input checked="" type="checkbox"/>	0.000	91	1	44	-1
primary	01266	135	<input checked="" type="checkbox"/>	0.000	135	0	44	-1
primary	01266	180	<input checked="" type="checkbox"/>	0.000	184	4	49	4
primary	01266	225	<input checked="" type="checkbox"/>	0.000	229	4	45	0
primary	01266	270	<input checked="" type="checkbox"/>	0.000	275	5	46	1
primary	01266	315	<input checked="" type="checkbox"/>	0.000	319	4	44	-1
primary	01265	90	<input type="checkbox"/>	0.000	91	1		1
primary	01265	90	<input type="checkbox"/>	0.000	93	3		3
primary	01265	180	<input type="checkbox"/>	0.000	184	4		4
primary	01265	270	<input type="checkbox"/>	0.000	275	5		5
primary	01265	360	<input type="checkbox"/>	0.000	4	4		4

<b>Sensor Component</b>	Mast	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Condition	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Sensor Heater	<b>Condition</b>	Functioning	<b>Status</b>	pass
<b>Sensor Component</b>	Sensor Plumb	<b>Condition</b>	Plumb	<b>Status</b>	pass
<b>Sensor Component</b>	Torque	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Vane Condition	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass



# Delta Temperature Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
Climatronics	3976		ACA416	Eric Hebert	10/09/2012	Delta Temperature	none

<b>Mfg</b>	Climatronics	
<b>SN/Owner ID</b>	401	03630
<b>Parameter</b>	Temperature Translator	

**DAS 1:** **DAS 2:**

<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01H0060	<b>Tfer Desc.</b>	RTD probe
<b>Tfer ID</b>	01230		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000

<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01D102193	<b>Tfer Desc.</b>	RTD translator
<b>Tfer ID</b>	01231		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000

**Abs Avg Diff** **Abs Max Dif** **Abs Avg Diff** **Abs Max Dif**

0.06	0.07		
------	------	--	--

UseDescription:	Iteration:	OutputTmpSignal:	OutputSignalEng:	OutputSignalEngUnit:	Difference:
primary	1	0.000	0.06	C	0.06
primary	2	0.000	0.07	C	0.07
primary	3	0.000	0.05	C	0.05

<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Shield	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Properly Sited	<b>Condition</b>	Properly sited	<b>Status</b>	pass
<b>Sensor Component</b>	Blower Status Switch	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Blower	<b>Condition</b>	Functioning	<b>Status</b>	pass

# Humidity Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Tag Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
Vaisala	Illegible	ACA416	Eric Hebert	10/09/2012	Relative Humidity	none

<b>Mfg</b>	Rotronic	<b>Parameter</b>	Relative Humidity
<b>Serial Number</b>	124432	<b>Tfer Desc.</b>	Hygroclip
<b>Tfer ID</b>	01225		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	2/13/2012	<b>CorrCoff</b>	1.00000

**DAS 1:**

**DAS 2:**

	<b>Low Range</b>	<b>High Range</b>	<b>Low Range</b>	<b>High Range</b>
<b>Abs Avg Err</b>	6.7	5.1		
<b>Abs Max Er</b>	7.7	5.1		

UseDesc.:	Test type:	Device:	Input RH:	GTL Raw:	RH Corr.:	DAS Volts:	DAS %RH:	Difference:
primary	RH Low Range	Hygroclip	32.8	30.1	32.8	0.385	38.5	5.7
primary	RH Low Range	Hygroclip	52.9	57.4	52.9	0.606	60.6	7.7
primary	RH High Range	Hygroclip	93.6	89.1	93.6	0.885	88.5	-5.1

<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Blower	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Blower Status Switch	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	RH Filter	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Shield	<b>Condition</b>	Clean	<b>Status</b>	pass

# Solar Radiation Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Tag</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
Licor	illegible		ACA416	Eric Hebert	10/09/2012	Solar Radiation	none

<b>Mfg</b>	Climatronics	
<b>SN/Owner ID</b>	314	none
<b>Parameter</b>	Solar Radiation Translator	

<b>Mfg</b>	Eppley	<b>Parameter</b>	solar radiation
<b>Serial Number</b>	10765	<b>Tfer Desc.</b>	SR transfer translat
<b>Tfer ID</b>	01246		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	1/6/2010	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	Eppley	<b>Parameter</b>	solar radiation
<b>Serial Number</b>	34341F3	<b>Tfer Desc.</b>	SR transfer sensor
<b>Tfer ID</b>	01245		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	12/16/2010	<b>CorrCoff</b>	1.00000

<b>DAS 1:</b>	<b>DAS 2:</b>
% Diff of Avg	%Diff of Max
%Diff of Avg	%Diff of Max

2.9%	2.6%	0.0%	0.0%
------	------	------	------

UseDescription:	Measure Date	MeasureTime	Tfer Corr:	DAS w/m2:	PctDifference:
primary	10/9/2012	10:00	575	533	-7.3%
primary	10/9/2012	12:00	689	671	-2.6%
primary	10/9/2012	13:00	619	606	-2.1%
primary	10/9/2012	15:00	285	295	3.5%

<b>Sensor Component</b>	Sensor Level	<b>Condition</b>	Full bubble off level	<b>Status</b>	Fail
<b>Sensor Component</b>	Sensor Clean	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Properly Sited	<b>Condition</b>	Properly sited	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>	See comments	<b>Status</b>	pass

# Surface Wetness Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
RM Young	none		ACA416	Eric Hebert	10/09/2012	Surface Wetness	90725

<b>Mfg</b>	Ohmite	<b>Parameter</b>	surface wetness
<b>Serial Number</b>	296-1200	<b>Tfer Desc.</b>	decade box
<b>Tfer ID</b>	01210		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	1/4/2011	<b>CorrCoff</b>	1.00000

**Manual Test Pass**

UseDescription:	Test Type:	Tfer kOhms:	OutputSignal:	DAS eng:	OutputSignalEngUni	TferUnits:	OutputSignalUnit
primary	wet	N/A	0.955	95.50	V	N/A	% Wet
primary	dry	N/A	0.003	0.28	V	N/A	% Wet

<b>Sensor Component</b>	Grid Orientation	<b>Condition</b>	North	<b>Status</b>	pass
<b>Sensor Component</b>	Grid Clean	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Grid Angle	<b>Condition</b>	about 45 deg	<b>Status</b>	pass
<b>Sensor Component</b>	Grid Condition	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Properly Sited	<b>Condition</b>	Properly sited	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Grid Type	<b>Condition</b>	Grid without holes	<b>Status</b>	pass



# Precipitation Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
Texas Electronics	illegible		ACA416	Eric Hebert	10/09/2012	Precipitation	02179

<b>DAS 1:</b>	<b>DAS 2:</b>		
<b>A Avg % Diff:</b>	<b>A Max % Di</b>	<b>A Avg %Dif</b>	<b>A Max % Di</b>
19.0%	22.0%		

<b>Mfg</b>	PMP	<b>Parameter</b>	Precipitation
<b>Serial Number</b>	EW-06134-50	<b>Tfer Desc.</b>	250ml graduate
<b>Tfer ID</b>	01250		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	9/5/2005	<b>CorrCoff</b>	1.00000

UseDesc.	Test type:	TferVolume:	Iteration:	TimePerTip:	Eq.Ht:	DAS eng:	Eq.HtUnit:	OSE Unit:	TferUnits:	PctDifference
primary	tip check	10 manual	1	10 sec	1.00	1.00	mm	mm	ml	
primary	test 1	231.5	1	10 sec	5.00	5.80	mm	mm	ml	16.0%
primary	test 2	231.5	2	12 sec	5.00	6.10	mm	mm	ml	22.0%

<b>Sensor Component</b>	System Memo	<b>Condition</b>	See comments	<b>Status</b>	pass
<b>Sensor Component</b>	Sensor Heater	<b>Condition</b>	Not functioning	<b>Status</b>	Fail
<b>Sensor Component</b>	Properly Sited	<b>Condition</b>	See comments	<b>Status</b>	pass
<b>Sensor Component</b>	Gauge Drain Screen	<b>Condition</b>	Not installed	<b>Status</b>	Fail
<b>Sensor Component</b>	Level	<b>Condition</b>	Level	<b>Status</b>	pass
<b>Sensor Component</b>	Gauge Clean	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Funnel Clean	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Condition	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Gauge Screen	<b>Condition</b>	Installed	<b>Status</b>	pass

## Infrastructure Data For

Site ID  Technician  Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8818 (s/n 2920-1)"/>	<input type="text" value="1152 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="Fail"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

# Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
unknown	none		ACA416	Eric Hebert	10/09/2012	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.53	0.67		

<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Shelter Temperatur
<b>Serial Number</b>	01D102193	<b>Tfer Desc.</b>	RTD translator
<b>Tfer ID</b>	01231		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Shelter Temperatur
<b>Serial Number</b>	01H0060	<b>Tfer Desc.</b>	RTD probe
<b>Tfer ID</b>	01230		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	21.82	21.81	0.000	22.2	C	0.39
primary	Temp Mid Range	21.51	21.50	0.000	22.2	C	0.67

# Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	ACA416	Eric Hebert	10/09/2012	Moisture Present	Tylan	3649	<input type="checkbox"/>	<input type="checkbox"/>
The filter sample tubing has drops of moisture in low sections outside the shelter.								
Ozone	ACA416	Eric Hebert	10/09/2012	Sample Train	ThermoElectron	814	<input type="checkbox"/>	<input checked="" type="checkbox"/>
The ozone sample train is composed of materials other than the recommended materials which are Teflon and glass only.								
Precipitation	ACA416	Eric Hebert	10/09/2012	Properly Sited	Texas Electronic	2328	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Objects violate the 45 degree rule for the tipping bucket rain gage.								
Precipitation	ACA416	Eric Hebert	10/09/2012	Sensor Heater	Texas Electronic	2328	<input type="checkbox"/>	<input type="checkbox"/>
The tipping bucket heater is generating excessive heat, enough to evaporate water on the funnel.								
Solar Radiation	ACA416	Eric Hebert	10/09/2012	Sensor Level	Licor	3648	<input type="checkbox"/>	<input type="checkbox"/>
The solar radiation sensor is mounted on the meteorological tower and is difficult to access. The site operator does not check the sensor weekly.								

# Field Systems Comments

**1 Parameter:** SiteOpsProcComm

This site is operated partly by the NPS and the State of Maine DEP. It is not visited by ARS for semiannual calibration and maintenance visits. The site operator does not perform many of the routine checks conducted at other CASTNET sites, such as tip checks, wetness sensor tests, and visual checks of the blowers. The state of Maine personnel maintain the meteorological systems.

**2 Parameter:** SiteOpsProcedures

The meteorological and ozone instrument checks and maintenance are performed by the State of Maine DEP.

**3 Parameter:** PollAnalyzerCom

The ozone sample inlet has a stainless steel funnel and stainless steel fittings. The recommended material for ozone sample train is Teflon or glass.

**4 Parameter:** ShelterCleanNotes

The shelter is clean and well organized.

**5 Parameter:** MetSensorComme

The solar radiation sensor is a full bubble off level and bias to the west.

**6 Parameter:** MetOpMaintCom

The tipping bucket heater thermostat has failed in the closed circuit position allowing the heater to be continuously on. The tipping mechanism was beginning to melt. The heater was unplugged during the site audit.

# Field Systems Data Form

F-02058-1500-S1-rev001

Site ID  Technician  Site Visit Date

Site Sponsor (agency)	<input type="text" value="NPS/EPA"/>	USGS Map	<input type="text" value="Salsbury Cove"/>
Operating Group	<input type="text" value="NPS/MEDEP"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="23-009-0103"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, SO2, NOx, NOy, PM, VOC"/>	QAPP Latitude	<input type="text" value="44.3770"/>
Deposition Measurement	<input type="text" value="dry, wet, Hg"/>	QAPP Longitude	<input type="text" value="-68.2610"/>
Land Use	<input type="text" value="Costal, woodland - mixed"/>	QAPP Elevation Meters	<input type="text" value="158"/>
Terrain	<input type="text" value="rolling"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="No"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text" value="(432) 288-9322"/>	Audit Latitude	<input type="text" value="44.377086"/>
Site Address 1	<input type="text" value="Route 233"/>	Audit Longitude	<input type="text" value="-68.2608"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="153"/>
County	<input type="text" value="Hancock"/>	Audit Declination	<input type="text" value="-16.5"/>
City, State	<input type="text" value="Bar Harbor, ME"/>		
Zip Code	<input type="text" value="04609"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="Inspected Dec 2011"/>
Time Zone	<input type="text" value="Eastern"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text" value="Beth Arsenault"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text" value="(207) 288-8734"/>	Safety Hard Hat <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text" value="Beth_Arsenault@nps.gov"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text" value="Bill Gawley"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text" value="(207) 288-8723"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text" value="bill_gawley@nps.gov"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8818 (s/n 2920-1)"/>	Shelter Size <input type="text" value="1152 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is clean and well organized."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions

# Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO <sub>2</sub> or NO <sub>x</sub>	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	25 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

# Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- |    |  |                                     |                          |
|----|--|-------------------------------------|--------------------------|
| 1  | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?  | <input checked="" type="checkbox"/> |                          |
| 2  | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)     | <input checked="" type="checkbox"/> |                          |
| 3  | Are the tower and sensors plumb?   | <input checked="" type="checkbox"/> |                          |
| 4  | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?  | <input checked="" type="checkbox"/> |                          |
| 5  | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> |                          |
| 6  | Is the solar radiation sensor plumb?   | <input type="checkbox"/>            |                          |
| 7  | Is it sited to avoid shading, or any artificial or reflected light?  | <input checked="" type="checkbox"/> |                          |
| 8  | Is the rain gauge plumb?   | <input checked="" type="checkbox"/> |                          |
| 9  | Is it sited to avoid sheltering effects from buildings, trees, towers, etc?  | <input type="checkbox"/>            | 45 degree rule violation |
| 10 | Is the surface wetness sensor sited with the grid surface facing north?  | <input checked="" type="checkbox"/> |                          |
| 11 | Is it inclined approximately 30 degrees?   | <input checked="" type="checkbox"/> |                          |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:



# Field Systems Data Form

F-02058-1500-S4-rev001

Site ID

Technician

Site Visit Date

- 1 Do all the meteorological sensors appear to be intact, in good condition, and well maintained?
- 2 Are all the meteorological sensors operational online, and reporting data?
- 3 Are the shields for the temperature and RH sensors clean?
- 4 Are the aspirated motors working?
- 5 Is the solar radiation sensor's lens clean and free of scratches?
- 6 Is the surface wetness sensor grid clean and undamaged?
- 7 Are the sensor signal and power cables intact, in good condition, and well maintained?
- 8 Are the sensor signal and power cable connections protected from the elements and well maintained?


Parameter	Manufacturer	Model	S/N	Client ID
Met tower	Climatronics	unknown	illegible	none
Temperature	Climatronics	100093	5976	none
Delta Temperature	Climatronics	100093	3976	none
Shield (10 meter)	Climatronics	100325	illegible	none
Shield (2 meter)	Climatronics	100325	illegible	none
Surface Wetness	RM Young	58101	none	90725
Precipitation	Texas Electronics	TR-525i-HT	illegible	02179
Relative Humidity	Vaisala	HMP45AC	Illegible	none
Wind Speed	Climatronics	100075	1947	none
Wind Direction	Climatronics	100076	illegible	none
Solar Radiation	Licor	LI-200	illegible	none

**Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:**

The tipping bucket heater thermostat has failed in the closed circuit position allowing the heater to be continuously on. The tipping mechanism was beginning to melt. The heater was unplugged during the site audit.

# Field Systems Data Form

F-02058-1500-S5-rev001

Site ID  Technician  Site Visit Date

**Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E**

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

**Pollutant analyzers and deposition equipment operations and maintenance**

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	B	AT-71103-71-3	none
Ozone	ThermoElectron Inc	49C	49C-74536-376	90744
Zero air pump	ThermoElectron Inc	111	111-30215-237	none
Filter pack flow pump	Thomas	107CAB11	119900011314	none
MFC power supply	Tylan	RO-32	FP902028	00045

**Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:**

The ozone sample inlet has a stainless steel funnel and stainless steel fittings. The recommended material for ozone sample train is Teflon or glass.

# Field Systems Data Form

F-02058-1500-S6-rev001

Site ID

Technician

Site Visit Date

**DAS, sensor translators, and peripheral equipment operations and maintenance**

- 1 Do the DAS instruments appear to be in good condition and well maintained?
  - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
  - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry?
  - 4 Are the signal connections protected from the weather and well maintained?
  - 5 Are the signal leads connected to the correct DAS channel?
  - 6 Are the DAS, sensor translators, and shelter properly grounded?
  - 7 Does the instrument shelter have a stable power source?
  - 8 Is the instrument shelter temperature controlled?
- Stable**

**Grounded**
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Hewlett Packard	6730b	CNU9335F7W	ACAD
DAS	Environmental Sys Corp	8832	unknown2	ACADIA1
F460 translator	Climatronics	100163	683	none
Mainframe	Climatronics	100081	1288	01342
Modem	US Robotics	33.6 fax modem	unknown	none
Printer	Hewlett Packard	842C	unknown	none
Solar Radiation Translator	Climatronics	100144	314	none
Temperature Translator	Climatronics	100088-2	401	03630

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Printer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text" value="Dataview"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	<input type="text" value="June 2000"/>	<input checked="" type="checkbox"/>
HASP	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>

- Is the station log properly completed during every site visit?
- Are the Site Status Report Forms being completed and current?
- Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- Are ozone z/s/p control charts properly completed and current?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S8-rev001

Site ID  Technician  Site Visit Date

**Site operation procedures**

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

**Are regular operational QA/QC checks performed on meteorological instruments?**

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually by MEDEP"/>		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>		<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="Monthly"/>		<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input type="checkbox"/>	<input type="text" value="Not performed"/>		<input type="checkbox"/>

**Are regular operational QA/QC checks performed on the ozone analyzer?**

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Monthly"/>		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>		<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>		<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>		<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Monthly"/>		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Monthly"/>		<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>		<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S9-rev001

Site ID  Technician  Site Visit Date

**Site operation procedures**

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings, 90%
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	Flow and general observation sections only
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/> Not performed	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/> Not performed	<input type="checkbox"/>

**Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:**

This site is operated partly by the NPS and the State of Maine DEP. It is not visited by ARS for semiannual calibration and maintenance visits. The site operator does not perform many of the routine checks conducted at other CASTNET sites, such as tip checks, wetness sensor tests, and visual checks of the blowers. The state of Maine personnel maintain the meteorological systems.

## *Site Inventory by Site Visit*

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>HOW191-Eric Hebert-10/10/2012</i>						
1	10/10/2012	DAS	Campbell	000348	CR3000	2127
2	10/10/2012	elevation	Elevation	none	none	none
3	10/10/2012	Filter pack flow pump	Thomas	06022	107CAB18	060400022686
4	10/10/2012	Filter pack flow pump	Thomas	04921	107CAB18	060300019983
5	10/10/2012	Flow Rate	Apex	000645	AXMC105LPM DPCV	illegible
6	10/10/2012	Flow Rate	Apex	000671	AXMC105LPM DPCV	illegible
7	10/10/2012	Infrastructure	Infrastructure	none	none	none
8	10/10/2012	Modem	Raven	06470	H4222-C	0808311250
9	10/10/2012	Ozone	ThermoElectron Inc	unknown	49i A1NAA	1104347326
10	10/10/2012	Ozone Standard	ThermoElectron Inc	000514	49i A3NAA	0922236892
11	10/10/2012	Shelter Temperature	Campbell	none	107-L	none
12	10/10/2012	siting criteria	Siting Criteria	none	none	None
13	10/10/2012	Temperature23.5meter	RM Young	00245	41342VC	Illegible
14	10/10/2012	Temperature2meter	RM Young	04449	41342VC	4547
15	10/10/2012	Zero air pump	Werther International	06908	C 70/4	000821900

# Flow Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
Apex	illegible		HOW191	Eric Hebert	10/10/2012	Flow Rate	000671

<b>Mfg</b>	BIOS	<b>Parameter</b>	Flow Rate
<b>Serial Number</b>	122974	<b>Tfer Desc.</b>	BIOS 220-H
<b>Tfer ID</b>	01416		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	2/6/2012	<b>CorrCoff</b>	1.00000

<b>DAS 1:</b>	<b>DAS 2:</b>	<b>Cal Factor Zero</b>	-0.01
<b>A Avg % Diff:</b>	<b>A Max % Di</b>	<b>Cal Factor Full Scale</b>	0.99
0.17%	0.90%	<b>Rotometer Reading:</b>	0

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	0.00	0.000	0.02	l/m	l/m	
primary	leak check	0.000	0.000	0.03	0.000	0.04	l/m	l/m	
primary	test pt 1	0.000	1.502	1.49	1.507	1.50	l/m	l/m	-0.16%
primary	test pt 2	0.000	1.505	1.49	1.505	1.50	l/m	l/m	-0.31%
primary	test pt 3	0.000	1.504	1.49	1.505	1.49	l/m	l/m	-0.90%

<b>Sensor Component</b>	Leak Test	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Filter Azimuth	<b>Condition</b>	135 Deg	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Depth	<b>Condition</b>	1.5 cm	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Position	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Moisture Present	<b>Condition</b>	No moisture present	<b>Status</b>	pass
<b>Sensor Component</b>	Rotometer Condition	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Tubing Condition	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Distance	<b>Condition</b>	4.5 cm	<b>Status</b>	pass





<b>Mfg</b>	BIOS	<b>Parameter</b>	Flow Rate
<b>Serial Number</b>	122974	<b>Tfer Desc.</b>	BIOS 220-H
<b>Tfer ID</b>	01416		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	2/6/2012	<b>CorrCoff</b>	1.00000

<b>DAS 1:</b>	<b>DAS 2:</b>
<b>A Avg % Diff:</b> <input type="text" value="0.34%"/>	<b>A Max % Di</b> <input type="text" value="0.90%"/>
<b>A Avg %Dif</b> <input type="text"/>	<b>A Max % Di</b> <input type="text"/>

<b>Cal Factor Zero</b>	<input type="text" value="0"/>
<b>Cal Factor Full Scale</b>	<input type="text" value="1.02"/>
<b>Rotometer Reading:</b>	<input type="text" value="0"/>

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	-0.01	0.032	0.03	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.033	0.03	l/m	l/m	
primary	test pt 1	0.000	1.513	1.46	1.473	1.51	l/m	l/m	-0.20%
primary	test pt 2	0.000	1.512	1.46	1.473	1.51	l/m	l/m	-0.12%
primary	test pt 3	0.000	1.516	1.46	1.473	1.51	l/m	l/m	-0.38%

<b>Sensor Component</b>	Leak Test	<b>Condition</b>	<input type="text"/>	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Azimuth	<b>Condition</b>	45 Deg	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Depth	<b>Condition</b>	3.0 cm	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Position	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Moisture Present	<b>Condition</b>	No moisture present	<b>Status</b>	pass
<b>Sensor Component</b>	Rotometer Condition	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>	<input type="text"/>	<b>Status</b>	pass
<b>Sensor Component</b>	Tubing Condition	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Distance	<b>Condition</b>	5.0 cm	<b>Status</b>	pass

# Ozone Data Form

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1104347326	HOW191	Eric Hebert	10/10/2012	Ozone	unknown

<b>Slope:</b>	0.98987	<b>Slope:</b>	0.00000
<b>Intercept</b>	0.57532	<b>Intercept</b>	0.00000
<b>CorrCoff</b>	1.00000	<b>CorrCoff</b>	0.00000

<b>DAS 1:</b>	<b>DAS 2:</b>		
<b>A Avg % Diff:</b>	<b>A Max % Di</b>	<b>A Avg %Dif</b>	<b>A Max % Di</b>
3.0%	6.1%		

<b>Mfg</b>	ThermoElectron Inc	<b>Parameter</b>	ozone
<b>Serial Number</b>	517112175	<b>Tfer Desc.</b>	Ozone primary stan
<b>Tfer ID</b>	01111		
<b>Slope</b>	1.00987	<b>Intercept</b>	0.07483
<b>Cert Date</b>	3/23/2012	<b>CorrCoff</b>	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.23	0.15	0.75	ppb	
primary	2	7.49	7.34	7.79	ppb	6.13%
primary	3	18.43	18.17	18.59	ppb	2.31%
primary	4	38.07	37.62	37.81	ppb	0.51%

<b>Sensor Component</b>	Cell B Noise	<b>Condition</b>	1.0 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Tmp.	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Fullscale Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Inlet Filter Condition	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Line Loss	<b>Condition</b>	Not tested	<b>Status</b>	pass
<b>Sensor Component</b>	Offset	<b>Condition</b>	-0.6	<b>Status</b>	pass
<b>Sensor Component</b>	Span	<b>Condition</b>	1.025	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Freq.	<b>Condition</b>	93.8 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Sample Train	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Pressure	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Flow	<b>Condition</b>	0.64 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Tmp.	<b>Condition</b>	34.0 C	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Pressure	<b>Condition</b>	700 mmHg	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Noise	<b>Condition</b>	0.8 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Freq.	<b>Condition</b>	83.9 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Flow	<b>Condition</b>	0.67 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Battery Backup	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Zero Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass

**Infrastructure Data For**

**Site ID**  **Technician**  **Site Visit Date**

Shelter Make	Shelter Model	Shelter Size
<input type="text"/>	<input type="text"/>	<input type="text"/>

<b>Sensor Component</b>	<input type="text" value="Shelter Roof"/>	<b>Condition</b>	<input type="text" value="Good"/>	<b>Status</b>	<input type="text" value="pass"/>
<b>Sensor Component</b>	<input type="text" value="Sample Tower Type"/>	<b>Condition</b>	<input type="text" value="N/A"/>	<b>Status</b>	<input type="text" value="pass"/>
<b>Sensor Component</b>	<input type="text" value="Conduit"/>	<b>Condition</b>	<input type="text" value="N/A"/>	<b>Status</b>	<input type="text" value="pass"/>
<b>Sensor Component</b>	<input type="text" value="Met Tower"/>	<b>Condition</b>	<input type="text" value="N/A"/>	<b>Status</b>	<input type="text" value="pass"/>
<b>Sensor Component</b>	<input type="text" value="Moisture Trap"/>	<b>Condition</b>	<input type="text" value="Not installed"/>	<b>Status</b>	<input type="text" value="pass"/>
<b>Sensor Component</b>	<input type="text" value="Power Cables"/>	<b>Condition</b>	<input type="text" value="Good"/>	<b>Status</b>	<input type="text" value="pass"/>
<b>Sensor Component</b>	<input type="text" value="Rotometer"/>	<b>Condition</b>	<input type="text" value="Not installed"/>	<b>Status</b>	<input type="text" value="Fail"/>
<b>Sensor Component</b>	<input type="text" value="Sample Tower"/>	<b>Condition</b>	<input type="text" value="Good"/>	<b>Status</b>	<input type="text" value="pass"/>
<b>Sensor Component</b>	<input type="text" value="Shelter Condition"/>	<b>Condition</b>	<input type="text" value="Good"/>	<b>Status</b>	<input type="text" value="pass"/>
<b>Sensor Component</b>	<input type="text" value="Shelter Floor"/>	<b>Condition</b>	<input type="text" value="Good"/>	<b>Status</b>	<input type="text" value="pass"/>
<b>Sensor Component</b>	<input type="text" value="Shelter Temp Control"/>	<b>Condition</b>	<input type="text" value="Functioning"/>	<b>Status</b>	<input type="text" value="pass"/>
<b>Sensor Component</b>	<input type="text" value="Signal Cable"/>	<b>Condition</b>	<input type="text" value="Good"/>	<b>Status</b>	<input type="text" value="pass"/>
<b>Sensor Component</b>	<input type="text" value="Tubing Type"/>	<b>Condition</b>	<input type="text" value="1/4 teflon"/>	<b>Status</b>	<input type="text" value="pass"/>
<b>Sensor Component</b>	<input type="text" value="Shelter Door"/>	<b>Condition</b>	<input type="text" value="Good"/>	<b>Status</b>	<input type="text" value="pass"/>
<b>Sensor Component</b>	<input type="text" value="Sample Train"/>	<b>Condition</b>	<input type="text" value="Good"/>	<b>Status</b>	<input type="text" value="pass"/>

# Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none		HOW191	Eric Hebert	10/10/2012	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.26	0.40		

<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Shelter Temperatur
<b>Serial Number</b>	01D102193	<b>Tfer Desc.</b>	RTD translator
<b>Tfer ID</b>	01231		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Shelter Temperatur
<b>Serial Number</b>	01H0060	<b>Tfer Desc.</b>	RTD probe
<b>Tfer ID</b>	01230		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	20.11	20.10	0.000	19.9	C	-0.22
primary	Temp Mid Range	20.40	20.39	0.000	20.0	C	-0.4
primary	Temp Mid Range	21.75	21.74	0.000	21.6	C	-0.17

# Field Systems Data Form

F-02058-1500-S1-rev001

Site ID  Technician  Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Howland"/>
Operating Group	<input type="text" value="University of ME"/>	Map Scale	<input type="text"/>
AQS #	<input type="text"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>	QAPP Latitude	<input type="text"/>
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Longitude	<input type="text"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Elevation Meters	<input type="text"/>
Land Use	<input type="text" value="Woodland - mixed"/>	QAPP Declination	<input type="text"/>
Terrain	<input type="text" value="flat, gently rolling"/>	QAPP Declination Date	<input type="text"/>
Conforms to MLM	<input type="text" value="Yes"/>	Audit Latitude	<input type="text" value="45.203963"/>
Site Telephone	<input type="text"/>	Audit Longitude	<input type="text" value="-68.740041"/>
Site Address 1	<input type="text"/>	Audit Elevation	<input type="text" value="68"/>
Site Address 2	<input type="text"/>	Audit Declination	<input type="text" value="-17"/>
County	<input type="text" value="Penobscot"/>		
City, State	<input type="text" value="Howland, ME"/>		
Zip Code	<input type="text"/>	Present	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text" value="John Lee"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text" value="(207) 581-2930"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text" value="jtlee@maine.edu"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="custom"/>	Model <input type="text" value="custom"/>	Shelter Size <input type="text" value="800 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The custom built shelter is clean and organized."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		
Driving Directions	<input type="text" value="Arrange for site visit and access with the site operator."/>		

# Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

**Siting Criteria Comment**

The CASTNET filter pack at this location is located above a tree canopy at approximately 23.5 meters from the ground. A second filter is located below the canopy at approximately 2 meters. This is an AmeriFlux site which is approximately 2.5 km to the SW of the HOW132 CASTNET site. See the map included as Figure 1.

# Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- |    |  |                                     |     |
|----|--|-------------------------------------|-----|
| 1  | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?  | <input checked="" type="checkbox"/> | N/A |
| 2  | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)     | <input checked="" type="checkbox"/> | N/A |
| 3  | Are the tower and sensors plumb?   | <input checked="" type="checkbox"/> | N/A |
| 4  | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?  | <input checked="" type="checkbox"/> |     |
| 5  | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> |     |
| 6  | Is the solar radiation sensor plumb?   | <input checked="" type="checkbox"/> | N/A |
| 7  | Is it sited to avoid shading, or any artificial or reflected light?  | <input checked="" type="checkbox"/> | N/A |
| 8  | Is the rain gauge plumb?   | <input checked="" type="checkbox"/> | N/A |
| 9  | Is it sited to avoid sheltering effects from buildings, trees, towers, etc?  | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north?  | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees?   | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Other than a temperature sensor at each CASTNET filter location the meteorological instrumentation is being operated by the University of Maine and AmeriFlux.

# Field Systems Data Form

F-02058-1500-S4-rev001

Site ID  Technician  Site Visit Date

- 1 Do all the meteorological sensors appear to be intact, in good condition, and well maintained?
- 2 Are all the meteorological sensors operational online, and reporting data?
- 3 Are the shields for the temperature and RH sensors clean?
- 4 Are the aspirated motors working?
- 5 Is the solar radiation sensor's lens clean and free of scratches?
- 6 Is the surface wetness sensor grid clean and undamaged?
- 7 Are the sensor signal and power cables intact, in good condition, and well maintained?
- 8 Are the sensor signal and power cable connections protected from the elements and well maintained?

Parameter	Manufacturer	Model	S/N	Client ID
Temperature	RM Young	41342	illegible	00245

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:



# Field Systems Data Form

F-02058-1500-S5-rev001

Site ID  Technician  Site Visit Date

**Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E**

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?  in canopy

**Pollutant analyzers and deposition equipment operations and maintenance**

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)  At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

Parameter	Manufacturer	Model	S/N	Client ID
Filter pack flow pump	Thomas	107CAB18	060300019983	04921
Ozone	ThermoElectron Inc	49i A1NAA	1104347326	unknown
Zero air pump	Werther International	C 70/4	000821900	06908
Filter pack flow pump	Thomas	107CAB18	060400022686	06022

**Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:**

Ozone measurements at this location are being conducted at 8 levels through the tree canopy from 2 meters to 23.5 meters. Three minute measurements for each height are aggregated into an hourly average for each height to produce a through-canopy ozone profile.

# Field Systems Data Form

F-02058-1500-S6-rev001

Site ID  Technician  Site Visit Date

**DAS, sensor translators, and peripheral equipment operations and maintenance**

- 1 Do the DAS instruments appear to be in good condition and well maintained?
  - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
  - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry?
  - 4 Are the signal connections protected from the weather and well maintained?
  - 5 Are the signal leads connected to the correct DAS channel?
  - 6 Are the DAS, sensor translators, and shelter properly grounded?
  - 7 Does the instrument shelter have a stable power source?
  - 8 Is the instrument shelter temperature controlled?
- Stable**

**Grounded**
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Campbell	CR3000	2127	000348
Modem	Raven	H4222-C	0808311250	06470

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

**Documentation**

**Does the site have the required instrument and equipment manuals?**

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

**Does the site have the required and most recent QC documents and report forms?**

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?  Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S8-rev001

Site ID

Technician

Site Visit Date

**Site operation procedures**

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

**Are regular operational QA/QC checks performed on meteorological instruments?**

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

**Are regular operational QA/QC checks performed on the ozone analyzer?**

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S9-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

- |   |  |                                     |                         |
|---|--|-------------------------------------|-------------------------|
| 1 | Is the filter pack being changed every Tuesday as scheduled?                         | <input checked="" type="checkbox"/> |                         |
| 2 | Are the Site Status Report Forms being completed and filed correctly?                | <input checked="" type="checkbox"/> |                         |
| 3 | Are data downloads and backups being performed as scheduled?                         | <input type="checkbox"/>            | No longer required      |
| 4 | Are general observations being made and recorded? How?                               | <input checked="" type="checkbox"/> | SSRF                    |
| 5 | Are site supplies on-hand and replenished in a timely fashion?                       | <input checked="" type="checkbox"/> |                         |
| 6 | Are sample flow rates recorded? How?   | <input checked="" type="checkbox"/> | SSRF                    |
| 7 | Are samples sent to the lab on a regular schedule in a timely fashion?               | <input checked="" type="checkbox"/> |                         |
| 8 | Are filters protected from contamination during handling and shipping? How?          | <input checked="" type="checkbox"/> | Clean gloves on and off |
| 9 | Are the site conditions reported regularly to the field operations manager or staff? | <input checked="" type="checkbox"/> |                         |

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/> <input type="text"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

---

## *Site Inventory by Site Visit*

---

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

---

*HOW191-B-Eric Hebert-10/10/2012*

1	10/10/2012	DAS	Campbell	000348	CR3000	2127
2	10/10/2012	Filter pack flow pump	Thomas	06022	107CAB18	060400022686
3	10/10/2012	Flow Rate	Apex	000671	AXMC105LPMDPCV	illegible
4	10/10/2012	Temperature2meter	RM Young	04449	41342VC	4547

# Flow Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
Apex	illegible		HOW191-B	Eric Hebert	10/10/2012	Flow Rate	000671

<b>Mfg</b>	BIOS	<b>Parameter</b>	Flow Rate
<b>Serial Number</b>	122974	<b>Tfer Desc.</b>	BIOS 220-H
<b>Tfer ID</b>	01416		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	2/6/2012	<b>CorrCoff</b>	1.00000

<b>DAS 1:</b>	<b>DAS 2:</b>	<b>Cal Factor Zero</b>	-0.01
<b>A Avg % Diff:</b>	<b>A Max % Di</b>	<b>Cal Factor Full Scale</b>	0.99
0.46%	0.90%	<b>Rotometer Reading:</b>	0

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	0.00	0.000	0.02	l/m	l/m	
primary	leak check	0.000	0.000	0.03	0.000	0.04	l/m	l/m	
primary	test pt 1	0.000	1.502	1.49	1.507	1.50	l/m	l/m	-0.16%
primary	test pt 2	0.000	1.505	1.49	1.505	1.50	l/m	l/m	-0.31%
primary	test pt 3	0.000	1.504	1.49	1.505	1.49	l/m	l/m	-0.90%

<b>Sensor Component</b>	Leak Test	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Filter Azimuth	<b>Condition</b>	135 deg	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Depth	<b>Condition</b>	1.5 cm	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Position	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Moisture Present	<b>Condition</b>	No moisture present	<b>Status</b>	pass
<b>Sensor Component</b>	Rotometer Condition	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>	See comments	<b>Status</b>	pass
<b>Sensor Component</b>	Tubing Condition	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Distance	<b>Condition</b>	4.5 cm	<b>Status</b>	pass

# Temperature Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
RM Young	4547		HOW191-B	Eric Hebert	10/10/2012	Temperature	04449

**DAS 1:**  
Abs Avg Err   Abs Max Er

**DAS 2:**  
Abs Avg Err   Abs Max Er

<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01D102193	<b>Tfer Desc.</b>	RTD translator
<b>Tfer ID</b>	01231		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01H0060	<b>Tfer Desc.</b>	RTD probe
<b>Tfer ID</b>	01230		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000

0.08	0.17		
------	------	--	--

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	0.05	0.07	0.000	0.1	C	0.07
primary	Temp Mid Range	23.39	23.37	0.000	23.4	C	-0.01
primary	Temp High Range	49.10	49.04	0.000	49.2	C	0.17

<b>Sensor Component</b>	Shield	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Blower Status Switch	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Blower	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>	See comments	<b>Status</b>	pass



# Site Visit Comments

<b>Parameter</b>	<b>Site</b>	<b>Technician</b>	<b>S.V. Date</b>	<b>Component</b>	<b>Mfg</b>	<b>Serial No.</b>	<b>Hazard</b>	<b>Problem</b>
Flow Rate	HOW191-B	Eric Hebert	10/10/2012	System Memo	Apex	3652	<input type="checkbox"/>	<input type="checkbox"/>
This parameter is being measured at 2 meters from the ground and below a tree canopy.								
Temperature	HOW191-B	Eric Hebert	10/10/2012	System Memo	RM Young	3693	<input type="checkbox"/>	<input type="checkbox"/>
This parameter is being measured at 2 meters from the ground and below a tree canopy.								

## *Site Inventory by Site Visit*

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>HOW132-Eric Hebert-10/11/2012</i>						
1	10/11/2012	Computer	Dell	000501	D610	unknown
2	10/11/2012	DAS	Campbell	000352	CR3000	2130
3	10/11/2012	Elevation	Elevation	None	1	None
4	10/11/2012	Filter pack flow pump	Thomas	01423	107CA18	00002560587
5	10/11/2012	Flow Rate	Apex	000666	AXMC105LPMDPCV	54763
6	10/11/2012	Infrastructure	Infrastructure	none	none	none
7	10/11/2012	Met tower	Universal Tower	03533	unknown	none
8	10/11/2012	Modem	Raven	06483	H4222-C	0808310816
9	10/11/2012	Ozone	ThermoElectron Inc	000737	49i A1NAA	1105347912
10	10/11/2012	Ozone Standard	ThermoElectron Inc	000373	49i A3NAA	0726124685
11	10/11/2012	Sample Tower	Aluma Tower	03534	A	none
12	10/11/2012	Shelter Temperature	Campbell	none	107-L	unknown
13	10/11/2012	Shield (10 meter)	RM Young	02392	Aspirated 43408	none
14	10/11/2012	Siting Criteria	Siting Criteria	None	1	None
15	10/11/2012	Temperature	RM Young	04448	41342	4546
16	10/11/2012	Zero air pump	Werther International	06928	C 70/4	000822222

# DAS Data Form

DAS Time Max Error:

<b>Mfg</b>	<b>Serial Number</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Use Desc.</b>
Campbell	2130	HOW132	Eric Hebert	10/11/2012	DAS	Primary

<b>Das Date:</b>	<input type="text" value="10/13/2012"/>	<b>Audit Date</b>	<input type="text" value="10/13/2012"/>
<b>Das Time:</b>	<input type="text" value="12:08:00"/>	<b>Audit Time</b>	<input type="text" value="12:08:00"/>
<b>Das Day:</b>	<input type="text" value="287"/>	<b>Audit Day</b>	<input type="text" value="287"/>

<b>Low Channel:</b>	<b>High Channel:</b>		
<b>Avg Diff:</b>	<b>Max Diff:</b>	<b>Avg Diff:</b>	<b>Max Diff:</b>
<input type="text" value="0.0000"/>	<input type="text" value="0.0001"/>	<input type="text" value="0.0000"/>	<input type="text" value="0.0001"/>

<b>Mfg</b>	<input type="text" value="Datel"/>	<b>Parameter</b>	<input type="text" value="DAS"/>
<b>Serial Number</b>	<input type="text" value="4000392"/>	<b>Tfer Desc.</b>	<input type="text" value="Source generator (D"/>
<b>Tfer ID</b>	<input type="text" value="01321"/>		
<b>Slope</b>	<input type="text" value="1.00000"/>	<b>Intercept</b>	<input type="text" value="0.00000"/>
<b>Cert Date</b>	<input type="text" value="2/13/2012"/>	<b>CorrCoff</b>	<input type="text" value="1.00000"/>
<b>Mfg</b>	<input type="text" value="Fluke"/>	<b>Parameter</b>	<input type="text" value="DAS"/>
<b>Serial Number</b>	<input type="text" value="86590148"/>	<b>Tfer Desc.</b>	<input type="text" value="DVM"/>
<b>Tfer ID</b>	<input type="text" value="01310"/>		
<b>Slope</b>	<input type="text" value="1.00000"/>	<b>Intercept</b>	<input type="text" value="0.00000"/>
<b>Cert Date</b>	<input type="text" value="2/9/2012"/>	<b>CorrCoff</b>	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.1000	0.1000	V	V	0.0000
7	0.3000	0.3000	0.3000	V	V	0.0000
7	0.5000	0.5001	0.5001	V	V	0.0000
7	0.7000	0.7002	0.7001	V	V	-0.0001
7	0.9000	0.9002	0.9001	V	V	-0.0001
7	1.0000	1.0003	1.0002	V	V	-0.0001

# Flow Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
Apex	54763		HOW132	Eric Hebert	10/11/2012	Flow Rate	000666

<b>Mfg</b>	BIOS	<b>Parameter</b>	Flow Rate
<b>Serial Number</b>	122974	<b>Tfer Desc.</b>	BIOS 220-H
<b>Tfer ID</b>	01416		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	2/6/2012	<b>CorrCoff</b>	1.00000

<b>DAS 1:</b>	<b>DAS 2:</b>	<b>Cal Factor Zero</b>	-0.018
<b>A Avg % Diff:</b>	<b>A Max % Di</b>	<b>Cal Factor Full Scale</b>	0.987
1.55%	1.72%	<b>Rotometer Reading:</b>	1.45

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	0.02	0.028	0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.02	0.021	0.00	l/m	l/m	
primary	test pt 1	0.000	1.475	1.52	1.509	1.50	l/m	l/m	1.69%
primary	test pt 2	0.000	1.475	1.52	1.509	1.50	l/m	l/m	1.72%
primary	test pt 3	0.000	1.482	1.52	1.509	1.50	l/m	l/m	1.24%

<b>Sensor Component</b>	Leak Test	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Filter Azimuth	<b>Condition</b>	90 Deg	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Depth	<b>Condition</b>	3.5 cm	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Position	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Moisture Present	<b>Condition</b>	No moisture present	<b>Status</b>	pass
<b>Sensor Component</b>	Rotometer Condition	<b>Condition</b>	Clean and dry	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Tubing Condition	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Distance	<b>Condition</b>	6.0 cm	<b>Status</b>	pass

# Ozone Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
ThermoElectron Inc	1105347912		HOW132	Eric Hebert	10/11/2012	Ozone	000737

<b>Slope:</b>	0.98028	<b>Slope:</b>	0.00000
<b>Intercept</b>	0.17489	<b>Intercept</b>	0.00000
<b>CorrCoff</b>	0.99990	<b>CorrCoff</b>	0.00000

<b>DAS 1:</b>	<b>DAS 2:</b>
<b>A Avg % Diff:</b>	<b>A Avg %Dif</b>
<b>A Max % Di</b>	<b>A Max % Di</b>
1.5%	2.6%

<b>Mfg</b>	ThermoElectron Inc	<b>Parameter</b>	ozone
<b>Serial Number</b>	517112175	<b>Tfer Desc.</b>	Ozone primary stan
<b>Tfer ID</b>	01111		
<b>Slope</b>	1.00987	<b>Intercept</b>	0.07483
<b>Cert Date</b>	3/23/2012	<b>CorrCoff</b>	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.56	0.48	0.37	ppb	
primary	2	26.77	26.43	25.99	ppb	-1.66%
primary	3	64.52	63.81	63.30	ppb	-0.80%
primary	4	82.44	81.56	80.70	ppb	-1.05%
primary	5	104.95	103.85	101.20	ppb	-2.55%

<b>Sensor Component</b>	Cell B Noise	<b>Condition</b>	1.0 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Tmp.	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Fullscale Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Inlet Filter Condition	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Line Loss	<b>Condition</b>	Not tested	<b>Status</b>	pass
<b>Sensor Component</b>	Offset	<b>Condition</b>	-0.10	<b>Status</b>	pass
<b>Sensor Component</b>	Span	<b>Condition</b>	1.035	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Freq.	<b>Condition</b>	85.7 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Sample Train	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Pressure	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Flow	<b>Condition</b>	0.72 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Tmp.	<b>Condition</b>	33.5 C	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Pressure	<b>Condition</b>	738 mmHg	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Noise	<b>Condition</b>	0.9 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Freq.	<b>Condition</b>	81.6 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Flow	<b>Condition</b>	0.70 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Battery Backup	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Zero Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass

# Temperature Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Tag Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
RM Young	4546	HOW132	Eric Hebert	10/11/2012	Temperature	04448

**DAS 1:**  
 Abs Avg Err    Abs Max Er

**DAS 2:**  
 Abs Avg Err    Abs Max Er

<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01D102193	<b>Tfer Desc.</b>	RTD translator
<b>Tfer ID</b>	01231		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01H0060	<b>Tfer Desc.</b>	RTD probe
<b>Tfer ID</b>	01230		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000

0.14	0.25		
------	------	--	--

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	0.14	0.16	0.000	0.1	C	-0.05
primary	Temp Mid Range	23.29	23.27	0.000	23.4	C	0.12
primary	Temp High Range	47.88	47.83	0.000	48.1	C	0.25

<b>Sensor Component</b>	Shield	<b>Condition</b>	Moderately clean	<b>Status</b>	pass
<b>Sensor Component</b>	Blower Status Switch	<b>Condition</b>	Functioning	<b>Status</b>	pass
<b>Sensor Component</b>	Blower	<b>Condition</b>	Functioning	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass

## Infrastructure Data For

Site ID  Technician  Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Unv. Of Maine"/>	<input type="text" value="none"/>	<input type="text" value="2400 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Poor"/>	Status	<input type="text" value="Fail"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

# Shelter Temperature Data For

Mfg	Serial Number	Tag Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	unknown	HOW132	Eric Hebert	10/11/2012	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.48	0.65		

<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Shelter Temperatur
<b>Serial Number</b>	01D102193	<b>Tfer Desc.</b>	RTD translator
<b>Tfer ID</b>	01231		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Shelter Temperatur
<b>Serial Number</b>	01H0060	<b>Tfer Desc.</b>	RTD probe
<b>Tfer ID</b>	01230		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	19.42	19.41	0.000	20.0	C	0.55
primary	Temp Mid Range	18.81	18.80	0.000	19.5	C	0.65
primary	Temp Mid Range	18.40	18.39	0.000	18.6	C	0.24



# Field Systems Comments

**1 Parameter:** SiteOpsProcComm

The site operator reported that he does not always use gloves to handle the filters consistently.

**2 Parameter:** SiteOpsProcedures

The ozone sample inlet filter is replaced and the sample train is leak tested once each month.

**3 Parameter:** SitingCriteriaCom

There is a small power plant about 30 km northeast of the site. It is on-line approximately 50% of the time. The site is near a plantation and within 20 meters of the tree line.

**4 Parameter:** ShelterCleanNotes

The shelter is cleaner than it has been during previous audit visits

**5 Parameter:** PollAnalyzerCom

There is a tree branch that contacts the filter enclosure and the filter pack when the tower is lowered and raised.

# Field Systems Data Form

F-02058-1500-S1-rev001

Site ID  Technician  Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Howland"/>
Operating Group	<input type="text" value="University of ME"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="23-019-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text" value="45.2158"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text" value="-68.7085"/>
Land Use	<input type="text" value="woodland- mixed, wetland"/>	QAPP Elevation Meters	<input type="text" value="69"/>
Terrain	<input type="text" value="flat, gently rolling"/>	QAPP Declination	<input type="text" value="18.02"/>
Conforms to MLM	<input type="text" value="Yes"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text" value="(207) 745-6841"/>	Audit Latitude	<input type="text" value="45.215607"/>
Site Address 1	<input type="text" value="Lagrange Rd."/>	Audit Longitude	<input type="text" value="-68.70851"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="66"/>
County	<input type="text" value="Penobscot"/>	Audit Declination	<input type="text" value="-17"/>
City, State	<input type="text" value="Howland, ME"/>		
Zip Code	<input type="text" value="04453"/>	<b>Present</b>	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="inspected Feb 2007"/>
Primary Operator	<input type="text" value="John Lee"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text" value="(207) 581-2930"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text" value="jtleee@maine.edu"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text" value="none"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Unv. Of Maine"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
	Model <input type="text" value="none"/>	Shelter Size <input type="text" value="2400 cuft"/>	
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is cleaner than it has been during previous audit visits"/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

**Driving Directions**

# Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	30 km	<input type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	20 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

**Siting Criteria Comment**

There is a small power plant about 30 km northeast of the site. It is on-line approximately 50% of the time. The site is near a plantation and within 20 meters of the tree line.

# Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- |    |  |                                     |     |
|----|--|-------------------------------------|-----|
| 1  | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?  | <input checked="" type="checkbox"/> | N/A |
| 2  | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)     | <input checked="" type="checkbox"/> | N/A |
| 3  | Are the tower and sensors plumb?   | <input checked="" type="checkbox"/> | N/A |
| 4  | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?  | <input checked="" type="checkbox"/> |     |
| 5  | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> |     |
| 6  | Is the solar radiation sensor plumb?   | <input checked="" type="checkbox"/> | N/A |
| 7  | Is it sited to avoid shading, or any artificial or reflected light?  | <input checked="" type="checkbox"/> | N/A |
| 8  | Is the rain gauge plumb?   | <input checked="" type="checkbox"/> | N/A |
| 9  | Is it sited to avoid sheltering effects from buildings, trees, towers, etc?  | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north?  | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees?   | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S4-rev001

Site ID  Technician  Site Visit Date

- |   |  |                                     |     |
|---|--|-------------------------------------|-----|
| 1 | Do all the meteorological sensors appear to be intact, in good condition, and well maintained?     | <input checked="" type="checkbox"/> | N/A |
| 2 | Are all the meteorological sensors operational online, and reporting data?                         | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the shields for the temperature and RH sensors clean?  | <input checked="" type="checkbox"/> |     |
| 4 | Are the aspirated motors working?  | <input checked="" type="checkbox"/> |     |
| 5 | Is the solar radiation sensor's lens clean and free of scratches?                                  | <input checked="" type="checkbox"/> | N/A |
| 6 | Is the surface wetness sensor grid clean and undamaged?  | <input checked="" type="checkbox"/> | N/A |
| 7 | Are the sensor signal and power cables intact, in good condition, and well maintained?             | <input checked="" type="checkbox"/> |     |
| 8 | Are the sensor signal and power cable connections protected from the elements and well maintained? | <input checked="" type="checkbox"/> |     |

Parameter	Manufacturer	Model	S/N	Client ID
Temperature	RM Young	41342	4546	04448
Shield (10 meter)	RM Young	Aspirated 43408	none	02392
Met tower	Universal Tower	unknown	none	03533

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S5-rev001

Site ID  Technician  Site Visit Date

**Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E**

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?  One tree interfering

**Pollutant analyzers and deposition equipment operations and maintenance**

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube. 1/4 teflon by 16 meters
- 4 Describe dry dep sample tube. 3/8 teflon by 16 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)  At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?  Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	A	none	03534
Ozone	ThermoElectron Inc	49i A1NAA	1105347912	000737
Filter pack flow pump	Thomas	107CA18	00002560587	01423
Zero air pump	Werther International	C 70/4	000822222	06928

**Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:**

There is a tree branch that contacts the filter enclosure and the filter pack when the tower is lowered and raised.

# Field Systems Data Form

F-02058-1500-S6-rev001

Site ID  Technician  Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
  - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
  - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry?  Met sensors only
  - 4 Are the signal connections protected from the weather and well maintained?
  - 5 Are the signal leads connected to the correct DAS channel?
  - 6 Are the DAS, sensor translators, and shelter properly grounded?
  - 7 Does the instrument shelter have a stable power source?
  - 8 Is the instrument shelter temperature controlled?
- Stable**

**Grounded**
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D610	unknown	000501
DAS	Campbell	CR3000	2130	000352
Modem	Raven	H4222-C	0808310816	06483

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Nov 2009	<input type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	July 1990	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?  Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:



# Field Systems Data Form

F-02058-1500-S8-rev001

Site ID  Technician  Site Visit Date

**Site operation procedures**

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

**Are regular operational QA/QC checks performed on meteorological instruments?**

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

**Are regular operational QA/QC checks performed on the ozone analyzer?**

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Monthly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S9-rev001

Site ID  Technician  Site Visit Date

**Site operation procedures**

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input type="checkbox"/>	
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator reported that he does not always use gloves to handle the filters consistently.

---

## *Site Inventory by Site Visit*

---

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>ASH135-Eric Hebert-10/12/2012</i>						
1	10/12/2012	Computer	Dell	000430	D630	unknown
2	10/12/2012	DAS	Campbell	000343	CR3000	2122
3	10/12/2012	Elevation	Elevation	None	1	None
4	10/12/2012	Filter pack flow pump	Thomas	01458	107CA110	028871488
5	10/12/2012	Flow Rate	Apex	000648	AXMC105LPMDPCV	54777
6	10/12/2012	Infrastructure	Infrastructure	none	none	none
7	10/12/2012	Modem	Raven	06471	H4222-C	0808311148
8	10/12/2012	Ozone	ThermoElectron Inc	000743	49i A1NAA	1105347321
9	10/12/2012	Ozone Standard	ThermoElectron Inc	000438	49i A3NAA	CM08200014
10	10/12/2012	Sample Tower	Aluma Tower	03536	A	none
11	10/12/2012	Shelter Temperature	Campbell	none	107-L	none
12	10/12/2012	Siting Criteria	Siting Criteria	None	1	None
13	10/12/2012	Temperature	RM Young	06389	41342	13994
14	10/12/2012	UPS	APC	06797	RS900	unknown
15	10/12/2012	Zero air pump	Werther International	06923	C 70/4	000836208

# DAS Data Form

DAS Time Max Error:

<b>Mfg</b>	<b>Serial Number</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Use Desc.</b>
Campbell	2122	ASH135	Eric Hebert	10/12/2012	DAS	Primary

<b>Das Date:</b>	<input type="text" value="10/12/2012"/>	<b>Audit Date</b>	<input type="text" value="10/12/2012"/>
<b>Das Time:</b>	<input type="text" value="10:00:15"/>	<b>Audit Time</b>	<input type="text" value="10:00:15"/>
<b>Das Day:</b>	<input type="text" value="286"/>	<b>Audit Day</b>	<input type="text" value="286"/>

<b>Low Channel:</b>	<b>High Channel:</b>		
<b>Avg Diff:</b>	<b>Max Diff:</b>	<b>Avg Diff:</b>	<b>Max Diff:</b>
<input type="text" value="0.0000"/>	<input type="text" value="0.0001"/>	<input type="text" value="0.0000"/>	<input type="text" value="0.0001"/>

<b>Mfg</b>	<input type="text" value="Datel"/>	<b>Parameter</b>	<input type="text" value="DAS"/>
<b>Serial Number</b>	<input type="text" value="4000392"/>	<b>Tfer Desc.</b>	<input type="text" value="Source generator (D"/>
<b>Tfer ID</b>	<input type="text" value="01321"/>		
<b>Slope</b>	<input type="text" value="1.00000"/>	<b>Intercept</b>	<input type="text" value="0.00000"/>
<b>Cert Date</b>	<input type="text" value="2/13/2012"/>	<b>CorrCoff</b>	<input type="text" value="1.00000"/>
<b>Mfg</b>	<input type="text" value="Fluke"/>	<b>Parameter</b>	<input type="text" value="DAS"/>
<b>Serial Number</b>	<input type="text" value="86590148"/>	<b>Tfer Desc.</b>	<input type="text" value="DVM"/>
<b>Tfer ID</b>	<input type="text" value="01310"/>		
<b>Slope</b>	<input type="text" value="1.00000"/>	<b>Intercept</b>	<input type="text" value="0.00000"/>
<b>Cert Date</b>	<input type="text" value="2/9/2012"/>	<b>CorrCoff</b>	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.1000	0.1000	V	V	0.0000
7	0.3000	0.3001	0.3001	V	V	0.0000
7	0.5000	0.5001	0.5001	V	V	0.0000
7	0.7000	0.7002	0.7002	V	V	0.0000
7	0.9000	0.9002	0.9003	V	V	0.0001
7	1.0000	1.0003	1.0003	V	V	0.0000

# Flow Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
Apex	54777		ASH135	Eric Hebert	10/12/2012	Flow Rate	000648

<b>Mfg</b>	BIOS	<b>Parameter</b>	Flow Rate
<b>Serial Number</b>	122974	<b>Tfer Desc.</b>	BIOS 220-H
<b>Tfer ID</b>	01416		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	2/6/2012	<b>CorrCoff</b>	1.00000

<b>DAS 1:</b>	<b>DAS 2:</b>	<b>Cal Factor Zero</b>	0
<b>A Avg % Diff:</b>	<b>A Max % Di</b>	<b>Cal Factor Full Scale</b>	1.01
0.10%	0.11%	<b>Rotometer Reading:</b>	1.5

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	0.00	0.003	0.02	l/m	l/m	
primary	leak check	0.000	0.000	0.03	0.070	0.05	l/m	l/m	
primary	test pt 1	0.000	1.509	1.50	1.500	1.51	l/m	l/m	0.07%
primary	test pt 2	0.000	1.508	1.50	1.500	1.51	l/m	l/m	0.11%
primary	test pt 3	0.000	1.512	1.50	1.500	1.51	l/m	l/m	-0.11%

<b>Sensor Component</b>	Leak Test	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Filter Azimuth	<b>Condition</b>	280 Deg	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Depth	<b>Condition</b>	3.5 cm	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Position	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Moisture Present	<b>Condition</b>	No moisture present	<b>Status</b>	pass
<b>Sensor Component</b>	Rotometer Condition	<b>Condition</b>	Clean and dry	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Tubing Condition	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Distance	<b>Condition</b>	5.5 cm	<b>Status</b>	pass

# Ozone Data Form

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347321	ASH135	Eric Hebert	10/12/2012	Ozone	000743

<b>Slope:</b>	1.01773	<b>Slope:</b>	0.00000
<b>Intercept</b>	-0.34656	<b>Intercept</b>	0.00000
<b>CorrCoff</b>	0.99999	<b>CorrCoff</b>	0.00000

<b>DAS 1:</b>	<b>DAS 2:</b>		
<b>A Avg % Diff:</b>	<b>A Max % Di</b>	<b>A Avg %Dif</b>	<b>A Max % Di</b>
1.4%	1.5%		

<b>Mfg</b>	ThermoElectron Inc	<b>Parameter</b>	ozone
<b>Serial Number</b>	517112175	<b>Tfer Desc.</b>	Ozone primary stan
<b>Tfer ID</b>	01111		
<b>Slope</b>	1.00987	<b>Intercept</b>	0.07483
<b>Cert Date</b>	3/23/2012	<b>CorrCoff</b>	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.49	0.41	-0.13	ppb	
primary	2	35.73	35.30	35.78	ppb	1.36%
primary	3	66.72	65.99	66.86	ppb	1.32%
primary	4	84.33	83.43	84.70	ppb	1.52%
primary	5	118.09	116.86	118.40	ppb	1.32%

<b>Sensor Component</b>	Cell B Noise	<b>Condition</b>	1.4 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Tmp.	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Fullscale Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Inlet Filter Condition	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Line Loss	<b>Condition</b>	Not tested	<b>Status</b>	pass
<b>Sensor Component</b>	Offset	<b>Condition</b>	0.20	<b>Status</b>	pass
<b>Sensor Component</b>	Span	<b>Condition</b>	1.059	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Freq.	<b>Condition</b>	94.9 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Sample Train	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Pressure	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Flow	<b>Condition</b>	0.64 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Tmp.	<b>Condition</b>	32.1 C	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Pressure	<b>Condition</b>	720 mmHg	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Noise	<b>Condition</b>	1.7 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Freq.	<b>Condition</b>	66.1 kHz	<b>Status</b>	Fail
<b>Sensor Component</b>	Cell A Flow	<b>Condition</b>	0.70 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Battery Backup	<b>Condition</b>	Functioning	<b>Status</b>	pass
<b>Sensor Component</b>	Zero Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass

# Temperature Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Tag</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
RM Young	13994		ASH135	Eric Hebert	10/12/2012	Temperature	06389

<b>DAS 1:</b>	<b>DAS 2:</b>
<b>Abs Avg Err</b>	<b>Abs Max Er</b>
<b>Abs Avg Err</b>	<b>Abs Max Er</b>

<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01D102193	<b>Tfer Desc.</b>	RTD translator
<b>Tfer ID</b>	01231		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01H0060	<b>Tfer Desc.</b>	RTD probe
<b>Tfer ID</b>	01230		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000

0.06	0.09		
------	------	--	--

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	0.03	0.05	0.000	0.1	C	0.09
primary	Temp Mid Range	21.90	21.89	0.000	22.0	C	0.08
primary	Temp High Range	46.61	46.56	0.000	46.6	C	0.01

<b>Sensor Component</b>	Shield	<b>Condition</b>	Moderately clean	<b>Status</b>	pass
<b>Sensor Component</b>	Blower Status Switch	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Blower	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass

## Infrastructure Data For

Site ID  Technician  Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2149-17)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>



# Shelter Temperature Data For

Mfg	Serial Number	Tag Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	ASH135	Eric Hebert	10/12/2012	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.55	0.84		

<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Shelter Temperatur
<b>Serial Number</b>	01D102193	<b>Tfer Desc.</b>	RTD translator
<b>Tfer ID</b>	01231		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Shelter Temperatur
<b>Serial Number</b>	01H0060	<b>Tfer Desc.</b>	RTD probe
<b>Tfer ID</b>	01230		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	19.03	19.02	0.000	19.9	C	0.84
primary	Temp Mid Range	18.12	18.11	0.000	18.6	C	0.5
primary	Temp Mid Range	17.95	17.94	0.000	17.6	C	-0.31

# Field Systems Comments

**1 Parameter:** DasComments

The met tower has been removed and the 10 meter temperature sensor is mounted in a naturally aspirated shield on the sample tower.

**2 Parameter:** SiteOpsProcedures

The ozone inlet filter is replaced and the sample train is leak tested once each month.

**3 Parameter:** ShelterCleanNotes

The shelter is in good condition, clean, and very well organized.

**4 Parameter:** SitingCriteriaCom

There is an evergreen plantation 20 meters south of the site.

# Field Systems Data Form

F-02058-1500-S1-rev001

Site ID  Technician  Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Squa Pan"/>
Operating Group	<input type="text" value="private"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="23-003-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text" value="46.6039"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text" value="-68.4142"/>
Land Use	<input type="text" value="agriculture, woodland - mixed"/>	QAPP Elevation Meters	<input type="text" value="235"/>
Terrain	<input type="text" value="gently rolling"/>	QAPP Declination	<input type="text" value="18.7"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text" value="2/22/2006"/>
Site Telephone	<input type="text" value="(207) 435-6482"/>	Audit Latitude	<input type="text" value="46.603832"/>
Site Address 1	<input type="text" value="Radar Road"/>	Audit Longitude	<input type="text" value="-68.413227"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="231"/>
County	<input type="text" value="Aroostook"/>	Audit Declination	<input type="text" value="-18.2"/>
City, State	<input type="text" value="Ashland, ME"/>		
Zip Code	<input type="text" value="04732"/>	<b>Present</b>	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Primary Operator	<input type="text" value="Jodi Reese"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>

Shelter Working Room  Make  Model  Shelter Size

Shelter Clean  Notes

Site OK  Notes

Driving Directions

# Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	20 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

# Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- |    |  |                                     |     |
|----|--|-------------------------------------|-----|
| 1  | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?  | <input checked="" type="checkbox"/> | N/A |
| 2  | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)     | <input checked="" type="checkbox"/> | N/A |
| 3  | Are the tower and sensors plumb?   | <input checked="" type="checkbox"/> | N/A |
| 4  | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?  | <input checked="" type="checkbox"/> |     |
| 5  | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> |     |
| 6  | Is the solar radiation sensor plumb?   | <input checked="" type="checkbox"/> | N/A |
| 7  | Is it sited to avoid shading, or any artificial or reflected light?  | <input checked="" type="checkbox"/> | N/A |
| 8  | Is the rain gauge plumb?   | <input checked="" type="checkbox"/> | N/A |
| 9  | Is it sited to avoid sheltering effects from buildings, trees, towers, etc?  | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north?  | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees?   | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S4-rev001

Site ID  Technician  Site Visit Date

- |   |  |                                     |     |
|---|--|-------------------------------------|-----|
| 1 | Do all the meteorological sensors appear to be intact, in good condition, and well maintained?     | <input checked="" type="checkbox"/> | N/A |
| 2 | Are all the meteorological sensors operational online, and reporting data?                         | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the shields for the temperature and RH sensors clean?  | <input checked="" type="checkbox"/> |     |
| 4 | Are the aspirated motors working?  | <input checked="" type="checkbox"/> | N/A |
| 5 | Is the solar radiation sensor's lens clean and free of scratches?                                  | <input checked="" type="checkbox"/> | N/A |
| 6 | Is the surface wetness sensor grid clean and undamaged?  | <input checked="" type="checkbox"/> | N/A |
| 7 | Are the sensor signal and power cables intact, in good condition, and well maintained?             | <input checked="" type="checkbox"/> |     |
| 8 | Are the sensor signal and power cable connections protected from the elements and well maintained? | <input checked="" type="checkbox"/> |     |

Parameter	Manufacturer	Model	S/N	Client ID
Temperature	RM Young	41342	13994	06389

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S5-rev001

Site ID  Technician  Site Visit Date

**Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E**

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

**Pollutant analyzers and deposition equipment operations and maintenance**

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.  1/4 teflon by 12 meters
- 4 Describe dry dep sample tube.  3/8 teflon by 12 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)  At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?  Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	A	none	03536
Ozone	ThermoElectron Inc	49i A1NAA	1105347321	000743
Filter pack flow pump	Thomas	107CA110	028871488	01458
Zero air pump	Werther International	C 70/4	000836208	06923

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S6-rev001

Site ID  Technician  Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
  - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
  - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry?  Met sensors only
  - 4 Are the signal connections protected from the weather and well maintained?
  - 5 Are the signal leads connected to the correct DAS channel?
  - 6 Are the DAS, sensor translators, and shelter properly grounded?
  - 7 Does the instrument shelter have a stable power source?
  - 8 Is the instrument shelter temperature controlled?
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

<b>Stable</b>	<b>Grounded</b>
<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D630	unknown	000430
DAS	Campbell	CR3000	2122	000343
Modem	Raven	H4222-C	0808311148	06471
UPS	APC	RS900	unknown	06797

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The met tower has been removed and the 10 meter temperature sensor is mounted in a naturally aspirated shield on the sample tower.



# Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

**Documentation**

**Does the site have the required instrument and equipment manuals?**

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

**Does the site have the required and most recent QC documents and report forms?**

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	June 2007	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Nov 2009	<input checked="" type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?  Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S8-rev001

Site ID

Technician

Site Visit Date

**Site operation procedures**

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

**Are regular operational QA/QC checks performed on meteorological instruments?**

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

**Are regular operational QA/QC checks performed on the ozone analyzer?**

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Monthly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?  Unknown
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?  SSRF, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S9-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

## *Site Inventory by Site Visit*

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>WST109-Eric Hebert-10/22/2012</i>						
1	10/22/2012	Computer	Dell	000291	D520	unknown
2	10/22/2012	DAS	Campbell	000427	CR3000	2526
3	10/22/2012	Elevation	Elevation	None	1	None
4	10/22/2012	Filter pack flow pump	Thomas	00476	107CA18	000025705
5	10/22/2012	Flow Rate	Apex	000466	AXMC105LPMDPCV	43970
6	10/22/2012	Infrastructure	Infrastructure	none	none	none
7	10/22/2012	Met tower	Universal Tower	03532	unknown	none
8	10/22/2012	Modem	Raven	06598	V4221-V	0844349943
9	10/22/2012	Ozone	ThermoElectron Inc	000695	49i A1NAA	1030244801
10	10/22/2012	Ozone Standard	ThermoElectron Inc	000371	49i A3NAA	0726124692
11	10/22/2012	Sample Tower	Aluma Tower	03531	A	none
12	10/22/2012	Shelter Temperature	Campbell	none	107-L	none
13	10/22/2012	Shield (10 meter)	RM Young	00947	Aspirated 43408	none
14	10/22/2012	Siting Criteria	Siting Criteria	None	1	None
15	10/22/2012	Temperature	RM Young	02192	41342	148
16	10/22/2012	Zero air pump	Werther International	06934	P 70/4	000821881

# DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2526	WST109	Eric Hebert	10/22/2012	DAS	Primary

Das Date:	<input type="text" value="10/22/2012"/>	Audit Date:	<input type="text" value="10/22/2012"/>
Das Time:	<input type="text" value="10:08:01"/>	Audit Time:	<input type="text" value="10:08:00"/>
Das Day:	<input type="text" value="296"/>	Audit Day:	<input type="text" value="296"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0002"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0002"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="4000392"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01321"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/9/2012"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.1000	0.1000	V	V	0.0000
7	0.3000	0.3000	0.3000	V	V	0.0000
7	0.5000	0.5001	0.5000	V	V	-0.0001
7	0.7000	0.7001	0.7000	V	V	-0.0001
7	0.9000	0.9001	0.9000	V	V	-0.0001
7	1.0000	1.0002	1.0000	V	V	-0.0002

# Flow Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
Apex	43970		WST109	Eric Hebert	10/22/2012	Flow Rate	000466

<b>Mfg</b>	BIOS	<b>Parameter</b>	Flow Rate
<b>Serial Number</b>	122974	<b>Tfer Desc.</b>	BIOS 220-H
<b>Tfer ID</b>	01416		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	2/6/2012	<b>CorrCoff</b>	1.00000

<b>DAS 1:</b>	<b>DAS 2:</b>	<b>Cal Factor Zero</b>	-0.01
<b>A Avg % Diff:</b>	<b>A Max % Di</b>	<b>Cal Factor Full Scale</b>	0.98
0.82%	0.89%	<b>Rotometer Reading:</b>	1.55

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	0.01	0.009	-0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.022	0.01	l/m	l/m	
primary	test pt 1	0.000	1.512	1.53	1.521	1.50	l/m	l/m	-0.79%
primary	test pt 2	0.000	1.512	1.53	1.521	1.50	l/m	l/m	-0.77%
primary	test pt 3	0.000	1.514	1.53	1.521	1.50	l/m	l/m	-0.89%

<b>Sensor Component</b>	Leak Test	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Filter Azimuth	<b>Condition</b>	180 deg	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Depth	<b>Condition</b>	-1.0 cm	<b>Status</b>	Fail
<b>Sensor Component</b>	Filter Position	<b>Condition</b>	Poor	<b>Status</b>	Fail
<b>Sensor Component</b>	Moisture Present	<b>Condition</b>	No moisture present	<b>Status</b>	pass
<b>Sensor Component</b>	Rotometer Condition	<b>Condition</b>	Clean and dry	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>	See comments	<b>Status</b>	pass
<b>Sensor Component</b>	Tubing Condition	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Distance	<b>Condition</b>	5.0 cm	<b>Status</b>	pass

# Ozone Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
ThermoElectron Inc	1030244801		WST109	Eric Hebert	10/22/2012	Ozone	000695

<b>Slope:</b>	0.99876	<b>Slope:</b>	0.00000
<b>Intercept</b>	0.16956	<b>Intercept</b>	0.00000
<b>CorrCoff</b>	1.00000	<b>CorrCoff</b>	0.00000

<b>DAS 1:</b>	<b>DAS 2:</b>		
<b>A Avg % Diff:</b>	<b>A Max % Di</b>	<b>A Avg %Dif</b>	<b>A Max % Di</b>
0.2%	0.5%		

<b>Mfg</b>	ThermoElectron Inc	<b>Parameter</b>	ozone
<b>Serial Number</b>	517112175	<b>Tfer Desc.</b>	Ozone primary stan
<b>Tfer ID</b>	01111		
<b>Slope</b>	1.00987	<b>Intercept</b>	0.07483
<b>Cert Date</b>	3/23/2012	<b>CorrCoff</b>	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.18	0.10	0.30	ppb	
primary	2	24.51	24.19	24.30	ppb	0.45%
primary	3	66.93	66.20	66.34	ppb	0.21%
primary	4	87.89	86.95	86.90	ppb	-0.06%
primary	5	120.58	119.32	119.40	ppb	0.07%

<b>Sensor Component</b>	Cell B Noise	<b>Condition</b>	0.9 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Tmp.	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Fullscale Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Inlet Filter Condition	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Line Loss	<b>Condition</b>	Not tested	<b>Status</b>	pass
<b>Sensor Component</b>	Offset	<b>Condition</b>	-0.20	<b>Status</b>	pass
<b>Sensor Component</b>	Span	<b>Condition</b>	1.030	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Freq.	<b>Condition</b>	102.5 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Sample Train	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Pressure	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Flow	<b>Condition</b>	0.70 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Tmp.	<b>Condition</b>	31.8 C	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Pressure	<b>Condition</b>	707 mmHg	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Noise	<b>Condition</b>	1.1 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Freq.	<b>Condition</b>	98.0 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Flow	<b>Condition</b>	0.71 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Battery Backup	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Zero Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass

# Temperature Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
RM Young	148		WST109	Eric Hebert	10/22/2012	Temperature	02192

<b>DAS 1:</b>		<b>DAS 2:</b>	
<b>Abs Avg Err</b>	<b>Abs Max Er</b>	<b>Abs Avg Err</b>	<b>Abs Max Er</b>

<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01D102193	<b>Tfer Desc.</b>	RTD translator
<b>Tfer ID</b>	01231		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01H0060	<b>Tfer Desc.</b>	RTD probe
<b>Tfer ID</b>	01230		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000

0.10	0.21		
------	------	--	--

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	0.09	0.11	0.000	-0.1	C	-0.21
primary	Temp Mid Range	25.57	25.55	0.000	25.6	C	0.06
primary	Temp High Range	48.36	48.31	0.000	48.4	C	0.04

<b>Sensor Component</b>	Shield	<b>Condition</b>	Moderately clean	<b>Status</b>	pass
<b>Sensor Component</b>	Blower Status Switch	<b>Condition</b>	Functioning	<b>Status</b>	pass
<b>Sensor Component</b>	Blower	<b>Condition</b>	Functioning	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass



## Infrastructure Data For

Site ID  Technician  Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2149-16)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Poor"/>	Status	<input type="text" value="Fail"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

# Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	WST109	Eric Hebert	10/22/2012	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.67	0.76		

<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Shelter Temperatur
<b>Serial Number</b>	01D102193	<b>Tfer Desc.</b>	RTD translator
<b>Tfer ID</b>	01231		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Shelter Temperatur
<b>Serial Number</b>	01H0060	<b>Tfer Desc.</b>	RTD probe
<b>Tfer ID</b>	01230		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	21.91	21.90	0.000	21.3	C	-0.58
primary	Temp Mid Range	22.06	22.05	0.000	21.4	C	-0.68
primary	Temp Mid Range	20.14	20.13	0.000	20.9	C	0.76

# Site Visit Comments

<b>Parameter</b>	<b>Site</b>	<b>Technician</b>	<b>S.V. Date</b>	<b>Component</b>	<b>Mfg</b>	<b>Serial No.</b>	<b>Hazard</b>	<b>Problem</b>
------------------	-------------	-------------------	------------------	------------------	------------	-------------------	---------------	----------------

Flow Rate	WST109	Eric Hebert	10/22/2012	Filter Position	Apex	3248	<input type="checkbox"/>	<input checked="" type="checkbox"/>
-----------	--------	-------------	------------	-----------------	------	------	--------------------------	-------------------------------------

The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.

# Field Systems Comments

**1 Parameter:** DasComments

The sample tower is kinked at the hinge point and is in poor condition. One leg of the met tower is split. Both of these conditions were reported following the two previous site audit visits.

**2 Parameter:** SiteOpsProcedures

The state of NH DES performs monthly multi-point audits of the ozone analyzer. Ozone sample train leak checks are being conducted every two weeks.

**3 Parameter:** SitingCriteriaCom

The site is in a small clearing surrounded by mountain forest. There is a small parking lot used by forest service employees located 50 meters from the site.

**4 Parameter:** SiteOKNotes

State of NH Department of Environmental Services contact is Tom Fazzina (603) 271-0911 and tfazzina@DES.state.NH.US

**5 Parameter:** ShelterCleanNotes

The shelter floor and roof have been repaired. Hand rails have been installed on platform.

**6 Parameter:** MetSensorComme

10-meter temperature is being operated and maintained on the meteorological tower.

# Field Systems Data Form

F-02058-1500-S1-rev001

Site ID  Technician  Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Woodstock"/>
Operating Group	<input type="text" value="IES/USFS"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="33-009-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text" value="43.9446"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text" value="-71.7008"/>
Land Use	<input type="text" value="woodland - mixed"/>	QAPP Elevation Meters	<input type="text" value="258"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text" value="15.9"/>
Conforms to MLM	<input type="text" value="No"/>	QAPP Declination Date	<input type="text" value="12/28/2004"/>
Site Telephone	<input type="text" value="(603) 726-4935"/>	Audit Latitude	<input type="text" value="43.944519"/>
Site Address 1	<input type="text" value="234 Mirror Lake Road"/>	Audit Longitude	<input type="text" value="-71.700787"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="255"/>
County	<input type="text" value="Grafton"/>	Audit Declination	<input type="text" value="-15.3"/>
City, State	<input type="text" value="Campton, NH"/>		
Zip Code	<input type="text" value="03223"/>	<b>Present</b>	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="Inspected March 2012"/>
Primary Operator	<input type="text" value="Brenda Minicucci"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text" value="(603) 726-4204"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text" value="bminicucci70703@roadrunner.com"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text" value="Don Buso"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text" value="(603) 7264-204"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text" value="dbuso@worldpath.net"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/> Model <input type="text" value="8810 (s/n 2149-16)"/> Shelter Size <input type="text" value="640 cuft"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter floor and roof have been repaired. Hand rails have been installed on platform."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text" value="State of NH Department of Environmental Services contact is Tom Fazzina (603) 271-0911 and tfazzina@DES.state.NH.US"/>		
Driving Directions	<input type="text" value="From I-93 take exit 30 and go south on route 3 for approximately 2 miles. Turn right on Mirror Lake road and continue to the end of the road. The site is through the gate on the right."/>		

# Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	50 m	<input type="checkbox"/>
Tree line	50 m	10 - 30 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

**Siting Criteria Comment**

The site is in a small clearing surrounded by mountain forest. There is a small parking lot used by forest service employees located 50 meters from the site.

# Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- |    |  |                                     |     |
|----|--|-------------------------------------|-----|
| 1  | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?  | <input checked="" type="checkbox"/> | N/A |
| 2  | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)     | <input checked="" type="checkbox"/> | N/A |
| 3  | Are the tower and sensors plumb?   | <input checked="" type="checkbox"/> | N/A |
| 4  | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?  | <input checked="" type="checkbox"/> |     |
| 5  | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> |     |
| 6  | Is the solar radiation sensor plumb?   | <input checked="" type="checkbox"/> | N/A |
| 7  | Is it sited to avoid shading, or any artificial or reflected light?  | <input checked="" type="checkbox"/> | N/A |
| 8  | Is the rain gauge plumb?   | <input checked="" type="checkbox"/> | N/A |
| 9  | Is it sited to avoid sheltering effects from buildings, trees, towers, etc?  | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north?  | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees?   | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

10-meter temperature is being operated and maintained on the meteorological tower.

# Field Systems Data Form

F-02058-1500-S4-rev001

Site ID  Technician  Site Visit Date

- 1 Do all the meteorological sensors appear to be intact, in good condition, and well maintained?
- 2 Are all the meteorological sensors operational online, and reporting data?
- 3 Are the shields for the temperature and RH sensors clean?
- 4 Are the aspirated motors working?
- 5 Is the solar radiation sensor's lens clean and free of scratches?
- 6 Is the surface wetness sensor grid clean and undamaged?
- 7 Are the sensor signal and power cables intact, in good condition, and well maintained?
- 8 Are the sensor signal and power cable connections protected from the elements and well maintained?

Parameter	Manufacturer	Model	S/N	Client ID
Temperature	RM Young	41342	148	02192
Shield (10 meter)	RM Young	Aspirated 43408	none	00947
Met tower	Universal Tower	unknown	none	03532

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:



# Field Systems Data Form

F-02058-1500-S5-rev001

Site ID

Technician

Site Visit Date

**Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E**

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

**Pollutant analyzers and deposition equipment operations and maintenance**

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.  1/4 teflon by 15 meters
- 4 Describe dry dep sample tube.  3/8 teflon by 15 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)  At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?  Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	A	none	03531
Ozone	ThermoElectron Inc	49i A1NAA	1030244801	000695
Zero air pump	Werther International	P 70/4	000821881	06934
Filter pack flow pump	Thomas	107CA18	000025705	00476

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S6-rev001

Site ID  Technician  Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
  - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
  - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry?  Met sensors only
  - 4 Are the signal connections protected from the weather and well maintained?
  - 5 Are the signal leads connected to the correct DAS channel?
  - 6 Are the DAS, sensor translators, and shelter properly grounded?
  - 7 Does the instrument shelter have a stable power source?
  - 8 Is the instrument shelter temperature controlled?
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

Stable	Grounded
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000291
DAS	Campbell	CR3000	2526	000427
Modem	Raven	V4221-V	0844349943	06598

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The sample tower is kinked at the hinge point and is in poor condition. One leg of the met tower is split. Both of these conditions were reported following the two previous site audit visits.

# Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Nov 2009	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	July 1990	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Preventive maintenance schedul	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?  Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S8-rev001

Site ID

Technician

Site Visit Date

**Site operation procedures**

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?  The site operator was trained by the previous operator, who was trained by the previous operator
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

**Are regular operational QA/QC checks performed on meteorological instruments?**

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

**Are regular operational QA/QC checks performed on the ozone analyzer?**

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?  Unknown
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?  SSRF, logbook, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The state of NH DES performs monthly multi-point audits of the ozone analyzer. Ozone sample train leak checks are being conducted every two weeks.

# Field Systems Data Form

F-02058-1500-S9-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

- |   |  |                                     |                          |
|---|--|-------------------------------------|--------------------------|
| 1 | Is the filter pack being changed every Tuesday as scheduled?                         | <input checked="" type="checkbox"/> | Filter changed morinings |
| 2 | Are the Site Status Report Forms being completed and filed correctly?                | <input checked="" type="checkbox"/> |                          |
| 3 | Are data downloads and backups being performed as scheduled?                         | <input type="checkbox"/>            | No longer required       |
| 4 | Are general observations being made and recorded? How?                               | <input checked="" type="checkbox"/> | SSRF, logbook            |
| 5 | Are site supplies on-hand and replenished in a timely fashion?                       | <input checked="" type="checkbox"/> |                          |
| 6 | Are sample flow rates recorded? How?   | <input checked="" type="checkbox"/> | SSRF, logbook, call-in   |
| 7 | Are samples sent to the lab on a regular schedule in a timely fashion?               | <input checked="" type="checkbox"/> |                          |
| 8 | Are filters protected from contamination during handling and shipping? How?          | <input checked="" type="checkbox"/> | Clean gloves on and off  |
| 9 | Are the site conditions reported regularly to the field operations manager or staff? | <input checked="" type="checkbox"/> |                          |

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

## *Site Inventory by Site Visit*

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>ABT147-Eric Hebert-10/23/2012</i>						
1	10/23/2012	Computer	Dell	000321	D520	unknown
2	10/23/2012	DAS	Campbell	000413	CR3000	2519
3	10/23/2012	Elevation	Elevation	None	1	None
4	10/23/2012	Filter pack flow pump	Thomas	02974	107CAB18	0493002469
5	10/23/2012	Flow Rate	Apex	000467	AXMC105LPM DPCV	43973
6	10/23/2012	Infrastructure	Infrastructure	none	none	none
7	10/23/2012	Met tower	Universal Tower	06486	unknown	none
8	10/23/2012	Modem	Raven	06602	H4223-C	0844430633
9	10/23/2012	Ozone	ThermoElectron Inc	000733	49i A1NAA	1105347322
10	10/23/2012	Ozone Standard	ThermoElectron Inc	000220	49i A3NAA	0622717868
11	10/23/2012	Sample Tower	Aluma Tower	000017	B	AT-61152-A-H8-C
12	10/23/2012	Shelter Temperature	Campbell	none	107-L	none
13	10/23/2012	Shield (10 meter)	RM Young	02804	Aspirated 43408	none
14	10/23/2012	Siting Criteria	Siting Criteria	None	1	None
15	10/23/2012	Temperature	RM Young	06503	41342	14623
16	10/23/2012	UPS	APC	06795	RS900	unknown
17	10/23/2012	Zero air pump	Werther International	06930	P 70/4	000829168

# DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2519	ABT147	Eric Hebert	10/23/2012	DAS	Primary

Das Date:	<input type="text" value="10/23/2012"/>	Audit Date:	<input type="text" value="10/23/2012"/>
Das Time:	<input type="text" value="11:00:01"/>	Audit Time:	<input type="text" value="11:00:00"/>
Das Day:	<input type="text" value="297"/>	Audit Day:	<input type="text" value="297"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0002"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0002"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="4000392"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01321"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/9/2012"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.1000	0.1000	V	V	0.0000
7	0.3000	0.3000	0.2999	V	V	-0.0001
7	0.5000	0.5000	0.4999	V	V	-0.0001
7	0.7000	0.7000	0.6999	V	V	-0.0001
7	0.9000	0.9000	0.8999	V	V	-0.0001
7	1.0000	1.0001	0.9999	V	V	-0.0002

# Flow Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
Apex	43973	ABT147	Eric Hebert	10/23/2012	Flow Rate	000467

<b>Mfg</b>	BIOS	<b>Parameter</b>	Flow Rate
<b>Serial Number</b>	122974	<b>Tfer Desc.</b>	BIOS 220-H
<b>Tfer ID</b>	01416		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	2/6/2012	<b>CorrCoff</b>	1.00000

<b>DAS 1:</b>	<b>DAS 2:</b>
<b>A Avg % Diff:</b>	<b>A Max % Di</b>
0.19%	0.39%

<b>Cal Factor Zero</b>	-0.01
<b>Cal Factor Full Scale</b>	0.99
<b>Rotometer Reading:</b>	1.55

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	-0.01	0.002	-0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.02	0.020	0.01	l/m	l/m	
primary	test pt 1	0.000	1.498	1.51	1.506	1.50	l/m	l/m	0.13%
primary	test pt 2	0.000	1.499	1.51	1.506	1.50	l/m	l/m	0.06%
primary	test pt 3	0.000	1.506	1.51	1.506	1.50	l/m	l/m	-0.39%

<b>Sensor Component</b>	Leak Test	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Filter Azimuth	<b>Condition</b>	240 deg	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Depth	<b>Condition</b>	0.0 cm	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Position	<b>Condition</b>	Fair	<b>Status</b>	pass
<b>Sensor Component</b>	Moisture Present	<b>Condition</b>	See comments	<b>Status</b>	pass
<b>Sensor Component</b>	Rotometer Condition	<b>Condition</b>	Clean and dry	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>	See comments	<b>Status</b>	pass
<b>Sensor Component</b>	Tubing Condition	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Distance	<b>Condition</b>	5.0 cm	<b>Status</b>	pass



# Ozone Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
ThermoElectron Inc	1105347322		ABT147	Eric Hebert	10/23/2012	Ozone	000733

<b>Slope:</b>	0.96006	<b>Slope:</b>	0.00000
<b>Intercept</b>	0.29628	<b>Intercept</b>	0.00000
<b>CorrCoff</b>	0.99995	<b>CorrCoff</b>	0.00000

<b>DAS 1:</b>	<b>DAS 2:</b>
<b>A Avg % Diff:</b>	<b>A Avg %Dif</b>
<b>A Max % Di</b>	<b>A Max % Di</b>
3.2%	4.2%

<b>Mfg</b>	ThermoElectron Inc	<b>Parameter</b>	ozone
<b>Serial Number</b>	517112175	<b>Tfer Desc.</b>	Ozone primary stan
<b>Tfer ID</b>	01111		
<b>Slope</b>	1.00987	<b>Intercept</b>	0.07483
<b>Cert Date</b>	3/23/2012	<b>CorrCoff</b>	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.38	0.30	0.14	ppb	
primary	2	33.17	32.77	32.03	ppb	-2.26%
primary	3	64.07	63.36	61.51	ppb	-2.92%
primary	4	83.43	82.54	79.80	ppb	-3.32%
primary	5	116.71	115.49	110.70	ppb	-4.15%

<b>Sensor Component</b>	Cell B Noise	<b>Condition</b>	0.8 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Tmp.	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Fullscale Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Inlet Filter Condition	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Line Loss	<b>Condition</b>	Not tested	<b>Status</b>	pass
<b>Sensor Component</b>	Offset	<b>Condition</b>	-0.20	<b>Status</b>	pass
<b>Sensor Component</b>	Span	<b>Condition</b>	1.028	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Freq.	<b>Condition</b>	93.0 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Sample Train	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Pressure	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Flow	<b>Condition</b>	0.71 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Tmp.	<b>Condition</b>	31.8 C	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Pressure	<b>Condition</b>	722 mmHg	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Noise	<b>Condition</b>	0.9 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Freq.	<b>Condition</b>	87.1 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Flow	<b>Condition</b>	0.73 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Battery Backup	<b>Condition</b>	Not functioning	<b>Status</b>	Fail
<b>Sensor Component</b>	Zero Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass

# Temperature Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
RM Young	14623		ABT147	Eric Hebert	10/23/2012	Temperature	06503

<b>DAS 1:</b>		<b>DAS 2:</b>	
<b>Abs Avg Err</b>	<b>Abs Max Er</b>	<b>Abs Avg Err</b>	<b>Abs Max Er</b>

<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01D102193	<b>Tfer Desc.</b>	RTD translator
<b>Tfer ID</b>	01231		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01H0060	<b>Tfer Desc.</b>	RTD probe
<b>Tfer ID</b>	01230		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000

0.09	0.14		
------	------	--	--

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	0.19	0.21	0.000	0.1	C	-0.14
primary	Temp Mid Range	25.31	25.29	0.000	25.3	C	-0.04
primary	Temp High Range	46.80	46.75	0.000	46.8	C	0.08

<b>Sensor Component</b>	Shield	<b>Condition</b>	Moderately clean	<b>Status</b>	pass
<b>Sensor Component</b>	Blower Status Switch	<b>Condition</b>	Functioning	<b>Status</b>	pass
<b>Sensor Component</b>	Blower	<b>Condition</b>	Functioning	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass

## Infrastructure Data For

Site ID  Technician  Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2149-9)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

# Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	ABT147	Eric Hebert	10/23/2012	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
1.23	3.40		

<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Shelter Temperatur
<b>Serial Number</b>	01D102193	<b>Tfer Desc.</b>	RTD translator
<b>Tfer ID</b>	01231		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Shelter Temperatur
<b>Serial Number</b>	01H0060	<b>Tfer Desc.</b>	RTD probe
<b>Tfer ID</b>	01230		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	20.22	20.21	0.000	23.6	C	3.4
primary	Temp Mid Range	19.71	19.70	0.000	19.9	C	0.16
primary	Temp Mid Range	19.28	19.27	0.000	19.4	C	0.14

# Site Visit Comments

<b>Parameter</b>	<b>Site</b>	<b>Technician</b>	<b>S.V. Date</b>	<b>Component</b>	<b>Mfg</b>	<b>Serial No.</b>	<b>Hazard</b>	<b>Problem</b>
Flow Rate	ABT147	Eric Hebert	10/23/2012	Moisture Present	Apex	3224	<input type="checkbox"/>	<input type="checkbox"/>
The filter sample tubing has drops of moisture in low sections outside the shelter.								

# Field Systems Comments

**1 Parameter:** SiteOpsProcComm

During the filter change-out it was observed that the filter flow pump was operating when the tower was lowered. This was discussed with the operator and the proper procedure was described by the auditor. The site operator indicated that she had been instructed by AMEC personnel to leave the filter installed and operate the flow pump while the tower was down.

**2 Parameter:** DasComments

The sample tower is no longer grounded. The lower section of the met tower has been replaced.

**3 Parameter:** SitingCriteriaCom

Manure is routinely spread on the hay fields surrounding the site.

**4 Parameter:** ShelterCleanNotes

The shelter is clean and well organized.

**5 Parameter:** MetSensorComme

10-meter temperature is operated and maintained on the meteorological tower.

# Field Systems Data Form

F-02058-1500-S1-rev001

Site ID  Technician  Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Hampton"/>
Operating Group	<input type="text" value="private"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="09-015-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text" value="41.8402"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text" value="-72.0111"/>
Land Use	<input type="text" value="agriculture, woodland - mixed"/>	QAPP Elevation Meters	<input type="text" value="209"/>
Terrain	<input type="text" value="rolling"/>	QAPP Declination	<input type="text" value="14.8"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text" value="2/22/2006"/>
Site Telephone	<input type="text" value="(860) 974-2273"/>	Audit Latitude	<input type="text" value="41.84046"/>
Site Address 1	<input type="text" value="80 Ayers Road"/>	Audit Longitude	<input type="text" value="-72.010368"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="202"/>
County	<input type="text" value="Windham"/>	Audit Declination	<input type="text" value="-14.5"/>
City, State	<input type="text" value="Abington, CT"/>		
Zip Code	<input type="text" value="06230"/>	<b>Present</b>	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="Inspected Nov 1992"/>
Primary Operator	<input type="text" value="Pam Brundage"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text" value="(860) 377-7159"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text" value="pambrundage@charter.net"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text" value="Andrea Cunningham"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text" value="(860) 974-0262"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text" value="abingtonandi@hotmail.com"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>

Shelter Working Room  Make  Model  Shelter Size

Shelter Clean  Notes

Site OK  Notes

**Driving Directions**

# Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text" value="10 m"/>	<input type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment



# Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- |    |  |                                     |     |
|----|--|-------------------------------------|-----|
| 1  | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?  | <input checked="" type="checkbox"/> | N/A |
| 2  | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)     | <input checked="" type="checkbox"/> | N/A |
| 3  | Are the tower and sensors plumb?   | <input checked="" type="checkbox"/> | N/A |
| 4  | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?  | <input checked="" type="checkbox"/> |     |
| 5  | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> |     |
| 6  | Is the solar radiation sensor plumb?   | <input checked="" type="checkbox"/> | N/A |
| 7  | Is it sited to avoid shading, or any artificial or reflected light?  | <input checked="" type="checkbox"/> | N/A |
| 8  | Is the rain gauge plumb?   | <input checked="" type="checkbox"/> | N/A |
| 9  | Is it sited to avoid sheltering effects from buildings, trees, towers, etc?  | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north?  | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees?   | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

10-meter temperature is operated and maintained on the meteorological tower.

# Field Systems Data Form

F-02058-1500-S4-rev001

Site ID  Technician  Site Visit Date

- |   |  |                                     |     |
|---|--|-------------------------------------|-----|
| 1 | Do all the meteorological sensors appear to be intact, in good condition, and well maintained?     | <input checked="" type="checkbox"/> | N/A |
| 2 | Are all the meteorological sensors operational online, and reporting data?                         | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the shields for the temperature and RH sensors clean?  | <input checked="" type="checkbox"/> |     |
| 4 | Are the aspirated motors working?  | <input checked="" type="checkbox"/> |     |
| 5 | Is the solar radiation sensor's lens clean and free of scratches?                                  | <input checked="" type="checkbox"/> | N/A |
| 6 | Is the surface wetness sensor grid clean and undamaged?  | <input checked="" type="checkbox"/> | N/A |
| 7 | Are the sensor signal and power cables intact, in good condition, and well maintained?             | <input checked="" type="checkbox"/> |     |
| 8 | Are the sensor signal and power cable connections protected from the elements and well maintained? | <input checked="" type="checkbox"/> |     |

Parameter	Manufacturer	Model	S/N	Client ID
Temperature	RM Young	41342	14623	06503
Shield (10 meter)	RM Young	Aspirated 43408	none	02804
Met tower	Universal Tower	unknown	none	06486

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S5-rev001

Site ID  Technician  Site Visit Date

**Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E**

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

**Pollutant analyzers and deposition equipment operations and maintenance**

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.  1/4 teflon by 15 meters
- 4 Describe dry dep sample tube.  3/8 teflon by 15 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)  At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?  Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	B	AT-61152-A-H8-C	000017
Ozone	ThermoElectron Inc	49i A1NAA	1105347322	000733
Filter pack flow pump	Thomas	107CAB18	0493002469	02974
Zero air pump	Werther International	P 70/4	000829168	06930

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S6-rev001

Site ID  Technician  Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
  - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
  - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry?
  - 4 Are the signal connections protected from the weather and well maintained?
  - 5 Are the signal leads connected to the correct DAS channel?
  - 6 Are the DAS, sensor translators, and shelter properly grounded?
  - 7 Does the instrument shelter have a stable power source?
  - 8 Is the instrument shelter temperature controlled?
- Stable**

**Grounded**
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000321
DAS	Campbell	CR3000	2519	000413
Modem	Raven	H4223-C	0844430633	06602
UPS	APC	RS900	unknown	06795

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The sample tower is no longer grounded. The lower section of the met tower has been replaced.

# Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

**Documentation**

**Does the site have the required instrument and equipment manuals?**

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

**Does the site have the required and most recent QC documents and report forms?**

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Nov 2009	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?  Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S8-rev001

Site ID

Technician

Site Visit Date

**Site operation procedures**

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

**Are regular operational QA/QC checks performed on meteorological instruments?**

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

**Are regular operational QA/QC checks performed on the ozone analyzer?**

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S9-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

During the filter change-out it was observed that the filter flow pump was operating when the tower was lowered. This was discussed with the operator and the proper procedure was described by the auditor. The site operator indicated that she had been instructed by AMEC personnel to leave the filter installed and operate the flow pump while the tower was down.

---

## *Site Inventory by Site Visit*

---

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

---

### *CAT175-Eric Hebert-10/24/2012*

1	10/24/2012	Computer	Dell	000275	D520	unknown
2	10/24/2012	DAS	Campbell	000412	CR3000	2532
3	10/24/2012	Elevation	Elevation	None	1	None
4	10/24/2012	Filter pack flow pump	Brailsford	none	TD-4X2N	none
5	10/24/2012	Flow Rate	Apex	000550	AXMC105LPM DPCV	50740
6	10/24/2012	Infrastructure	Infrastructure	none	none	none
7	10/24/2012	Met tower	Universal Tower	02742	unknown	none
8	10/24/2012	Modem	Raven	06481	H4222-C	0808311025
9	10/24/2012	Sample Tower	Aluma Tower	666359	B	none
10	10/24/2012	Shield (10 meter)	RM Young	none	41003	none
11	10/24/2012	Siting Criteria	Siting Criteria	None	1	None
12	10/24/2012	Temperature	RM Young	06409	41342VO	14042



# DAS Data Form

DAS Time Max Error:

<b>Mfg</b>	<b>Serial Number</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Use Desc.</b>
Campbell	2532	CAT175	Eric Hebert	10/24/2012	DAS	Primary

<b>Das Date:</b>	<input type="text" value="10/24/2012"/>	<b>Audit Date</b>	<input type="text" value="10/24/2012"/>
<b>Das Time:</b>	<input type="text" value="11:16:00"/>	<b>Audit Time</b>	<input type="text" value="11:16:02"/>
<b>Das Day:</b>	<input type="text" value="298"/>	<b>Audit Day</b>	<input type="text" value="298"/>

<b>Low Channel:</b>	<b>High Channel:</b>		
<b>Avg Diff:</b>	<b>Max Diff:</b>	<b>Avg Diff:</b>	<b>Max Diff:</b>
<input type="text" value="0.0001"/>	<input type="text" value="0.0002"/>	<input type="text" value="0.0001"/>	<input type="text" value="0.0002"/>

<b>Mfg</b>	<input type="text" value="Datel"/>	<b>Parameter</b>	<input type="text" value="DAS"/>
<b>Serial Number</b>	<input type="text" value="4000392"/>	<b>Tfer Desc.</b>	<input type="text" value="Source generator (D"/>
<b>Tfer ID</b>	<input type="text" value="01321"/>		
<b>Slope</b>	<input type="text" value="1.00000"/>	<b>Intercept</b>	<input type="text" value="0.00000"/>
<b>Cert Date</b>	<input type="text" value="2/13/2012"/>	<b>CorrCoff</b>	<input type="text" value="1.00000"/>
<b>Mfg</b>	<input type="text" value="Fluke"/>	<b>Parameter</b>	<input type="text" value="DAS"/>
<b>Serial Number</b>	<input type="text" value="86590148"/>	<b>Tfer Desc.</b>	<input type="text" value="DVM"/>
<b>Tfer ID</b>	<input type="text" value="01310"/>		
<b>Slope</b>	<input type="text" value="1.00000"/>	<b>Intercept</b>	<input type="text" value="0.00000"/>
<b>Cert Date</b>	<input type="text" value="2/9/2012"/>	<b>CorrCoff</b>	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
5	0.0000	0.0000	0.0000	V	V	0.0000
5	0.1000	0.1000	0.1000	V	V	0.0000
5	0.3000	0.3000	0.3001	V	V	0.0001
5	0.5000	0.5001	0.5001	V	V	0.0000
5	0.7000	0.7001	0.7002	V	V	0.0001
5	0.9000	0.9002	0.9002	V	V	0.0000
5	1.0000	1.0002	1.0000	V	V	-0.0002

# Flow Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
Apex	50740		CAT175	Eric Hebert	10/24/2012	Flow Rate	000550

<b>Mfg</b>	BIOS	<b>Parameter</b>	Flow Rate
<b>Serial Number</b>	122974	<b>Tfer Desc.</b>	BIOS 220-H
<b>Tfer ID</b>	01416		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	2/6/2012	<b>CorrCoff</b>	1.00000

<b>DAS 1:</b>	<b>DAS 2:</b>	<b>Cal Factor Zero</b>	0
<b>A Avg % Diff:</b>	<b>A Max % Di</b>	<b>Cal Factor Full Scale</b>	0
2.63%	2.70%	<b>Rotometer Reading:</b>	1.45

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	0.10	0.000	0.03	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.000	0.03	l/m	l/m	
primary	test pt 1	0.000	1.461	1.50	0.000	1.50	l/m	l/m	2.70%
primary	test pt 2	0.000	1.462	1.50	0.000	1.50	l/m	l/m	2.57%
primary	test pt 3	0.000	1.462	1.50	0.000	1.50	l/m	l/m	2.61%

<b>Sensor Component</b>	Leak Test	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Filter Azimuth	<b>Condition</b>	180 deg	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Depth	<b>Condition</b>	-1.0 cm	<b>Status</b>	Fail
<b>Sensor Component</b>	Filter Position	<b>Condition</b>	Poor	<b>Status</b>	Fail
<b>Sensor Component</b>	Moisture Present	<b>Condition</b>	No moisture present	<b>Status</b>	pass
<b>Sensor Component</b>	Rotometer Condition	<b>Condition</b>	Clean and dry	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>	See comments	<b>Status</b>	pass
<b>Sensor Component</b>	Tubing Condition	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Distance	<b>Condition</b>	4.5 cm	<b>Status</b>	pass

# Temperature Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
RM Young	14042		CAT175	Eric Hebert	10/24/2012	Temperature	06409

<b>DAS 1:</b>	<b>DAS 2:</b>
<b>Abs Avg Err</b>	<b>Abs Max Er</b>
<b>Abs Avg Err</b>	<b>Abs Max Er</b>

<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01D102193	<b>Tfer Desc.</b>	RTD translator
<b>Tfer ID</b>	01231		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01H0060	<b>Tfer Desc.</b>	RTD probe
<b>Tfer ID</b>	01230		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000

0.16	0.27		
------	------	--	--

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	0.08	0.10	0.000	0.2	C	0.11
primary	Temp Mid Range	13.53	13.53	0.000	13.5	C	-0.08
primary	Temp Mid Range	23.92	23.90	0.000	23.6	C	-0.27
primary	Temp High Range	47.99	47.94	0.000	47.8	C	-0.16

<b>Sensor Component</b>	Shield	<b>Condition</b>	Moderately clean	<b>Status</b>	pass
<b>Sensor Component</b>	Blower Status Switch	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Blower	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass

## Infrastructure Data For

Site ID  Technician  Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 1977-1)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="Fail"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

# Site Visit Comments

<b>Parameter</b>	<b>Site</b>	<b>Technician</b>	<b>S.V. Date</b>	<b>Component</b>	<b>Mfg</b>	<b>Serial No.</b>	<b>Hazard</b>	<b>Problem</b>
------------------	-------------	-------------------	------------------	------------------	------------	-------------------	---------------	----------------

Flow Rate	CAT175	Eric Hebert	10/24/2012	Filter Position	Apex	3683	<input type="checkbox"/>	<input checked="" type="checkbox"/>
-----------	--------	-------------	------------	-----------------	------	------	--------------------------	-------------------------------------

The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.

# Field Systems Comments

1 **Parameter:** SiteOpsProcComm

The site operator was not available to meet with the auditor during the audit visit due to a personal family matter.

2 **Parameter:** DasComments

The shelter is not temperature controlled. The site is solar and DC battery powered.

3 **Parameter:** ShelterCleanNotes

The shelter and grounds are neat and clean. The shelter roof has been repaired.

4 **Parameter:** PollAnalyzerCom

Ozone monitoring is no longer being conducted at the site.

# Field Systems Data Form

F-02058-1500-S1-rev001

Site ID  Technician  Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Claryville"/>
Operating Group	<input type="text" value="private"/>	Map Scale	<input type="text"/>
AQS #	<input type="text"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text" value="41.9423"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text" value="-74.5519"/>
Land Use	<input type="text" value="woodland - mixed"/>	QAPP Elevation Meters	<input type="text" value="765"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text" value="13.5"/>
Conforms to MLM	<input type="text" value="No"/>	QAPP Declination Date	<input type="text" value="2/22/2006"/>
Site Telephone	<input type="text" value="(845) 798-0947"/>	Audit Latitude	<input type="text" value="41.942325"/>
Site Address 1	<input type="text" value="Wildcat Mt. Road"/>	Audit Longitude	<input type="text" value="-74.551999"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="754"/>
County	<input type="text" value="Ulster"/>	Audit Declination	<input type="text" value="-13.2"/>
City, State	<input type="text" value="Claryville, NY"/>		
Zip Code	<input type="text" value="12725"/>	<b>Present</b>	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Primary Operator	<input type="text" value="Mike Edwards"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text" value="(845) 701-1819"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text" value="medwards@usadatanet.net"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text" value="none"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/> Model <input type="text" value="8810 (s/n 1977-1)"/> Shelter Size <input type="text" value="640 cuft"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter and grounds are neat and clean. The shelter roof has been repaired."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

**Driving Directions** From Liberty, NY go west on route 52 toward Grahamsville. Just before reaching Grahamsville, turn left onto County Road 19 to Claryville. Stay on 19 through Claryville and turn left on Wildcat Mt Road immediately after crossing the bridge at the far end of town. Bear right and follow the semi-paved road for about 0.7 miles to the fork. Go right at the fork and turn left at the first house on the left. The site is about .75 miles up the dirt road behind the house.

# Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment



# Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- |    |  |                                     |     |
|----|--|-------------------------------------|-----|
| 1  | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?  | <input checked="" type="checkbox"/> | N/A |
| 2  | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)     | <input checked="" type="checkbox"/> | N/A |
| 3  | Are the tower and sensors plumb?   | <input checked="" type="checkbox"/> | N/A |
| 4  | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?  | <input checked="" type="checkbox"/> |     |
| 5  | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> |     |
| 6  | Is the solar radiation sensor plumb?   | <input checked="" type="checkbox"/> | N/A |
| 7  | Is it sited to avoid shading, or any artificial or reflected light?  | <input checked="" type="checkbox"/> | N/A |
| 8  | Is the rain gauge plumb?   | <input checked="" type="checkbox"/> | N/A |
| 9  | Is it sited to avoid sheltering effects from buildings, trees, towers, etc?  | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north?  | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees?   | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S4-rev001

Site ID  Technician  Site Visit Date

- 1 Do all the meteorological sensors appear to be intact, in good condition, and well maintained?  N/A
- 2 Are all the meteorological sensors operational online, and reporting data?  N/A
- 3 Are the shields for the temperature and RH sensors clean?
- 4 Are the aspirated motors working?  Natural aspiration
- 5 Is the solar radiation sensor's lens clean and free of scratches?  N/A
- 6 Is the surface wetness sensor grid clean and undamaged?  N/A
- 7 Are the sensor signal and power cables intact, in good condition, and well maintained?  N/A
- 8 Are the sensor signal and power cable connections protected from the elements and well maintained?  N/A

Parameter	Manufacturer	Model	S/N	Client ID
Temperature	RM Young	41342VO	14042	06409
Shield (10 meter)	RM Young	41003	none	none
Met tower	Universal Tower	unknown	none	02742

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S5-rev001

Site ID  Technician  Site Visit Date

**Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E**

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

**Pollutant analyzers and deposition equipment operations and maintenance**

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?  Ozone not measured
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube. N/A
- 4 Describe dry dep sample tube. 3/8 teflon by 18 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)  N/A
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?  N/A
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?  Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	B	none	666359
Filter pack flow pump	Brailsford	TD-4X2N	none	none

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Ozone monitoring is no longer being conducted at the site.

# Field Systems Data Form

F-02058-1500-S6-rev001

Site ID  Technician  Site Visit Date

**DAS, sensor translators, and peripheral equipment operations and maintenance**

- 1 Do the DAS instruments appear to be in good condition and well maintained?
  - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
  - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry?  Met sensors only
  - 4 Are the signal connections protected from the weather and well maintained?
  - 5 Are the signal leads connected to the correct DAS channel?
  - 6 Are the DAS, sensor translators, and shelter properly grounded?
  - 7 Does the instrument shelter have a stable power source?  Solar power
  - 8 Is the instrument shelter temperature controlled?  Shelter not temperature controlled
- 9 Is the met tower stable and grounded? 

Stable	Grounded
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
- 10 Is the sample tower stable and grounded? 

Stable	Grounded
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
- 11 Tower comments?

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000275
DAS	Campbell	CR3000	2532	000412
Modem	Raven	H4222-C	0808311025	06481

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The shelter is not temperature controlled. The site is solar and DC battery powered.

# Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Nov 2001	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	N/A	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?  N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S8-rev001

Site ID

Technician

Site Visit Date

**Site operation procedures**

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

**Are regular operational QA/QC checks performed on meteorological instruments?**

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

**Are regular operational QA/QC checks performed on the ozone analyzer?**

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S9-rev001

Site ID

Technician

Site Visit Date

**Site operation procedures**

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed afternoons
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, e-mail
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/> Not performed	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator was not available to meet with the auditor during the audit visit due to a personal family matter.

## *Site Inventory by Site Visit*

---

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

---

### *ARE128-Sandy Grenville-10/30/2012*

1	10/30/2012	Computer	Dell	000244	D520	67FNHB1
2	10/30/2012	DAS	Campbell	000400	CR3000	2524
3	10/30/2012	Elevation	Elevation	None	1	None
4	10/30/2012	Filter pack flow pump	Thomas	02661	107CA110	000012187C
5	10/30/2012	Flow Rate	Apex	000462	AXMC105LPMDPCV	42228
6	10/30/2012	Infrastructure	Infrastructure	none	none	none
7	10/30/2012	Met tower	Universal Tower	03505	unknown	none
8	10/30/2012	Modem	Raven	06591	V4221-V	0844349616
9	10/30/2012	Ozone	ThermoElectron Inc	000609	49i A1NAA	1009241782
10	10/30/2012	Ozone Standard	ThermoElectron Inc	000328	49i A3NAA	0622717850
11	10/30/2012	Sample Tower	Aluma Tower	666361	B	none
12	10/30/2012	Shelter Temperature	Campbell	none	107-L	none
13	10/30/2012	Shield (10 meter)	Climatronics	01167	100325	1272
14	10/30/2012	Siting Criteria	Siting Criteria	None	1	None
15	10/30/2012	Temperature	Climatronics	06678	100093	missing
16	10/30/2012	Zero air pump	Werther International	06866	PC70/4	000815262



# DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2524	ARE128	Sandy Grenville	10/30/2012	DAS	Primary

Das Date:	<input type="text" value="10/30/2012"/>	Audit Date:	<input type="text" value="10/30/2012"/>
Das Time:	<input type="text" value="15:38:04"/>	Audit Time:	<input type="text" value="15:38:00"/>
Das Day:	<input type="text" value="306"/>	Audit Day:	<input type="text" value="306"/>

Low Channel:	High Channel:		
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
<input type="text" value="0.0001"/>	<input type="text" value="0.0002"/>	<input type="text" value="0.0001"/>	<input type="text" value="0.0002"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="15510194"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01320"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/2/2010"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740135"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01311"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/9/2012"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	-0.0001	0.0000	V	V	0.0001
7	0.1000	0.0998	0.0999	V	V	0.0001
7	0.3000	0.2997	0.2997	V	V	0.0000
7	0.5000	0.4996	0.4996	V	V	0.0000
7	0.7000	0.6996	0.6994	V	V	-0.0002
7	0.9000	0.8996	0.8995	V	V	-0.0001
7	1.0000	0.9993	0.9991	V	V	-0.0002

# Flow Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
Apex	42228		ARE128	Sandy Grenville	10/30/2012	Flow Rate	000462

<b>Mfg</b>	BIOS	<b>Parameter</b>	Flow Rate
<b>Serial Number</b>	103471	<b>Tfer Desc.</b>	nexus
<b>Tfer ID</b>	01420		
<b>Mfg</b>	BIOS	<b>Parameter</b>	Flow Rate
<b>Serial Number</b>	103424	<b>Tfer Desc.</b>	BIOS cell
<b>Tfer ID</b>	01410		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	1/27/2012	<b>CorrCoff</b>	1.00000

<b>DAS 1:</b>	<b>DAS 2:</b>
<b>A Avg % Diff:</b>	<b>A Max % Di</b>
2.78%	3.29%
<b>A Avg %Dif</b>	<b>A Max % Di</b>

<b>Cal Factor Zero</b>	0.01
<b>Cal Factor Full Scale</b>	0.99
<b>Rotometer Reading:</b>	1

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	-0.03	0.035	0.04	l/m	l/m	
primary	leak check	0.000	0.000	-0.01	0.037	0.04	l/m	l/m	
primary	test pt 1	1.532	1.551	1.51	1.511	1.50	l/m	l/m	-3.29%
primary	test pt 2	1.531	1.549	1.51	1.513	1.50	l/m	l/m	-3.16%
primary	test pt 3	1.548	1.529	1.51	1.511	1.50	l/m	l/m	-1.90%

<b>Sensor Component</b>	Leak Test	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Filter Azimuth	<b>Condition</b>	280 deg	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Depth	<b>Condition</b>	3.0 cm	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Position	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Moisture Present	<b>Condition</b>	Moisture present	<b>Status</b>	pass
<b>Sensor Component</b>	Rotometer Condition	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>	See comments	<b>Status</b>	pass
<b>Sensor Component</b>	Tubing Condition	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Distance	<b>Condition</b>	5.0 cm	<b>Status</b>	pass

# Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241782		ARE128	Sandy Grenville	10/30/2012	Ozone	000609

<b>Slope:</b>	0.99968	<b>Slope:</b>	0.00000
<b>Intercept</b>	0.06764	<b>Intercept</b>	0.00000
<b>CorrCoff</b>	0.99993	<b>CorrCoff</b>	0.00000

<b>DAS 1:</b>	<b>DAS 2:</b>
<b>A Avg % Diff:</b>	<b>A Avg % Dif</b>
<b>A Max % Di</b>	<b>A Max % Di</b>
0.8%	1.9%

<b>Mfg</b>	ThermoElectron Inc	<b>Parameter</b>	ozone
<b>Serial Number</b>	49C-73104-373	<b>Tfer Desc.</b>	Ozone transfer
<b>Tfer ID</b>	01100		
<b>Slope</b>	1.01297	<b>Intercept</b>	0.09498
<b>Cert Date</b>	1/23/2012	<b>CorrCoff</b>	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.11	0.01	0.77	ppb	
primary	2	36.32	35.76	36.05	ppb	0.81%
primary	3	65.97	65.03	65.24	ppb	0.32%
primary	4	87.27	86.05	84.40	ppb	-1.92%
primary	5	213.43	210.60	211.20	ppb	0.28%

<b>Sensor Component</b>	Cell B Noise	<b>Condition</b>	0.8 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Tmp.	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Fullscale Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Inlet Filter Condition	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Line Loss	<b>Condition</b>	Not tested	<b>Status</b>	pass
<b>Sensor Component</b>	Offset	<b>Condition</b>	-0.30	<b>Status</b>	pass
<b>Sensor Component</b>	Span	<b>Condition</b>	1.004	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Freq.	<b>Condition</b>	92.5 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Sample Train	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Pressure	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Flow	<b>Condition</b>	0.72 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Tmp.	<b>Condition</b>	28.1 C	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Pressure	<b>Condition</b>	703 mmHg	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Noise	<b>Condition</b>	0.9 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Freq.	<b>Condition</b>	87.9 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Flow	<b>Condition</b>	0.70 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Battery Backup	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Zero Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass

# Temperature Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
Climatronics	missing		ARE128	Sandy Grenville	10/30/2012	Temperature	06678

<b>DAS 1:</b>		<b>DAS 2:</b>	
<b>Abs Avg Err</b>	<b>Abs Max Er</b>	<b>Abs Avg Err</b>	<b>Abs Max Er</b>

<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01D102193	<b>Tfer Desc.</b>	RTD translator
<b>Tfer ID</b>	01231		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01H0060	<b>Tfer Desc.</b>	RTD probe
<b>Tfer ID</b>	01230		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000

0.08	0.21		
------	------	--	--

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	0.05	0.07	0.000	0.0	C	-0.03
primary	Temp Mid Range	25.00	24.98	0.000	24.8	C	-0.21
primary	Temp High Range	45.35	45.30	0.000	45.3	C	0.01

<b>Sensor Component</b>	Shield	<b>Condition</b>	Moderately clean	<b>Status</b>	pass
<b>Sensor Component</b>	Blower Status Switch	<b>Condition</b>	Functioning	<b>Status</b>	pass
<b>Sensor Component</b>	Blower	<b>Condition</b>	Functioning	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass

## Infrastructure Data For

Site ID  Technician  Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2116-7)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>

# Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	ARE128	Sandy Grenville	10/30/2012	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
2.04	2.73		

<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Shelter Temperatur
<b>Serial Number</b>	01D102193	<b>Tfer Desc.</b>	RTD translator
<b>Tfer ID</b>	01231		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Shelter Temperatur
<b>Serial Number</b>	01H0060	<b>Tfer Desc.</b>	RTD probe
<b>Tfer ID</b>	01230		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	17.20	17.19	0.000	19.9	C	2.73
primary	Temp Mid Range	18.90	18.89	0.000	20.7	C	1.84
primary	Temp Mid Range	19.40	19.39	0.000	21.0	C	1.56

# Site Visit Comments

<b>Parameter</b>	<b>Site</b>	<b>Technician</b>	<b>S.V. Date</b>	<b>Component</b>	<b>Mfg</b>	<b>Serial No.</b>	<b>Hazard</b>	<b>Problem</b>
------------------	-------------	-------------------	------------------	------------------	------------	-------------------	---------------	----------------

Flow Rate	ARE128	Sandy Grenville	10/30/2012	System Memo	Apex	3308	<input type="checkbox"/>	<input type="checkbox"/>
-----------	--------	-----------------	------------	-------------	------	------	--------------------------	--------------------------

Additional details can be found in the hardcopy of the site audit report.

Flow Rate	ARE128	Sandy Grenville	10/30/2012	Moisture Present	Apex	3308	<input type="checkbox"/>	<input type="checkbox"/>
-----------	--------	-----------------	------------	------------------	------	------	--------------------------	--------------------------

There is moisture present in the dry deposition sample train inside the shelter.

# Field Systems Comments

**1 Parameter:** DasComments

The meteorological tower is grounded but the lightning rod has been removed. The sample tower is not grounded.

**2 Parameter:** SitingCriteriaCom

The site is located in an active orchard where spraying occurs. Fruit trees are rotated with corn and other crops.

**3 Parameter:** ShelterCleanNotes

The shelter is cluttered and disorganized.

**4 Parameter:** PollAnalyzerCom

Moisture was present in the moisture trap and tubing upon arrival for the audit one day after hurricane Sandy. The system was left open without the filter installed for one day and then the audit of the flow system was performed.

**5 Parameter:** MetOpMaintCom

The 10-meter temperature sensor is being operated and maintained on the meteorological tower.



# Field Systems Data Form

F-02058-1500-S1-rev001

Site ID  Technician  Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Arendtsville"/>
Operating Group	<input type="text" value="PSU/private"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="42-001-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, IMROVE"/>	QAPP Latitude	<input type="text" value="39.9231"/>
Deposition Measurement	<input type="text" value="dry, wet, Hg, PM"/>	QAPP Longitude	<input type="text" value="-77.3078"/>
Land Use	<input type="text" value="agriculture"/>	QAPP Elevation Meters	<input type="text" value="269"/>
Terrain	<input type="text" value="complex - rolling"/>	QAPP Declination	<input type="text" value="10.9"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text" value="2/22/2006"/>
Site Telephone	<input type="text" value="(717) 677-9866"/>	Audit Latitude	<input type="text" value="39.923241"/>
Site Address 1	<input type="text" value="PSU Fruit Research Orchard"/>	Audit Longitude	<input type="text" value="-77.307863"/>
Site Address 2	<input type="text" value="Winding Road"/>	Audit Elevation	<input type="text" value="266"/>
County	<input type="text" value="Adams"/>	Audit Declination	<input type="text" value="-11"/>
City, State	<input type="text" value="Arendtsville, PA"/>		
Zip Code	<input type="text" value="17307"/>	<b>Present</b>	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Primary Operator	<input type="text" value="Sharon Scamack"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text" value="(717) 677-6116"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text" value="sks8@psu.edu"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text" value="Kathy Wholaver"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text" value="(717) 677-6116"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810 (s/n 2116-7)"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input type="checkbox"/>	Notes <input type="text" value="The shelter is cluttered and disorganized."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

**Driving Directions** From Gettysburg take route 34 north to Biglerville. At the intersection of 34 and 234 turn left (west) to Arendtsville. Continue into the town of Arendtsville. At the stop sign next to the gas station, turn left and immediately turn right, onto Chambersburg Street. Continue approximately 0.4 miles and turn right onto Winding Road. There is a sign for Boyer Nursery & Orchard. The site will be visible at the top of the hill in the orchard on the right.

# Field Systems Data Form

F-02058-1500-S2-rev001

Site ID  Technician  Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	20 m	<input type="checkbox"/>
Limited agricultural operations	200 m	20 m	<input type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

The site is located in an active orchard where spraying occurs. Fruit trees are rotated with corn and other crops.

# Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- |    |  |                                     |     |
|----|--|-------------------------------------|-----|
| 1  | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?  | <input checked="" type="checkbox"/> | N/A |
| 2  | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)     | <input checked="" type="checkbox"/> | N/A |
| 3  | Are the tower and sensors plumb?   | <input checked="" type="checkbox"/> | N/A |
| 4  | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?  | <input checked="" type="checkbox"/> |     |
| 5  | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> |     |
| 6  | Is the solar radiation sensor plumb?   | <input checked="" type="checkbox"/> | N/A |
| 7  | Is it sited to avoid shading, or any artificial or reflected light?  | <input checked="" type="checkbox"/> | N/A |
| 8  | Is the rain gauge plumb?   | <input checked="" type="checkbox"/> | N/A |
| 9  | Is it sited to avoid sheltering effects from buildings, trees, towers, etc?  | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north?  | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees?   | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S4-rev001

Site ID  Technician  Site Visit Date

- |   |  |                                     |     |
|---|--|-------------------------------------|-----|
| 1 | Do all the meteorological sensors appear to be intact, in good condition, and well maintained?     | <input checked="" type="checkbox"/> | N/A |
| 2 | Are all the meteorological sensors operational online, and reporting data?                         | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the shields for the temperature and RH sensors clean?  | <input checked="" type="checkbox"/> |     |
| 4 | Are the aspirated motors working?  | <input checked="" type="checkbox"/> |     |
| 5 | Is the solar radiation sensor's lens clean and free of scratches?                                  | <input checked="" type="checkbox"/> | N/A |
| 6 | Is the surface wetness sensor grid clean and undamaged?  | <input checked="" type="checkbox"/> | N/A |
| 7 | Are the sensor signal and power cables intact, in good condition, and well maintained?             | <input checked="" type="checkbox"/> |     |
| 8 | Are the sensor signal and power cable connections protected from the elements and well maintained? | <input checked="" type="checkbox"/> |     |

Parameter	Manufacturer	Model	S/N	Client ID
Shield (10 meter)	Climatronics	100325	1272	01167
Temperature	Climatronics	100093	missing	06678
Met tower	Universal Tower	unknown	none	03505

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The 10-meter temperature sensor is being operated and maintained on the meteorological tower.

# Field Systems Data Form

F-02058-1500-S5-rev001

Site ID  Technician  Site Visit Date

**Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E**

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

**Pollutant analyzers and deposition equipment operations and maintenance**

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.  1/4 teflon by 12 meters
- 4 Describe dry dep sample tube.  3/8 teflon by 12 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)  At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?  Moisture present
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?  Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	B	none	666361
Ozone	ThermoElectron Inc	49i A1NAA	1009241782	000609
Filter pack flow pump	Thomas	107CA110	000012187C	02661
Zero air pump	Werther International	PC70/4	000815262	06866

**Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:**

Moisture was present in the moisture trap and tubing upon arrival for the audit one day after hurricane Sandy. The system was left open without the filter installed for one day and then the audit of the flow system was performed.

# Field Systems Data Form

F-02058-1500-S6-rev001

Site ID  Technician  Site Visit Date

**DAS, sensor translators, and peripheral equipment operations and maintenance**

- 1 Do the DAS instruments appear to be in good condition and well maintained?
- 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
- 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry?  Met sensors only
- 4 Are the signal connections protected from the weather and well maintained?
- 5 Are the signal leads connected to the correct DAS channel?
- 6 Are the DAS, sensor translators, and shelter properly grounded?
- 7 Does the instrument shelter have a stable power source?
- 8 Is the instrument shelter temperature controlled?

- 9 Is the met tower stable and grounded?
 

<b>Stable</b>	<b>Grounded</b>
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?
 

Met tower grounded but lightning rod removed, sample tower not grounded

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	67FNHB1	000244
DAS	Campbell	CR3000	2524	000400
Modem	Raven	V4221-V	0844349616	06591

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The meteorological tower is grounded but the lightning rod has been removed. The sample tower is not grounded.

# Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

**Documentation**

**Does the site have the required instrument and equipment manuals?**

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

**Does the site have the required and most recent QC documents and report forms?**

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text" value="No page numbers"/>	<input type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	<input type="text" value="Oct 2010"/>	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	<input type="text" value="Oct 2010"/>	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	<input type="text" value="Oct 2001"/>	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S8-rev001

Site ID  Technician  Site Visit Date

**Site operation procedures**

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

**Are regular operational QA/QC checks performed on meteorological instruments?**

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

**Are regular operational QA/QC checks performed on the ozone analyzer?**

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:



# Field Systems Data Form

F-02058-1500-S9-rev001

Site ID  Technician  Site Visit Date

**Site operation procedures**

- |   |  |                                     |                              |
|---|--|-------------------------------------|------------------------------|
| 1 | Is the filter pack being changed every Tuesday as scheduled?                         | <input checked="" type="checkbox"/> | Filter changed afternoons    |
| 2 | Are the Site Status Report Forms being completed and filed correctly?                | <input checked="" type="checkbox"/> |                              |
| 3 | Are data downloads and backups being performed as scheduled?                         | <input type="checkbox"/>            | No longer required           |
| 4 | Are general observations being made and recorded? How?                               | <input checked="" type="checkbox"/> | SSRF                         |
| 5 | Are site supplies on-hand and replenished in a timely fashion?                       | <input checked="" type="checkbox"/> |                              |
| 6 | Are sample flow rates recorded? How?   | <input checked="" type="checkbox"/> | SSRF, call-in                |
| 7 | Are samples sent to the lab on a regular schedule in a timely fashion?               | <input checked="" type="checkbox"/> |                              |
| 8 | Are filters protected from contamination during handling and shipping? How?          | <input type="checkbox"/>            | Gloves not consistently used |
| 9 | Are the site conditions reported regularly to the field operations manager or staff? | <input checked="" type="checkbox"/> |                              |

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

## *Site Inventory by Site Visit*

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>PSU106-Sandy Grenville-11/03/2012</i>						
1	11/3/2012	Computer	Dell	000268	D520	unknown
2	11/3/2012	DAS	Campbell	000407	CR3000	2512
3	11/3/2012	Elevation	Elevation	None	1	None
4	11/3/2012	Filter pack flow pump	Thomas	06023	107CAB18	060400022676
5	11/3/2012	Flow Rate	Apex	000560	AXMC105LPMDPCV	50732
6	11/3/2012	Infrastructure	Infrastructure	none	none	none
7	11/3/2012	Modem	Raven	06601	V4221-V	0844430833
8	11/3/2012	Ozone	ThermoElectron Inc	000684	49i A1NAA	1030244795
9	11/3/2012	Ozone Standard	ThermoElectron Inc	000684	49i A3NAA	1030244812
10	11/3/2012	Sample Tower	Aluma Tower	02747	A	none
11	11/3/2012	Shelter Temperature	Campbell	none	107-L	none
12	11/3/2012	Siting Criteria	Siting Criteria	None	1	None
13	11/3/2012	Temperature	RM Young	04316	41342VO	4013
14	11/3/2012	Zero air pump	Werther International	06914	C 70/4	000829156

# DAS Data Form

DAS Time Max Error:

<b>Mfg</b>	<b>Serial Number</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Use Desc.</b>
Campbell	2512	PSU106	Sandy Grenville	11/03/2012	DAS	Primary

<b>Das Date:</b>	<input type="text" value="11/3 /2012"/>	<b>Audit Date</b>	<input type="text" value="11/3 /2012"/>
<b>Das Time:</b>	<input type="text" value="11:50:01"/>	<b>Audit Time</b>	<input type="text" value="11:50:00"/>
<b>Das Day:</b>	<input type="text" value="308"/>	<b>Audit Day</b>	<input type="text" value="308"/>
<b>Low Channel:</b>		<b>High Channel:</b>	
<b>Avg Diff:</b>	<input type="text" value="0.0001"/>	<b>Max Diff:</b>	<input type="text" value="0.0002"/>
		<b>Avg Diff:</b>	<input type="text" value="0.0001"/>
		<b>Max Diff:</b>	<input type="text" value="0.0002"/>

<b>Mfg</b>	<input type="text" value="Datel"/>	<b>Parameter</b>	<input type="text" value="DAS"/>
<b>Serial Number</b>	<input type="text" value="15510194"/>	<b>Tfer Desc.</b>	<input type="text" value="Source generator (D"/>
<b>Tfer ID</b>	<input type="text" value="01320"/>		
<b>Slope</b>	<input type="text" value="1.00000"/>	<b>Intercept</b>	<input type="text" value="0.00000"/>
<b>Cert Date</b>	<input type="text" value="2/2/2010"/>	<b>CorrCoff</b>	<input type="text" value="1.00000"/>
<b>Mfg</b>	<input type="text" value="Fluke"/>	<b>Parameter</b>	<input type="text" value="DAS"/>
<b>Serial Number</b>	<input type="text" value="95740135"/>	<b>Tfer Desc.</b>	<input type="text" value="DVM"/>
<b>Tfer ID</b>	<input type="text" value="01311"/>		
<b>Slope</b>	<input type="text" value="1.00000"/>	<b>Intercept</b>	<input type="text" value="0.00000"/>
<b>Cert Date</b>	<input type="text" value="2/9/2012"/>	<b>CorrCoff</b>	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	-0.0001	0.0000	V	V	0.0001
7	0.1000	0.0998	0.1000	V	V	0.0002
7	0.3000	0.2997	0.2998	V	V	0.0001
7	0.5000	0.4996	0.4997	V	V	0.0001
7	0.7000	0.6996	0.6996	V	V	0.0000
7	0.9000	0.8995	0.8995	V	V	0.0000
7	1.0000	0.9994	0.9994	V	V	0.0000

# Flow Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
Apex	50732		PSU106	Sandy Grenville	11/03/2012	Flow Rate	000560

<b>Mfg</b>	BIOS	<b>Parameter</b>	Flow Rate
<b>Serial Number</b>	103471	<b>Tfer Desc.</b>	nexus
<b>Tfer ID</b>	01420		
<b>Mfg</b>	BIOS	<b>Parameter</b>	Flow Rate
<b>Serial Number</b>	103424	<b>Tfer Desc.</b>	BIOS cell
<b>Tfer ID</b>	01410		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	1/27/2012	<b>CorrCoff</b>	1.00000

<b>DAS 1:</b>	<b>DAS 2:</b>
<b>A Avg % Diff:</b>	<b>A Max % Di</b>
4.42%	4.55%

<b>Cal Factor Zero</b>	-0.01
<b>Cal Factor Full Scale</b>	0.97
<b>Rotometer Reading:</b>	1.5

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	0.00	0.004	0.00	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.039	0.03	l/m	l/m	
primary	test pt 1	1.527	1.561	1.53	1.526	1.49	l/m	l/m	-4.55%
primary	test pt 2	1.526	1.558	1.53	1.527	1.49	l/m	l/m	-4.36%
primary	test pt 3	1.524	1.558	1.53	1.526	1.49	l/m	l/m	-4.36%

<b>Sensor Component</b>	Leak Test	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Filter Azimuth	<b>Condition</b>	250 deg	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Depth	<b>Condition</b>	0.5 cm	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Position	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Moisture Present	<b>Condition</b>	No moisture present	<b>Status</b>	pass
<b>Sensor Component</b>	Rotometer Condition	<b>Condition</b>	Clean and dry	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Tubing Condition	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Distance	<b>Condition</b>	6.5 cm	<b>Status</b>	pass

# Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1030244795		PSU106	Sandy Grenville	11/03/2012	Ozone	000684

<b>Slope:</b>	0.99049	<b>Slope:</b>	0.00000
<b>Intercept</b>	0.66213	<b>Intercept</b>	0.00000
<b>CorrCoff</b>	0.99999	<b>CorrCoff</b>	0.00000

<b>DAS 1:</b>	<b>DAS 2:</b>
<b>A Avg % Diff:</b>	<b>A Avg % Dif</b>
<b>A Max % Di</b>	<b>A Max % Di</b>
0.8%	2.1%

<b>Mfg</b>	ThermoElectron Inc	<b>Parameter</b>	ozone
<b>Serial Number</b>	49C-73104-373	<b>Tfer Desc.</b>	Ozone transfer
<b>Tfer ID</b>	01100		
<b>Slope</b>	1.01297	<b>Intercept</b>	0.09498
<b>Cert Date</b>	1/23/2012	<b>CorrCoff</b>	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	-0.06	-0.15	0.27	ppb	
primary	2	35.81	35.25	36.00	ppb	2.13%
primary	3	66.13	65.18	65.09	ppb	-0.14%
primary	4	86.69	85.48	85.30	ppb	-0.21%
primary	5	214.62	211.77	210.40	ppb	-0.65%

<b>Sensor Component</b>	Cell B Noise	<b>Condition</b>	0.9 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Tmp.	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Fullscale Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Inlet Filter Condition	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Line Loss	<b>Condition</b>	Not tested	<b>Status</b>	pass
<b>Sensor Component</b>	Offset	<b>Condition</b>	0.000	<b>Status</b>	pass
<b>Sensor Component</b>	Span	<b>Condition</b>	0.995	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Freq.	<b>Condition</b>	96.4 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Sample Train	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Pressure	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Flow	<b>Condition</b>	0.71 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Tmp.	<b>Condition</b>	32.9 C	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Pressure	<b>Condition</b>	710 mmHg	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Noise	<b>Condition</b>	1.1 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Freq.	<b>Condition</b>	87.9 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Flow	<b>Condition</b>	0.68 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Battery Backup	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Zero Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass

# Temperature Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
RM Young	4013		PSU106	Sandy Grenville	11/03/2012	Temperature	04316

**DAS 1:**  
**Abs Avg Err**   **Abs Max Er**   **DAS 2:**  
**Abs Avg Err**   **Abs Max Er**

<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01D102193	<b>Tfer Desc.</b>	RTD translator
<b>Tfer ID</b>	01231		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01H0060	<b>Tfer Desc.</b>	RTD probe
<b>Tfer ID</b>	01230		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000

0.14	0.19		
------	------	--	--

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	0.04	0.06	0.000	0.1	C	0.06
primary	Temp Mid Range	26.86	26.84	0.000	26.7	C	-0.19
primary	Temp High Range	46.43	46.38	0.000	46.2	C	-0.17

<b>Sensor Component</b>	Shield	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Blower Status Switch	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Blower	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass

## Infrastructure Data For

Site ID  Technician  Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="PSU"/>	<input type="text" value="N/A"/>	<input type="text" value="3840 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

# Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	PSU106	Sandy Grenville	11/03/2012	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.17	0.33		

<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Shelter Temperatur
<b>Serial Number</b>	01D102193	<b>Tfer Desc.</b>	RTD translator
<b>Tfer ID</b>	01231		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Shelter Temperatur
<b>Serial Number</b>	01H0060	<b>Tfer Desc.</b>	RTD probe
<b>Tfer ID</b>	01230		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	23.60	23.58	0.000	23.3	C	-0.33
primary	Temp Mid Range	23.84	23.82	0.000	23.7	C	-0.13
primary	Temp Mid Range	23.95	23.93	0.000	23.9	C	-0.06



# Field Systems Comments

**1 Parameter:** DasComments

The meteorological tower has been removed.

**2 Parameter:** SitingCriteriaCom

The site is within 10 km of State College which has a population of approximately 50,000. The site is located in a university agricultural research field.

**3 Parameter:** ShelterCleanNotes

The shelter is owned by the university and is clean and orderly. The site is part of the Surfrad network.

**4 Parameter:** MetOpMaintCom

The 10-meter temperature sensor is now mounted in a naturally aspirated shield on the sample tower.

# Field Systems Data Form

F-02058-1500-S1-rev001

Site ID  Technician  Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Pine Grove Mills"/>
Operating Group	<input type="text" value="PSU"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="42-027-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text" value="40.7209"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text" value="-77.9316"/>
Land Use	<input type="text" value="agriculture"/>	QAPP Elevation Meters	<input type="text" value="376"/>
Terrain	<input type="text" value="rolling - complex"/>	QAPP Declination	<input type="text" value="10.9"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text" value="9/16/2005"/>
Site Telephone	<input type="text" value="(814) 237-5778"/>	Audit Latitude	<input type="text" value="40.720902"/>
Site Address 1	<input type="text" value="PSU Agriculture Research Farm"/>	Audit Longitude	<input type="text" value="-77.931759"/>
Site Address 2	<input type="text" value="Tadpole Road"/>	Audit Elevation	<input type="text" value="364"/>
County	<input type="text" value="Centre"/>	Audit Declination	<input type="text" value="-10.7"/>
City, State	<input type="text" value="Rockspring, PA"/>		
Zip Code	<input type="text" value="16865"/>	<b>Present</b>	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Primary Operator	<input type="text" value="Bob Ziegler"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text" value="(814) 863-4526"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text" value="rfz1@psu.edu"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text" value="none"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="PSU"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
	Model <input type="text" value="N/A"/>	Shelter Size	<input type="text" value="3840 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes	<input type="text" value="The shelter is owned by the university and is clean and orderly. The site is part of the Surfrad network."/>	
Site OK <input checked="" type="checkbox"/>	Notes	<input type="text"/>	

**Driving Directions** From 322 on the east side of State College, take SR 3024 south. After the traffic light at the intersection of route 26, SR 3024 will change to Whitehall Road. Continue on Whitehall road for approximately 3 miles to Fairbrook. Turn left on Tadpole Road in Fairbrook at the church. Continue approximately 0.5 miles, the site will be in the field on the right.

# Field Systems Data Form

F-02058-1500-S2-rev001

Site ID  Technician  Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km		<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km		<input checked="" type="checkbox"/>
City > 50,000 population	40 km		<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	State College	<input type="checkbox"/>
City 1,000 to 10,000 population	5 km		<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km		<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m		<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m		<input checked="" type="checkbox"/>
Feedlot operations	500 m		<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m		<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	10 m	<input type="checkbox"/>
Large parking lot	200 m		<input checked="" type="checkbox"/>
Small parking lot	100 m		<input checked="" type="checkbox"/>
Tree line	50 m		<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height		<input checked="" type="checkbox"/>

Siting Distances OK

**Siting Criteria Comment**

The site is within 10 km of State College which has a population of approximately 50,000. The site is located in a university agricultural research field.

# Field Systems Data Form

F-02058-1500-S3-rev001

Site ID PSU106

Technician Sandy Grenville

Site Visit Date 11/03/2012

- |    |  |                                     |     |
|----|--|-------------------------------------|-----|
| 1  | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?  | <input checked="" type="checkbox"/> | N/A |
| 2  | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)     | <input checked="" type="checkbox"/> | N/A |
| 3  | Are the tower and sensors plumb?   | <input checked="" type="checkbox"/> | N/A |
| 4  | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?  | <input checked="" type="checkbox"/> |     |
| 5  | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> |     |
| 6  | Is the solar radiation sensor plumb?   | <input checked="" type="checkbox"/> | N/A |
| 7  | Is it sited to avoid shading, or any artificial or reflected light?  | <input checked="" type="checkbox"/> | N/A |
| 8  | Is the rain gauge plumb?   | <input checked="" type="checkbox"/> | N/A |
| 9  | Is it sited to avoid sheltering effects from buildings, trees, towers, etc?  | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north?  | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees?   | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S4-rev001

Site ID  Technician  Site Visit Date

- 1 Do all the meteorological sensors appear to be intact, in good condition, and well maintained?
- 2 Are all the meteorological sensors operational online, and reporting data?
- 3 Are the shields for the temperature and RH sensors clean?
- 4 Are the aspirated motors working?
- 5 Is the solar radiation sensor's lens clean and free of scratches?
- 6 Is the surface wetness sensor grid clean and undamaged?
- 7 Are the sensor signal and power cables intact, in good condition, and well maintained?
- 8 Are the sensor signal and power cable connections protected from the elements and well maintained?

Parameter	Manufacturer	Model	S/N	Client ID
Temperature	RM Young	41342VO	4013	04316

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The 10-meter temperature sensor is now mounted in a naturally aspirated shield on the sample tower.

# Field Systems Data Form

F-02058-1500-S5-rev001

Site ID  Technician  Site Visit Date

**Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E**

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

**Pollutant analyzers and deposition equipment operations and maintenance**

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	A	none	02747
Filter pack flow pump	Thomas	107CAB18	060400022676	06023
Zero air pump	Werther International	C 70/4	000829156	06914
Ozone	ThermoElectron Inc	49i A1NAA	1030244795	000684

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S6-rev001

Site ID  Technician  Site Visit Date

**DAS, sensor translators, and peripheral equipment operations and maintenance**

- 1 Do the DAS instruments appear to be in good condition and well maintained?
  - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
  - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry?  Met sensors only
  - 4 Are the signal connections protected from the weather and well maintained?
  - 5 Are the signal leads connected to the correct DAS channel?
  - 6 Are the DAS, sensor translators, and shelter properly grounded?
  - 7 Does the instrument shelter have a stable power source?
  - 8 Is the instrument shelter temperature controlled?
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

<b>Stable</b>	<b>Grounded</b>
<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

Met tower removed

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000268
DAS	Campbell	CR3000	2512	000407
Modem	Raven	V4221-V	0844430833	06601

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The meteorological tower has been removed.

# Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

**Documentation**

**Does the site have the required instrument and equipment manuals?**

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

**Does the site have the required and most recent QC documents and report forms?**

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Apr 2009	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Nov 2009	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?  Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:



# Field Systems Data Form

F-02058-1500-S8-rev001

Site ID

Technician

Site Visit Date

**Site operation procedures**

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

**Are regular operational QA/QC checks performed on meteorological instruments?**

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>

**Are regular operational QA/QC checks performed on the ozone analyzer?**

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S9-rev001

Site ID  Technician  Site Visit Date

**Site operation procedures**

- |   |  |                                     |                          |
|---|--|-------------------------------------|--------------------------|
| 1 | Is the filter pack being changed every Tuesday as scheduled?                         | <input checked="" type="checkbox"/> | Filter changed morinings |
| 2 | Are the Site Status Report Forms being completed and filed correctly?                | <input checked="" type="checkbox"/> |                          |
| 3 | Are data downloads and backups being performed as scheduled?                         | <input type="checkbox"/>            | No longer required       |
| 4 | Are general observations being made and recorded? How?                               | <input checked="" type="checkbox"/> | SSRF, logbook            |
| 5 | Are site supplies on-hand and replenished in a timely fashion?                       | <input checked="" type="checkbox"/> |                          |
| 6 | Are sample flow rates recorded? How?   | <input checked="" type="checkbox"/> | SSRF, logbook, call-in   |
| 7 | Are samples sent to the lab on a regular schedule in a timely fashion?               | <input checked="" type="checkbox"/> |                          |
| 8 | Are filters protected from contamination during handling and shipping? How?          | <input type="checkbox"/>            | gloves are not used      |
| 9 | Are the site conditions reported regularly to the field operations manager or staff? | <input checked="" type="checkbox"/> |                          |

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/> <input type="text"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

## *Site Inventory by Site Visit*

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>BEL116-Eric Hebert-11/20/2012</i>						
1	11/20/2012	Computer	Dell	000280	D520	unknown
2	11/20/2012	DAS	Campbell	000341	CR3000	2120
3	11/20/2012	Elevation	Elevation	None	1	None
4	11/20/2012	Filter pack flow pump	Thomas	02755	107CAB18	1192001881
5	11/20/2012	Flow Rate	Apex	illegible	AXMC105LPM DPCV	illegible
6	11/20/2012	Infrastructure	Infrastructure	none	none	none
7	11/20/2012	Met tower	Universal Tower	06484	unknown	none
8	11/20/2012	Modem	Raven	06382	H4222-C	0802310513
9	11/20/2012	Ozone	ThermoElectron Inc	000692	49i A1NAA	1030244803
10	11/20/2012	Ozone Standard	ThermoElectron Inc	000366	49i A3NAA	0726124695
11	11/20/2012	Precipitation	Texas Electronics	06332	TR-525i-HT	43527-807
12	11/20/2012	Relative Humidity	Rotronic	06219	MP 101A-C4	123962
13	11/20/2012	Sample Tower	Aluma Tower	000127	B	none
14	11/20/2012	Shelter Temperature	Campbell	none	107-L	44281
15	11/20/2012	Shield (10 meter)	RM Young	05042	Aspirated 43408	none
16	11/20/2012	Shield (2 meter)	RM Young	05041	Aspirated 43408	none
17	11/20/2012	Siting Criteria	Siting Criteria	None	1	None
18	11/20/2012	Solar Radiation	Licor	04935	LI-200	PY47675
19	11/20/2012	Solar Radiation Translator	RM Young	04888	70101-X	none
20	11/20/2012	Surface Wetness	RM Young	04608	58101	none
21	11/20/2012	Temperature	RM Young	06308	41342VO	12533
22	11/20/2012	Temperature2meter	RM Young	06309	41342VO	12534
23	11/20/2012	Wind Direction	RM Young	03416	AQ05103-5	17096wdr
24	11/20/2012	Wind Speed	RM Young	03416	AQ05103-5	17096wsp
25	11/20/2012	Zero air pump	Teledyne	000776	701H	606

# DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2120	BEL116	Eric Hebert	11/20/2012	DAS	Primary

Das Date:	<input type="text" value="11/20/2012"/>	Audit Date:	<input type="text" value="11/20/2012"/>
Das Time:	<input type="text" value="10:30:01"/>	Audit Time:	<input type="text" value="10:30:00"/>
Das Day:	<input type="text" value="325"/>	Audit Day:	<input type="text" value="325"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0000"/>	Max Diff:	<input type="text" value="0.0001"/>
		Avg Diff:	<input type="text" value="0.0000"/>
		Max Diff:	<input type="text" value="0.0001"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="4000392"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01321"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/9/2012"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.1000	0.1000	V	V	0.0000
7	0.3000	0.3000	0.3000	V	V	0.0000
7	0.5000	0.5000	0.5000	V	V	0.0000
7	0.7000	0.7001	0.7000	V	V	-0.0001
7	0.9000	0.9001	0.9000	V	V	-0.0001
7	1.0000	1.0001	1.0000	V	V	-0.0001

# Flow Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
Apex	illegible		BEL116	Eric Hebert	11/20/2012	Flow Rate	illegible

<b>Mfg</b>	BIOS	<b>Parameter</b>	Flow Rate
<b>Serial Number</b>	122974	<b>Tfer Desc.</b>	BIOS 220-H
<b>Tfer ID</b>	01416		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	2/6/2012	<b>CorrCoff</b>	1.00000

<b>DAS 1:</b>	<b>DAS 2:</b>	<b>Cal Factor Zero</b>	-0.02
<b>A Avg % Diff:</b>	<b>A Max % Di</b>	<b>Cal Factor Full Scale</b>	0.98
0.11%	0.16%	<b>Rotometer Reading:</b>	1.85

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	0.01	0.033	0.02	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.042	0.02	l/m	l/m	
primary	test pt 1	0.000	1.512	1.53	1.528	1.51	l/m	l/m	-0.16%
primary	test pt 2	0.000	1.511	1.53	1.528	1.51	l/m	l/m	-0.07%
primary	test pt 3	0.000	1.512	1.53	1.528	1.51	l/m	l/m	-0.11%

<b>Sensor Component</b>	Leak Test	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Filter Azimuth	<b>Condition</b>	270 deg	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Depth	<b>Condition</b>	0.5 cm	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Position	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Moisture Present	<b>Condition</b>	No moisture present	<b>Status</b>	pass
<b>Sensor Component</b>	Rotometer Condition	<b>Condition</b>	Clean and dry	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Tubing Condition	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Filter Distance	<b>Condition</b>	5.0 cm	<b>Status</b>	pass

# Ozone Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
ThermoElectron Inc	1030244803		BEL116	Eric Hebert	11/20/2012	Ozone	000692

<b>Slope:</b>	0.97643	<b>Slope:</b>	0.00000
<b>Intercept</b>	0.47920	<b>Intercept</b>	0.00000
<b>CorrCoff</b>	0.99999	<b>CorrCoff</b>	0.00000

<b>DAS 1:</b>	<b>DAS 2:</b>
<b>A Avg % Diff:</b>	<b>A Avg %Dif</b>
<b>A Max % Di</b>	<b>A Max % Di</b>
1.6%	2.1%

<b>Mfg</b>	ThermoElectron Inc	<b>Parameter</b>	ozone
<b>Serial Number</b>	517112175	<b>Tfer Desc.</b>	Ozone primary stan
<b>Tfer ID</b>	01111		
<b>Slope</b>	1.00987	<b>Intercept</b>	0.07483
<b>Cert Date</b>	3/23/2012	<b>CorrCoff</b>	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.19	0.11	0.57	ppb	
primary	2	31.84	31.45	31.11	ppb	-1.08%
primary	3	66.12	65.39	64.34	ppb	-1.61%
primary	4	83.36	82.47	81.30	ppb	-1.42%
primary	5	107.98	106.85	104.60	ppb	-2.11%

<b>Sensor Component</b>	Cell B Noise	<b>Condition</b>	1.0 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Tmp.	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Fullscale Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Inlet Filter Condition	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Line Loss	<b>Condition</b>	Not tested	<b>Status</b>	pass
<b>Sensor Component</b>	Offset	<b>Condition</b>	-0.20	<b>Status</b>	pass
<b>Sensor Component</b>	Span	<b>Condition</b>	1.025	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Freq.	<b>Condition</b>	101.1 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Sample Train	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Pressure	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Flow	<b>Condition</b>	0.69 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Tmp.	<b>Condition</b>	35.9 C	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Pressure	<b>Condition</b>	733 mmHg	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Noise	<b>Condition</b>	1.1 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Freq.	<b>Condition</b>	88.9 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Flow	<b>Condition</b>	0.70 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Battery Backup	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Zero Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass

# Wind Speed Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
RM Young	17096wsp		BEL116	Eric Hebert	11/20/2012	Wind Speed	03416

**Prop or Cups SN**   
**Prop or Cups Torque**  to   
**Prop Correction Fact**

<b>Mfg</b>	<input type="text" value="RM Young"/>	<b>Parameter</b>	<input type="text" value="wind speed"/>
<b>Serial Number</b>	<input type="text"/>	<b>Tfer Desc.</b>	<input type="text" value="wind speed motor (h"/>
<b>Tfer ID</b>	<input type="text" value="01262"/>		
<b>Slope</b>	<input type="text" value="1.00000"/>	<b>Intercept</b>	<input type="text" value="0.00000"/>
<b>Cert Date</b>	<input type="text" value="1/13/2010"/>	<b>CorrCoff</b>	<input type="text" value="1.00000"/>
<b>Mfg</b>	<input type="text" value="RM Young"/>	<b>Parameter</b>	<input type="text" value="wind speed"/>
<b>Serial Number</b>	<input type="text"/>	<b>Tfer Desc.</b>	<input type="text" value="wind speed motor (l"/>
<b>Tfer ID</b>	<input type="text" value="01261"/>		
<b>Slope</b>	<input type="text" value="1.00000"/>	<b>Intercept</b>	<input type="text" value="0.00000"/>
<b>Cert Date</b>	<input type="text" value="1/13/2010"/>	<b>CorrCoff</b>	<input type="text" value="1.00000"/>

	<b>DAS 1:</b>		<b>DAS 2:</b>	
	<b>Low Range</b>	<b>High Range</b>	<b>Low Range</b>	<b>High Range</b>
<b>Abs Avg Err</b>	<input type="text" value="0.05"/>	<input type="text" value="0.00%"/>	<input type="text"/>	<input type="text"/>
<b>Abs Max Er</b>	<input type="text" value="0.20"/>	<input type="text" value="0.00%"/>	<input type="text"/>	<input type="text"/>

UseDescription:	InputDevice:	Input RPM:	Input m/s:	Output V:	DAS m/s:	Diff/ %Diff:	Difference:
primary	none	0	0.20	0.000	0.0		-0.20
primary	01262	200	1.02	0.000	1.0		0.00
primary	01262	400	2.05	0.000	2.1		0.00
primary	01262	800	4.10	0.000	4.1		0.00
primary	01262	1200	6.14	0.000	6.1	0.00%	
primary	01262	2400	12.29	0.000	12.3	0.00%	
primary	01262	4000	20.48	0.000	20.5	0.00%	
primary	01262	9400	48.13	0.000	48.1	0.00%	

<b>Sensor Component</b>	<input type="text" value="Torque"/>	<b>Condition</b>	<input type="text"/>	<b>Status</b>	<input type="text" value="pass"/>
<b>Sensor Component</b>	<input type="text" value="System Memo"/>	<b>Condition</b>	<input type="text"/>	<b>Status</b>	<input type="text" value="pass"/>
<b>Sensor Component</b>	<input type="text" value="Sensor Plumb"/>	<b>Condition</b>	<input type="text" value="Plumb"/>	<b>Status</b>	<input type="text" value="pass"/>
<b>Sensor Component</b>	<input type="text" value="Sensor Heater"/>	<b>Condition</b>	<input type="text" value="N/A"/>	<b>Status</b>	<input type="text" value="pass"/>
<b>Sensor Component</b>	<input type="text" value="Prop or Cups Condition"/>	<b>Condition</b>	<input type="text" value="Good"/>	<b>Status</b>	<input type="text" value="pass"/>
<b>Sensor Component</b>	<input type="text" value="Condition"/>	<b>Condition</b>	<input type="text" value="Good"/>	<b>Status</b>	<input type="text" value="pass"/>

# Wind Direction Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	17096wdr		BEL116	Eric Hebert	11/20/2012	Wind Direction	03416

Vane SN:  C. A. Align. deg. true:

Vane Torque  to

Mfg	<input type="text" value="RM Young"/>	Parameter	<input type="text" value="wind direction"/>
Serial Number	<input type="text" value=""/>	Tfer Desc.	<input type="text" value="wind direction wheel"/>
Tfer ID	<input type="text" value="01266"/>		
Mfg	<input type="text" value="Ushikata"/>	Parameter	<input type="text" value="wind direction"/>
Serial Number	<input type="text" value="190037"/>	Tfer Desc.	<input type="text" value="transit"/>
Tfer ID	<input type="text" value="01265"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/4/2011"/>	CorrCoff	<input type="text" value="1.00000"/>

DAS 1:	DAS 2:		
Orientation	Linearity:	Orientation	Linearity:
Abs Avg Err	<input type="text" value="2.3"/>	<input type="text" value="1.3"/>	<input type="text" value=""/>
Abs Max Er	<input type="text" value="3"/>	<input type="text" value="2"/>	<input type="text" value=""/>

UseDescription:	TferID:	Input Raw:	Linearity	Output V:	Output Deg.:	Difference:	Change:	Error:
primary	01265	90	<input type="checkbox"/>	0.000	88	2		2
primary	01265	180	<input type="checkbox"/>	0.000	177	3		3
primary	01265	270	<input type="checkbox"/>	0.000	267	3		3
primary	01265	360	<input type="checkbox"/>	0.000	1	1		1
primary	01266	0	<input checked="" type="checkbox"/>	0.000	1	1	47	2
primary	01266	45	<input checked="" type="checkbox"/>	0.000	44	1	43	-2
primary	01266	90	<input checked="" type="checkbox"/>	0.000	88	2	44	-1
primary	01266	135	<input checked="" type="checkbox"/>	0.000	133	2	45	0
primary	01266	180	<input checked="" type="checkbox"/>	0.000	177	3	44	-1
primary	01266	225	<input checked="" type="checkbox"/>	0.000	221	4	44	-1
primary	01266	270	<input checked="" type="checkbox"/>	0.000	267	3	46	1
primary	01266	315	<input checked="" type="checkbox"/>	0.000	314	1	47	2

Sensor Component	<input type="text" value="Mast"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Heater"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Plumb"/>	Condition	<input type="text" value="Plumb"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Torque"/>	Condition	<input type="text" value=""/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Vane Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="System Memo"/>	Condition	<input type="text" value=""/>	Status	<input type="text" value="pass"/>



# Temperature Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
RM Young	12533		BEL116	Eric Hebert	11/20/2012	Temperature	06308

<b>DAS 1:</b>	<b>DAS 2:</b>
Abs Avg Err	Abs Max Er
Abs Avg Err	Abs Max Er

<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01D102193	<b>Tfer Desc.</b>	RTD translator
<b>Tfer ID</b>	01231		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01H0060	<b>Tfer Desc.</b>	RTD probe
<b>Tfer ID</b>	01230		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000

0.15	0.33		
------	------	--	--

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	0.24	0.26	0.000	0.17	C	-0.09
primary	Temp Mid Range	14.28	14.28	0.000	14.31	C	0.03
primary	Temp High Range	47.01	46.96	0.000	47.29	C	0.33

<b>Sensor Component</b>	Shield	<b>Condition</b>	Moderately clean	<b>Status</b>	pass
<b>Sensor Component</b>	Blower Status Switch	<b>Condition</b>	Functioning	<b>Status</b>	pass
<b>Sensor Component</b>	Blower	<b>Condition</b>	Functioning	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass

# 2 Meter Temperature Data For

Calc. Difference

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	12534		BEL116	Eric Hebert	11/20/2012	Temperature2meter	06309

**DAS 1:** Abs Avg Err Abs Max Er  
**DAS 2:** Abs Avg Err Abs Max Er

<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01H0060	<b>Tfer Desc.</b>	RTD probe
<b>Tfer ID</b>	01230		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Temperature
<b>Serial Number</b>	01D102193	<b>Tfer Desc.</b>	RTD translator
<b>Tfer ID</b>	01231		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000

0.17 0.35

UseDescription:	Test type:	InputTmpRaw	InputTmpCorrected:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Rang	0.24	0.26	0.000	0.14	C	-0.12
primary	Temp Mid Rang	14.28	14.28	0.000	14.31	C	0.03
primary	Temp High Ran	47.01	46.96	0.000	47.31	C	0.35

<b>Sensor Component</b>	Blower Status Switch	<b>Condition</b>	Functioning	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Blower	<b>Condition</b>	Functioning	<b>Status</b>	pass
<b>Sensor Component</b>	Properly Sited	<b>Condition</b>	Properly sited	<b>Status</b>	pass
<b>Sensor Component</b>	Shield	<b>Condition</b>	Moderately clean	<b>Status</b>	pass

# Humidity Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
Rotronic	123962		BEL116	Eric Hebert	11/20/2012	Relative Humidity	06219

<b>Mfg</b>	Rotronic	<b>Parameter</b>	Relative Humidity
<b>Serial Number</b>	124432	<b>Tfer Desc.</b>	Hygroclip
<b>Tfer ID</b>	01225		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	2/13/2012	<b>CorrCoff</b>	1.00000

**DAS 1:**

**DAS 2:**

	<b>Low Range</b>	<b>High Range</b>	<b>Low Range</b>	<b>High Range</b>
<b>Abs Avg Err</b>	7.1	5.9		
<b>Abs Max Er</b>	8.0	5.9		

UseDesc.:	Test type:	Device:	Input RH:	GTL Raw:	RH Corr.:	DAS Volts:	DAS %RH:	Difference:
primary	RH Low Range	Hygroclip	32.8	33.4	32.8	0.389	38.9	6.1
primary	RH Low Range	Hygroclip	52.9	55.1	52.9	0.609	60.9	8.0
primary	RH High Range	Hygroclip	93.6	91.4	93.6	0.995	99.5	5.9

<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Blower	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Blower Status Switch	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	RH Filter	<b>Condition</b>	Dirty	<b>Status</b>	Fail
<b>Sensor Component</b>	Shield	<b>Condition</b>	Moderately clean	<b>Status</b>	pass

# Solar Radiation Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
Licor	PY47675		BEL116	Eric Hebert	11/20/2012	Solar Radiation	04935

<b>Mfg</b>	RM Young	
<b>SN/Owner ID</b>	none	04888
<b>Parameter</b>	Solar Radiation Translator	

<b>Mfg</b>	Eppley	<b>Parameter</b>	solar radiation
<b>Serial Number</b>	10765	<b>Tfer Desc.</b>	SR transfer translat
<b>Tfer ID</b>	01246		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	1/6/2010	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	Eppley	<b>Parameter</b>	solar radiation
<b>Serial Number</b>	34341F3	<b>Tfer Desc.</b>	SR transfer sensor
<b>Tfer ID</b>	01245		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	12/16/2010	<b>CorrCoff</b>	1.00000

**DAS 1:**                                      **DAS 2:**  
 % Diff of Avg   %Diff of Max   %Diff of Avg   %Diff of Max

6.4%      6.4%      0.0%      0.0%

UseDescription:	Measure Date	MeasureTime	Tfer Corr:	DAS w/m2:	PctDifference:
primary	11/20/2012	11:00	299	318	6.4%
primary	11/20/2012	12:00	288	304	5.6%
primary	11/20/2012	13:00	216	232	7.4%

<b>Sensor Component</b>	Sensor Level	<b>Condition</b>	Level	<b>Status</b>	pass
<b>Sensor Component</b>	Sensor Clean	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Properly Sited	<b>Condition</b>	Properly sited	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass

# Surface Wetness Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
RM Young	none		BEL116	Eric Hebert	11/20/2012	Surface Wetness	04608

<b>Mfg</b>	Ohmite	<b>Parameter</b>	surface wetness
<b>Serial Number</b>	296-1200	<b>Tfer Desc.</b>	decade box
<b>Tfer ID</b>	01210		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	1/4/2011	<b>CorrCoff</b>	1.00000

**Manual Test Pass**

UseDescription:	Test Type:	Tfer kOhms:	OutputSignal:	DAS eng:	OutputSignalEngUni	TferUnits:	OutputSignalUnit
primary	wet	N/A	1.017	1.02	V	N/A	V
primary	dry	N/A	0.008	0.01	V	N/A	V

<b>Sensor Component</b>	Grid Orientation	<b>Condition</b>	North	<b>Status</b>	pass
<b>Sensor Component</b>	Grid Clean	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Grid Angle	<b>Condition</b>	About 45 deg	<b>Status</b>	pass
<b>Sensor Component</b>	Grid Condition	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Properly Sited	<b>Condition</b>	Properly sited	<b>Status</b>	pass
<b>Sensor Component</b>	Grid Type	<b>Condition</b>	Grid without holes	<b>Status</b>	pass

# Precipitation Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
Texas Electronics	43527-807		BEL116	Eric Hebert	11/20/2012	Precipitation	06332

<b>DAS 1:</b>	<b>DAS 2:</b>
<b>A Avg % Diff:</b>	<b>A Max % Di</b>
5.0%	8.0%
<b>A Avg %Dif</b>	<b>A Max % Di</b>

<b>Mfg</b>	PMP	<b>Parameter</b>	Precipitation
<b>Serial Number</b>	EW-06134-50	<b>Tfer Desc.</b>	250ml graduate
<b>Tfer ID</b>	01250		
<b>Slope</b>	1.00000	<b>Intercept</b>	0.00000
<b>Cert Date</b>	9/5/2005	<b>CorrCoff</b>	1.00000

UseDesc.	Test type:	TferVolume:	Iteration:	TimePerTip:	Eq.Ht:	DAS eng:	Eq.HtUnit:	OSE Unit:	TferUnits:	PctDifference
primary	tip check	10 manual	1	2 sec	0.10	0.10	in	in	ml	
primary	test 1	231.5	1	8 sec	0.50	0.49	in	in	ml	-2.0%
primary	test 2	231.5	2	10 sec	0.50	0.46	in	in	ml	-8.0%

<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Sensor Heater	<b>Condition</b>	Functioning	<b>Status</b>	pass
<b>Sensor Component</b>	Gauge Screen	<b>Condition</b>	Installed	<b>Status</b>	Fail
<b>Sensor Component</b>	Level	<b>Condition</b>	Level	<b>Status</b>	pass
<b>Sensor Component</b>	Gauge Drain Screen	<b>Condition</b>	Installed	<b>Status</b>	pass
<b>Sensor Component</b>	Gauge Clean	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Funnel Clean	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Condition	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Properly Sited	<b>Condition</b>	Properly sited	<b>Status</b>	pass

## Infrastructure Data For

Site ID  Technician  Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2140-4)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value=""/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

# Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	44281	BEL116	Eric Hebert	11/20/2012	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.10	0.19		

<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Shelter Temperatur
<b>Serial Number</b>	01D102193	<b>Tfer Desc.</b>	RTD translator
<b>Tfer ID</b>	01231		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000
<b>Mfg</b>	Eutechnics	<b>Parameter</b>	Shelter Temperatur
<b>Serial Number</b>	01H0060	<b>Tfer Desc.</b>	RTD probe
<b>Tfer ID</b>	01230		
<b>Slope</b>	1.00157	<b>Intercept</b>	-0.02095
<b>Cert Date</b>	2/10/2012	<b>CorrCoff</b>	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	23.44	23.42	0.000	23.6	C	0.19
primary	Temp Mid Range	24.27	24.25	0.000	24.2	C	-0.02



# Field Systems Comments

**1 Parameter:** SiteOpsProcedures

The site operator was incorrectly recording the filter final flow as the filter installed flow (on the SSRF) as instructed by the previous site operator. This was discussed during the audit and the correct procedures were described by the auditor.

**2 Parameter:** SitingCriteriaCom

The site is located between Washington DC and Baltimore, MD near a major transportation corridor. Although the site surroundings are woodland and agriculture, the region surrounding the research center is densely populated and urban.

**3 Parameter:** ShelterCleanNotes

Larger shelter installed since previous audit visit in 2010.

# Field Systems Data Form

F-02058-1500-S1-rev001

Site ID  Technician  Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Laurel"/>
Operating Group	<input type="text" value="BARC/private"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="24-033-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, SO2, NOy, NOx, CO, Hg"/>	QAPP Latitude	<input type="text" value="39.0283"/>
Deposition Measurement	<input type="text" value="dry, wet, Hg"/>	QAPP Longitude	<input type="text" value="-76.8175"/>
Land Use	<input type="text" value="urban - agriculture"/>	QAPP Elevation Meters	<input type="text" value="46"/>
Terrain	<input type="text" value="flat"/>	QAPP Declination	<input type="text" value="11.25"/>
Conforms to MLM	<input type="text" value="No"/>	QAPP Declination Date	<input type="text" value="2/23/2006"/>
Site Telephone	<input type="text" value="(301) 474-3019"/>	Audit Latitude	<input type="text" value="39.028177"/>
Site Address 1	<input type="text" value="BARC old airport"/>	Audit Longitude	<input type="text" value="-76.817127"/>
Site Address 2	<input type="text" value="Springfield Road"/>	Audit Elevation	<input type="text" value="47"/>
County	<input type="text" value="Prince George's"/>	Audit Declination	<input type="text" value="-11"/>
City, State	<input type="text" value="Laurel, MD"/>		
Zip Code	<input type="text" value="20708"/>	<b>Present</b>	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Primary Operator	<input type="text" value="Dan Goldberg"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text" value="(301) 405-7638"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text" value="dgoldb@atmos.umd.edu"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text" value="Allison Ring"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text" value="aring1@umd.edu"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Unknown"/>	Model <input type="text" value="Unknown"/>	Shelter Size <input type="text" value="Unknown"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="Larger shelter installed since previous audit visit in 2010."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

**Driving Directions**

# Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km		<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km		<input checked="" type="checkbox"/>
City > 50,000 population	40 km	25 km	<input type="checkbox"/>
City 10,000 to 50,000 population	10 km		<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km		<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km		<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m		<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m		<input checked="" type="checkbox"/>
Feedlot operations	500 m		<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m		<input checked="" type="checkbox"/>
Limited agricultural operations	200 m		<input checked="" type="checkbox"/>
Large parking lot	200 m		<input checked="" type="checkbox"/>
Small parking lot	100 m		<input checked="" type="checkbox"/>
Tree line	50 m		<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height		<input checked="" type="checkbox"/>

Siting Distances OK

**Siting Criteria Comment**

The site is located between Washington DC and Baltimore, MD near a major transportation corridor. Although the site surroundings are woodland and agriculture, the region surrounding the research center is densely populated and urban.

# Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- |    |  |                                     |                  |
|----|--|-------------------------------------|------------------|
| 1  | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?  | <input checked="" type="checkbox"/> |                  |
| 2  | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)     | <input checked="" type="checkbox"/> |                  |
| 3  | Are the tower and sensors plumb?   | <input checked="" type="checkbox"/> |                  |
| 4  | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?  | <input checked="" type="checkbox"/> |                  |
| 5  | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> |                  |
| 6  | Is the solar radiation sensor plumb?   | <input checked="" type="checkbox"/> |                  |
| 7  | Is it sited to avoid shading, or any artificial or reflected light?  | <input checked="" type="checkbox"/> |                  |
| 8  | Is the rain gauge plumb?   | <input checked="" type="checkbox"/> |                  |
| 9  | Is it sited to avoid sheltering effects from buildings, trees, towers, etc?  | <input checked="" type="checkbox"/> |                  |
| 10 | Is the surface wetness sensor sited with the grid surface facing north?  | <input checked="" type="checkbox"/> |                  |
| 11 | Is it inclined approximately 30 degrees?   | <input checked="" type="checkbox"/> | About 45 degrees |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S4-rev001

Site ID  Technician  Site Visit Date

- 1 Do all the meteorological sensors appear to be intact, in good condition, and well maintained?
- 2 Are all the meteorological sensors operational online, and reporting data?
- 3 Are the shields for the temperature and RH sensors clean?
- 4 Are the aspirated motors working?
- 5 Is the solar radiation sensor's lens clean and free of scratches?
- 6 Is the surface wetness sensor grid clean and undamaged?
- 7 Are the sensor signal and power cables intact, in good condition, and well maintained?
- 8 Are the sensor signal and power cable connections protected from the elements and well maintained?

Parameter	Manufacturer	Model	S/N	Client ID
Solar Radiation	Licor	LI-200	PY47675	04935
Shield (10 meter)	RM Young	Aspirated 43408	none	05042
Shield (2 meter)	RM Young	Aspirated 43408	none	05041
Surface Wetness	RM Young	58101	none	04608
Temperature	RM Young	41342VO	12533	06308
Temperature2meter	RM Young	41342VO	12534	06309
Relative Humidity	Rotronic	MP 101A-C4	123962	06219
Precipitation	Texas Electronics	TR-525i-HT	43527-807	06332
Met tower	Universal Tower	unknown	none	06484
Wind Speed	RM Young	AQ05103-5	17096wsp	03416
Wind Direction	RM Young	AQ05103-5	17096wdr	03416

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S5-rev001

Site ID

Technician

Site Visit Date

**Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E**

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

**Pollutant analyzers and deposition equipment operations and maintenance**

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.  1/4 teflon by 15 meters
- 4 Describe dry dep sample tube.  3/8 teflon by 15 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)  At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?  Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	B	none	000127
Ozone	ThermoElectron Inc	49i A1NAA	1030244803	000692
Filter pack flow pump	Thomas	107CAB18	1192001881	02755
Zero air pump	Teledyne	701H	606	000776

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S6-rev001

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
  - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
  - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry?  Met sensors only
  - 4 Are the signal connections protected from the weather and well maintained?
  - 5 Are the signal leads connected to the correct DAS channel?
  - 6 Are the DAS, sensor translators, and shelter properly grounded?
  - 7 Does the instrument shelter have a stable power source?
  - 8 Is the instrument shelter temperature controlled?
- Stable**

**Grounded**
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000280
DAS	Campbell	CR3000	2120	000341
Modem	Raven	H4222-C	0802310513	06382
Solar Radiation Translator	RM Young	70101-X	none	04888

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

# Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Nov 2010	<input type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	Nov 2010	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- Is the station log properly completed during every site visit?
- Are the Site Status Report Forms being completed and current?  With the exception of final flow
- Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- Are ozone z/s/p control charts properly completed and current?  Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:



# Field Systems Data Form

F-02058-1500-S8-rev001

Site ID

Technician

Site Visit Date

**Site operation procedures**

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

**Are regular operational QA/QC checks performed on meteorological instruments?**

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

**Are regular operational QA/QC checks performed on the ozone analyzer?**

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator was incorrectly recording the filter final flow as the filter installed flow (on the SSRF) as instructed by the previous site operator. This was discussed during the audit and the correct procedures were described by the auditor.

# Field Systems Data Form

F-02058-1500-S9-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	With noted exceptions
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean glove on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

---

**APPENDIX B**

**CASTNET Site Spot Report Forms**

---

# EEMS Spot Report

Data Compiled: 10/28/2012 6:00:22 PM

Site Visit Date Site Technician

10/09/2012 ACA416 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Wind Speed average error below 5m/s in m/s	P	3	0.5	4	0.20	m/s	P
2	Wind Speed max error below 5m/s in m/s	P	3	0.5	4	0.22	m/s	P
3	Wind Speed average % difference above 5 m/s	P	3	5	4	0.7	%	P
4	Wind Speed max % difference above 5 m/s	P	3	5	4	1.6	%	P
5	Wind Speed Torque average error	P	3	0.5	1	0.20	g-cm	P
6	Wind Speed Torque max error	P	3	0.5	1	0.2	g-cm	P
7	Wind Direction Input Deg True average error (de	P	2	5	5	3.4	degrees	P
8	Wind Direction Input Deg True max error (deg)	P	2	5	5	5	degrees	P
9	Wind Direction Linearity average error (deg)	P	2	5	8	1.2	degrees	P
10	Wind Direction Linearity max error (deg)	P	2	5	8	4	degrees	P
11	Wind Direction Torque average error	P	2	20	1	6	g-cm	P
12	Wind Direction Torque max error	P	2	20	1	7	g-cm	P
13	Temperature average error	P	4	0.5	12	0.05	c	P
14	Temperature max error	P	4	0.5	12	0.09	c	P
15	Delta Temperature average error	P	5	0.5	12	0.06	c	P
16	Delta Temperature max error	P	5	0.5	12	0.07	c	P
17	Relative Humidity average above 85%	P	6	10	1	5.1	%	P
18	Relative Humidity max above 85%	P	6	10	1	5.1	%	P
19	Relative Humidity average below 85%	P	6	10	2	6.7	%	P
20	Relative Humidity max below 85%	P	6	10	2	7.7	%	P
21	Solar Radiation % diff of avg	P	9	10	4	2.91	%	P
22	Solar Radiation % diff of max STD value	P	9	10	4	2.6	%	P
23	Precipitation average % difference	P	1	10	2	19.0	%	Fail
24	Precipitation max % difference	P	1	10	2	22.0	%	Fail
25	Ozone Slope	P	0	1.1	4	0.96212	unitless	P
26	Ozone Intercept	P	0	5	4	0.29896	ppb	P
27	Ozone correlation	P	0	0.995	4	0.99993	unitless	P
28	Ozone % difference avg	P	7	10	4	3.2	%	P
29	Ozone % difference max	P	7	10	4	4.3	%	P
30	Flow Rate average % difference	P	10	5	2	1.96	%	P
31	Flow Rate max % difference	P	10	5	2	2.09	%	P
32	DAS Time maximum error	P	0	5	1	0.40	min	P
33	DAS Voltage average error	P	2	0.003	14	0.0003	V	P
34	Surface Wetness Response	P	12	100	1	95.5		P

**SiteVisitDate Site Technician**

---

10/09/2012	ACA416	Eric Hebert							
35	Shelter Temperature average error	P	5	1	2	0.53	c	<b>P</b>	
36	Shelter Temperature max error	P	5	1	2	0.67	c	<b>P</b>	

## Field Performance Comments

- Parameter:** Flow Rate      **SensorComponent:** Moisture Present      **CommentCode** 72  
The filter sample tubing has drops of moisture in low sections outside the shelter.
- Parameter:** Ozone      **SensorComponent:** Sample Train      **CommentCode** 208  
The ozone sample train is composed of materials other than the recommended materials which are Teflon and glass only.
- Parameter:** Precipitation      **SensorComponent:** Properly Sited      **CommentCode** 193  
Objects violate the 45 degree rule for the tipping bucket rain gage.
- Parameter:** Precipitation      **SensorComponent:** Sensor Heater      **CommentCode** 104  
The tipping bucket heater is generating excessive heat, enough to evaporate water on the funnel.
- Parameter:** Solar Radiation      **SensorComponent:** Sensor Level      **CommentCode** 128  
The solar radiation sensor is mounted on the meteorological tower and is difficult to access. The site operator does not check the sensor weekly.

## Field Systems Comments

- Parameter:** SiteOpsProcComm  
This site is operated partly by the NPS and the State of Maine DEP. It is not visited by ARS for semiannual calibration and maintenance visits. The site operator does not perform many of the routine checks conducted at other CASTNET sites, such as tip checks, wetness sensor tests, and visual checks of the blowers. The state of Maine personnel maintain the meteorological systems.
- Parameter:** SiteOpsProcedures  
The meteorological and ozone instrument checks and maintenance are performed by the State of Maine DEP.
- Parameter:** ShelterCleanNotes  
The shelter is clean and well organized.
- Parameter:** PollAnalyzerCom  
The ozone sample inlet has a stainless steel funnel and stainless steel fittings. The recommended material for ozone sample train is Teflon or glass.
- Parameter:** MetSensorComme  
The solar radiation sensor is a full bubble off level and bias to the west.
- Parameter:** MetOpMaintCom  
The tipping bucket heater thermostat has failed in the closed circuit position allowing the heater to be continuously on. The tipping mechanism was beginning to melt. The heater was unplugged during the site audit.

# EEMS Spot Report

Data Compiled: 1/18/2013 12:03:13 PM

Site Visit Date Site Technician

10/10/2012 HOW191 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	3	0.26	c	P
2	Temperature max error	P	4	0.5	3	0.34	c	P
3	Ozone Slope	P	0	1.1	3	0.98987	unitless	P
4	Ozone Intercept	P	0	5	3	0.57532	ppb	P
5	Ozone correlation	P	0	0.995	3	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	3	3.0	%	P
7	Ozone % difference max	P	7	10	3	6.1	%	P
8	Flow Rate average % difference	P	11	5	2	0.24	%	P
9	Flow Rate max % difference	P	11	5	2	0.38	%	P
10	Shelter Temperature average error	P	5	1	3	0.26	c	P
11	Shelter Temperature max error	P	5	1	3	0.40	c	P


## Field Performance Comments

- Parameter:** Flow Rate      **SensorComponent:** System Memo      **CommentCode** 209  
This parameter is being measured at 23.5 meters from the ground and above a tree canopy.
- Parameter:** Temperature      **SensorComponent:** System Memo      **CommentCode** 209  
This parameter is being measured at 23.5 meters from the ground and above a tree canopy.

## Field Systems Comments

- Parameter:** SiteOpsProcedures  
The daily zero, span, and precision checks are conducted through one of the 8 inlets only.
- Parameter:** SitingCriteriaCom  
The CASTNET filter pack at this location is located above a tree canopy at approximately 23.5 meters from the ground. A second filter is located below the canopy at approximately 2 meters. This is an AmeriFlux site which is approximately 2.5 km to the SW of the HOW132 CASTNET site. See the map included as Figure 1.
- Parameter:** ShelterCleanNotes  
The custom built shelter is clean and organized.
- Parameter:** PollAnalyzerCom  
Ozone measurements at this location are being conducted at 8 levels through the tree canopy from 2 meters to 23.5 meters. Three minute measurements for each height are aggregated into an hourly average for each height to produce a through-canopy ozone profile.
- Parameter:** MetSensorComme  
Other than a temperature sensor at each CASTNET filter location the meteorological instrumentation is being operated by the University of Maine and AmeriFlux.






Data use subject to license.

© DeLorme. Topo North America™ 9.

www.delorme.com



# EEMS Spot Report

Data Compiled: 1/17/2013 2:09:52 PM

SiteVisitDate	Site	Technician
10/10/2012	HOW191-B	Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	3	0.08	c	P
2	Temperature max error	P	4	0.5	3	0.17	c	P
3	Flow Rate average % difference	P	10	5	2	0.46	%	P
4	Flow Rate max % difference	P	10	5	2	0.90	%	P

## Field Performance Comments

- Parameter:** Flow Rate      **SensorComponent:** System Memo      **CommentCode** 210  
This parameter is being measured at 2 meters from the ground and below a tree canopy.
- Parameter:** Temperature      **SensorComponent:** System Memo      **CommentCode** 210  
This parameter is being measured at 2 meters from the ground and below a tree canopy.

# EEMS Spot Report

Data Compiled: 10/28/2012 8:20:23 PM

Site Visit Date Site Technician

10/11/2012 HOW132 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	12	0.14	c	P
2	Temperature max error	P	4	0.5	12	0.25	c	P
3	Ozone Slope	P	0	1.1	4	0.98028	unitless	P
4	Ozone Intercept	P	0	5	4	0.17489	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99990	unitless	P
6	Ozone % difference avg	P	7	10	4	1.5	%	P
7	Ozone % difference max	P	7	10	4	2.6	%	P
8	Flow Rate average % difference	P	10	5	2	1.55	%	P
9	Flow Rate max % difference	P	10	5	2	1.72	%	P
10	DAS Time maximum error	P	0	5	1	0.00	min	P
11	DAS Voltage average error	P	7	0.003	28	0.0000	V	P
12	Shelter Temperature average error	P	5	1	9	0.48	c	P
13	Shelter Temperature max error	P	5	1	9	0.65	c	P

## Field Systems Comments

**1 Parameter:** SiteOpsProcComm

The site operator reported that he does not always use gloves to handle the filters consistently.

**2 Parameter:** SiteOpsProcedures

The ozone sample inlet filter is replaced and the sample train is leak tested once each month.

**3 Parameter:** SitingCriteriaCom

There is a small power plant about 30 km northeast of the site. It is on-line approximately 50% of the time. The site is near a plantation and within 20 meters of the tree line.

**4 Parameter:** ShelterCleanNotes

The shelter is cleaner than it has been during previous audit visits

**5 Parameter:** PollAnalyzerCom

There is a tree branch that contacts the filter enclosure and the filter pack when the tower is lowered and raised.

# EEMS Spot Report

Data Compiled: 10/28/2012 8:55:37 PM

Site Visit Date Site Technician

10/12/2012 ASH135 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	9	0.06	c	P
2	Temperature max error	P	4	0.5	9	0.09	c	P
3	Ozone Slope	P	0	1.1	4	1.01773	unitless	P
4	Ozone Intercept	P	0	5	4	-0.34656	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
6	Ozone % difference avg	P	7	10	4	1.4	%	P
7	Ozone % difference max	P	7	10	4	1.5	%	P
8	Flow Rate average % difference	P	10	5	2	0.09	%	P
9	Flow Rate max % difference	P	10	5	2	0.11	%	P
10	DAS Time maximum error	P	0	5	1	0.00	min	P
11	DAS Voltage average error	P	7	0.003	28	0.0000	V	P
12	Shelter Temperature average error	P	5	1	9	0.55	c	P
13	Shelter Temperature max error	P	5	1	9	0.84	c	P

## Field Systems Comments

**1 Parameter:** DasComments

The met tower has been removed and the 10 meter temperature sensor is mounted in a naturally aspirated shield on the sample tower.

**2 Parameter:** SiteOpsProcedures

The ozone inlet filter is replaced and the sample train is leak tested once each month.

**3 Parameter:** SitingCriteriaCom

There is an evergreen plantation 20 meters south of the site.

**4 Parameter:** ShelterCleanNotes

The shelter is in good condition, clean, and very well organized.

# EEMS Spot Report

Data Compiled: 1/7/2013 12:37:55 PM

Site Visit Date Site Technician

10/22/2012 WST109 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	6	0.10	c	P
2	Temperature max error	P	4	0.5	6	0.21	c	P
3	Ozone Slope	P	0	1.1	4	0.99876	unitless	P
4	Ozone Intercept	P	0	5	4	0.16956	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	0.2	%	P
7	Ozone % difference max	P	7	10	4	0.5	%	P
8	Flow Rate average % difference	P	10	5	3	0.82	%	P
9	Flow Rate max % difference	P	10	5	3	0.89	%	P
10	DAS Time maximum error	P	0	5	1	0.02	min	P
11	DAS Voltage average error	P	7	0.003	21	0.0001	V	P
12	Shelter Temperature average error	P	5	1	6	0.67	c	P
13	Shelter Temperature max error	P	5	1	6	0.76	c	P

## Field Performance Comments

1 **Parameter:** Flow Rate      **SensorComponent:** Filter Position      **CommentCode** 71

The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.

## Field Systems Comments

1 **Parameter:** DasComments

The sample tower is kinked at the hinge point and is in poor condition. One leg of the met tower is split. Both of these conditions were reported following the two previous site audit visits.

2 **Parameter:** SiteOpsProcedures

The state of NH DES performs monthly multi-point audits of the ozone analyzer. Ozone sample train leak checks are being conducted every two weeks.

3 **Parameter:** SitingCriteriaCom

The site is in a small clearing surrounded by mountain forest. There is a small parking lot used by forest service employees located 50 meters from the site.

4 **Parameter:** SiteOKNotes

State of NH Department of Environmental Services contact is Tom Fazzina (603) 271-0911 and tfazzina@DES.state.NH.US

5 **Parameter:** ShelterCleanNotes

The shelter floor and roof have been repaired. Hand rails have been installed on platform.

6 **Parameter:** MetSensorComme

10-meter temperature is being operated and maintained on the meteorological tower.

# EEMS Spot Report

Data Compiled: 1/7/2013 1:40:40 PM

Site Visit Date Site Technician

10/23/2012 ABT147 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	6	0.09	c	P
2	Temperature max error	P	4	0.5	6	0.14	c	P
3	Ozone Slope	P	0	1.1	4	0.96006	unitless	P
4	Ozone Intercept	P	0	5	4	0.29628	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99995	unitless	P
6	Ozone % difference avg	P	7	10	4	3.2	%	P
7	Ozone % difference max	P	7	10	4	4.1	%	P
8	Flow Rate average % difference	P	10	5	3	0.20	%	P
9	Flow Rate max % difference	P	10	5	3	0.39	%	P
10	DAS Time maximum error	P	0	5	1	0.02	min	P
11	DAS Voltage average error	P	7	0.003	14	0.0001	V	P
12	Shelter Temperature average error	P	5	1	6	1.23	c	Fail
13	Shelter Temperature max error	P	5	1	6	3.4	c	Fail



## Field Performance Comments

- 1 **Parameter:** Flow Rate      **SensorComponent:** Moisture Present      **CommentCode** 72  
The filter sample tubing has drops of moisture in low sections outside the shelter.

## Field Systems Comments

- 1 **Parameter:** SiteOpsProcComm  
During the filter change-out it was observed that the filter flow pump was operating when the tower was lowered. This was discussed with the operator and the proper procedure was described by the auditor. The site operator indicated that she had been instructed by AMEC personnel to leave the filter installed and operate the flow pump while the tower was down.
- 2 **Parameter:** DasComments  
The sample tower is no longer grounded. The lower section of the met tower has been replaced.
- 3 **Parameter:** SitingCriteriaCom  
Manure is routinely spread on the hay fields surrounding the site.
- 4 **Parameter:** ShelterCleanNotes  
The shelter is clean and well organized.
- 5 **Parameter:** MetSensorComme  
10-meter temperature is operated and maintained on the meteorological tower.

# EEMS Spot Report

Data Compiled: 1/4/2013 2:41:01 PM

SiteVisitDate	Site	Technician
10/23/2012	CDR119	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00905	unitless	P
2	Ozone Intercept	P	0	5	4	0.34390	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	1.3	%	P
5	Ozone % difference max	P	7	10	4	2.2	%	P

# EEMS Spot Report

Data Compiled: 1/7/2013 5:36:38 PM

SiteVisitDate	Site	Technician
10/24/2012	CAT175	Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	12	0.15	c	P
2	Temperature max error	P	4	0.5	12	0.27	c	P
3	Flow Rate average % difference	P	10	5	2	2.63	%	P
4	Flow Rate max % difference	P	10	5	2	2.7	%	P
5	DAS Time maximum error	P	0	5	1	0.03	min	P
6	DAS Voltage average error	P	5	0.003	7	0.0001	V	P

## Field Performance Comments

1 **Parameter:** Flow Rate **SensorComponent:** Filter Position **CommentCode** 71

The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.

## Field Systems Comments

1 **Parameter:** SiteOpsProcComm

The site operator was not available to meet with the auditor during the audit visit due to a personal family matter.

2 **Parameter:** DasComments

The shelter is not temperature controlled. The site is solar and DC battery powered.

3 **Parameter:** ShelterCleanNotes

The shelter and grounds are neat and clean. The shelter roof has been repaired.

4 **Parameter:** PollAnalyzerCom

Ozone monitoring is no longer being conducted at the site.

# EEMS Spot Report

Data Compiled: 1/4/2013 3:19:59 PM

SiteVisitDate	Site	Technician
10/24/2012	PAR107	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00657	unitless	P
2	Ozone Intercept	P	0	5	4	0.59606	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	1.4	%	P
5	Ozone % difference max	P	7	10	4	2.6	%	P

## Field Performance Comments

1 **Parameter:** Ozone      **SensorComponent:** Cell B Freq.      **CommentCode** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

# EEMS Spot Report

Data Compiled: 1/4/2013 3:42:05 PM

SiteVisitDate	Site	Technician
10/25/2012	LRL117	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.96660	unitless	P
2	Ozone Intercept	P	0	5	4	0.56306	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	2.8	%	P
5	Ozone % difference max	P	7	10	4	3.4	%	P

# EEMS Spot Report

Data Compiled: 1/7/2013 7:11:30 PM

Site Visit Date Site Technician  
10/30/2012 ARE128 Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	6	0.08	c	P
2	Temperature max error	P	4	0.5	6	0.21	c	P
3	Ozone Slope	P	0	1.1	4	0.99968	unitless	P
4	Ozone Intercept	P	0	5	4	0.06764	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99993	unitless	P
6	Ozone % difference avg	P	7	10	4	0.8	%	P
7	Ozone % difference max	P	7	10	4	1.9	%	P
8	Flow Rate average % difference	P	10	5	3	2.78	%	P
9	Flow Rate max % difference	P	10	5	3	3.29	%	P
10	DAS Time maximum error	P	0	5	1	0.07	min	P
11	DAS Voltage average error	P	7	0.003	21	0.0001	V	P
12	Shelter Temperature average error	P	5	1	6	2.04	c	Fail
13	Shelter Temperature max error	P	5	1	6	2.73	c	Fail

## Field Performance Comments

- Parameter:** Flow Rate      **SensorComponent:** System Memo      **CommentCode** 174  
Additional details can be found in the hardcopy of the site audit report.
- Parameter:** Flow Rate      **SensorComponent:** Moisture Present      **CommentCode** 204  
There is moisture present in the dry deposition sample train inside the shelter.

## Field Systems Comments

- Parameter:** DasComments  
The meteorological tower is grounded but the lightning rod has been removed. The sample tower is not grounded.
- Parameter:** SitingCriteriaCom  
The site is located in an active orchard where spraying occurs. Fruit trees are rotated with corn and other crops.
- Parameter:** PollAnalyzerCom  
Moisture was present in the moisture trap and tubing upon arrival for the audit one day after hurricane Sandy. The system was left open without the filter installed for one day and then the audit of the flow system was performed.
- Parameter:** ShelterCleanNotes  
The shelter is cluttered and disorganized.
- Parameter:** MetOpMaintCom  
The 10-meter temperature sensor is being operated and maintained on the meteorological tower.

# EEMS Spot Report

Data Compiled: 1/4/2013 4:37:12 PM

SiteVisitDate	Site	Technician
11/01/2012	GRS420	Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99614	unitless	P
2	Ozone Intercept	P	0	5	4	1.25232	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99994	unitless	P
4	Ozone % difference avg	P	7	10	4	1.9	%	P
5	Ozone % difference max	P	7	10	4	3.1	%	P



# EEMS Spot Report

Data Compiled: 1/8/2013 4:38:48 PM

Site Visit Date	Site	Technician
11/03/2012	PSU106	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	6	0.14	c	P
2	Temperature max error	P	4	0.5	6	0.19	c	P
3	Ozone Slope	P	0	1.1	4	0.99049	unitless	P
4	Ozone Intercept	P	0	5	4	0.66213	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
6	Ozone % difference avg	P	7	10	4	0.8	%	P
7	Ozone % difference max	P	7	10	4	2.1	%	P
8	Flow Rate average % difference	P	10	5	2	4.43	%	P
9	Flow Rate max % difference	P	10	5	2	4.55	%	P
10	DAS Time maximum error	P	0	5	1	0.02	min	P
11	DAS Voltage average error	P	7	0.003	21	0.0001	V	P
12	Shelter Temperature average error	P	5	1	6	0.17	c	P
13	Shelter Temperature max error	P	5	1	6	0.33	c	P

## Field Systems Comments

**1 Parameter:** DasComments

The meteorological tower has been removed.

**2 Parameter:** SitingCriteriaCom

The site is within 10 km of State College which has a population of approximately 50,000. The site is located in a university agricultural research field.

**3 Parameter:** ShelterCleanNotes

The shelter is owned by the university and is clean and orderly. The site is part of the Surfrad network.

**4 Parameter:** MetOpMaintCom

The 10-meter temperature sensor is now mounted in a naturally aspirated shield on the sample tower.

# EEMS Spot Report

Data Compiled: 1/4/2013 5:04:25 PM

SiteVisitDate	Site	Technician
11/13/2012	SHN418	Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00815	unitless	P
2	Ozone Intercept	P	0	5	4	-0.21303	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99995	unitless	P
4	Ozone % difference avg	P	7	10	4	0.9	%	P
5	Ozone % difference max	P	7	10	4	1.8	%	P

## Field Performance Comments

1 **Parameter:** Ozone      **SensorComponent:** Cell A Freq.      **CommentCode** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

# EEMS Spot Report

Data Compiled: 1/4/2013 3:54:31 PM

SiteVisitDate	Site	Technician
11/17/2012	BWR139	Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99669	unitless	P
2	Ozone Intercept	P	0	5	4	0.06569	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99992	unitless	P
4	Ozone % difference avg	P	7	10	4	0.5	%	P
5	Ozone % difference max	P	7	10	4	1.0	%	P

# EEMS Spot Report

Data Compiled: 1/9/2013 5:23:13 PM

Site Visit Date Site Technician

11/20/2012 BEL116 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature 2 meter average error	P	5	0.5	3	0.17	c	P
2	Temperature 2 meter max error	P	5	0.5	3	0.35	c	P
3	Wind Speed average error below 5m/s in m/s	P	3	0.5	4	0.05	m/s	P
4	Wind Speed max error below 5m/s in m/s	P	3	0.5	4	0.20	m/s	P
5	Wind Speed average % difference above 5 m/s	P	3	5	4	0.0	%	P
6	Wind Speed max % difference above 5 m/s	P	3	5	4	0.0	%	P
7	Wind Speed Torque average error	P	3	0.5	1	0.25	g-cm	P
8	Wind Speed Torque max error	P	3	0.5	1	0.3	g-cm	P
9	Wind Direction Input Deg True average error (de	P	2	5	4	2.2	degrees	P
10	Wind Direction Input Deg True max error (deg)	P	2	5	4	3	degrees	P
11	Wind Direction Linearity average error (deg)	P	2	5	8	1.2	degrees	P
12	Wind Direction Linearity max error (deg)	P	2	5	8	2	degrees	P
13	Wind Direction Torque average error	P	2	20	1	15	g-cm	P
14	Wind Direction Torque max error	P	2	20	1	15	g-cm	P
15	Temperature average error	P	4	0.5	9	0.15	c	P
16	Temperature max error	P	4	0.5	9	0.33	c	P
17	Relative Humidity average above 85%	P	6	10	3	5.9	%	P
18	Relative Humidity max above 85%	P	6	10	3	5.9	%	P
19	Relative Humidity average below 85%	P	6	10	6	7.0	%	P
20	Relative Humidity max below 85%	P	6	10	6	8.0	%	P
21	Solar Radiation % diff of avg	P	9	10	9	6.35	%	P
22	Solar Radiation % diff of max STD value	P	9	10	9	6.4	%	P
23	Precipitation average % difference	P	1	10	2	5.0	%	P
24	Precipitation max % difference	P	1	10	2	8.0	%	P
25	Ozone Slope	P	0	1.1	4	0.97643	unitless	P
26	Ozone Intercept	P	0	5	4	0.47920	ppb	P
27	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
28	Ozone % difference avg	P	7	10	4	1.6	%	P
29	Ozone % difference max	P	7	10	4	2.1	%	P
30	Flow Rate average % difference	P	10	5	2	0.11	%	P
31	Flow Rate max % difference	P	10	5	2	0.16	%	P
32	DAS Time maximum error	P	0	5	1	0.02	min	P
33	DAS Voltage average error	P	7	0.003	28	0.0000	V	P
34	Surface Wetness Response	P	12	0.5	1	1.02		P

SiteVisitDate	Site	Technician							
11/20/2012	BEL116	Eric Hebert							
35	Shelter Temperature average error	P	5	1	6	0.10	c	P	
36	Shelter Temperature max error	P	5	1	6	0.19	c	P	

## Field Systems Comments

**1 Parameter:** SiteOpsProcedures

The site operator was incorrectly recording the filter final flow as the filter installed flow (on the SSRF) as instructed by the previous site operator. This was discussed during the audit and the correct procedures were described by the auditor.

**2 Parameter:** ShelterCleanNotes

Larger shelter installed since previous audit visit in 2010.

**3 Parameter:** SitingCriteriaCom

The site is located between Washington DC and Baltimore, MD near a major transportation corridor. Although the site surroundings are woodland and agriculture, the region surrounding the research center is densely populated and urban.

# EEMS Spot Report

Data Compiled: 1/4/2013 5:26:04 PM

SiteVisitDate	Site	Technician
11/29/2021	BFT142	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00277	unitless	P
2	Ozone Intercept	P	0	5	4	-0.04122	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99997	unitless	P
4	Ozone % difference avg	P	7	10	4	0.5	%	P
5	Ozone % difference max	P	7	10	4	1.3	%	P

## Field Performance Comments

1 **Parameter:** Ozone      **SensorComponent:** Cell B Freq.      **CommentCode** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

# EEMS Spot Report

Data Compiled: 1/4/2013 5:47:24 PM

SiteVisitDate	Site	Technician
11/29/2012	CND125	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.01781	unitless	P
2	Ozone Intercept	P	0	5	4	0.18162	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99997	unitless	P
4	Ozone % difference avg	P	7	10	4	1.9	%	P
5	Ozone % difference max	P	7	10	4	2.3	%	P

## Field Performance Comments

1 **Parameter:** Ozone      **SensorComponent:** Cell A Freq.      **CommentCode** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

---

**APPENDIX C**

**CASTNET Ozone Performance Evaluation Forms**

---



---

## *Site Inventory by Site Visit*

---

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

---

### *CDR119-Sandy Grenville-10/23/2012*

1	10/23/2012	DAS	Campbell	000332	CR3000	2111
2	10/23/2012	Ozone	ThermoElectron Inc	000611	49i A1NAA	1009241795
3	10/23/2012	Ozone Standard	ThermoElectron Inc	000330	49i A3NAA	0622717854
4	10/23/2012	Sample Tower	Aluma Tower	928376	B	AT-51060-56
5	10/23/2012	Zero air pump	Werther International	06903	C 70/4	000899159

# Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241795		CDR119	Sandy Grenville	10/23/2012	Ozone	000611

<b>Slope:</b>	1.00905	<b>Slope:</b>	0.00000
<b>Intercept</b>	0.34390	<b>Intercept</b>	0.00000
<b>CorrCoff</b>	0.99999	<b>CorrCoff</b>	0.00000

<b>DAS 1:</b>	<b>DAS 2:</b>
<b>A Avg % Diff:</b>	<b>A Avg %Dif</b>
<b>A Max % Di</b>	<b>A Max % Di</b>
1.3%	2.2%

<b>Mfg</b>	ThermoElectron Inc	<b>Parameter</b>	ozone
<b>Serial Number</b>	49C-73104-373	<b>Tfer Desc.</b>	Ozone transfer
<b>Tfer ID</b>	01100		
<b>Slope</b>	1.01297	<b>Intercept</b>	0.09498
<b>Cert Date</b>	1/23/2012	<b>CorrCoff</b>	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.04	-0.05	0.42	ppb	
primary	2	36.10	35.54	36.00	ppb	1.29%
primary	3	64.90	63.97	65.39	ppb	2.22%
primary	4	86.60	85.39	86.00	ppb	0.71%
primary	5	216.00	213.14	215.50	ppb	1.11%

<b>Sensor Component</b>	Cell B Noise	<b>Condition</b>	1.3 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Tmp.	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Fullscale Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Inlet Filter Condition	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Line Loss	<b>Condition</b>	Not tested	<b>Status</b>	pass
<b>Sensor Component</b>	Offset	<b>Condition</b>	-0.13	<b>Status</b>	pass
<b>Sensor Component</b>	Span	<b>Condition</b>	1.004	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Freq.	<b>Condition</b>	98.1 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Sample Train	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Pressure	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Flow	<b>Condition</b>	0.71 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Tmp.	<b>Condition</b>	35.0 C	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Pressure	<b>Condition</b>	719 mmHg	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Noise	<b>Condition</b>	1.3 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Freq.	<b>Condition</b>	82.9 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Flow	<b>Condition</b>	0.69 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Battery Backup	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Zero Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass

---

## *Site Inventory by Site Visit*

---

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

---

*PAR107-Sandy Grenville-10/24/2012*

1	10/24/2012	DAS	Campbell	000333	CR3000	2112
2	10/24/2012	Ozone	ThermoElectron Inc	000735	49i A1NAA	1105347308
3	10/24/2012	Ozone Standard	ThermoElectron Inc	000704	49i A3NAA	1030244816
4	10/24/2012	Zero air pump	Werther International	06932	C 70/4	000829174

# Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347308		PAR107	Sandy Grenville	10/24/2012	Ozone	000735

<b>Slope:</b>	1.00657	<b>Slope:</b>	0.00000
<b>Intercept</b>	0.59606	<b>Intercept</b>	0.00000
<b>CorrCoff</b>	0.99999	<b>CorrCoff</b>	0.00000

<b>DAS 1:</b>	<b>DAS 2:</b>
<b>A Avg % Diff:</b>	<b>A Avg % Dif</b>
<b>A Max % Di</b>	<b>A Max % Di</b>
1.4%	2.6%

<b>Mfg</b>	ThermoElectron Inc	<b>Parameter</b>	ozone
<b>Serial Number</b>	49C-73104-373	<b>Tfer Desc.</b>	Ozone transfer
<b>Tfer ID</b>	01100		
<b>Slope</b>	1.01297	<b>Intercept</b>	0.09498
<b>Cert Date</b>	1/23/2012	<b>CorrCoff</b>	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.00	-0.09	0.91	ppb	
primary	2	34.83	34.29	35.18	ppb	2.60%
primary	3	65.36	64.42	65.13	ppb	1.10%
primary	4	87.27	86.05	86.80	ppb	0.87%
primary	5	216.83	213.95	216.20	ppb	1.05%

<b>Sensor Component</b>	Cell B Noise	<b>Condition</b>	0.9 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Tmp.	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Fullscale Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Inlet Filter Condition	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Line Loss	<b>Condition</b>	Not tested	<b>Status</b>	pass
<b>Sensor Component</b>	Offset	<b>Condition</b>	-0.20	<b>Status</b>	pass
<b>Sensor Component</b>	Span	<b>Condition</b>	1.013	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Freq.	<b>Condition</b>	78.6 kHz	<b>Status</b>	Fail
<b>Sensor Component</b>	System Memo	<b>Condition</b>	See comments	<b>Status</b>	pass
<b>Sensor Component</b>	Sample Train	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Pressure	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Flow	<b>Condition</b>	0.62 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Tmp.	<b>Condition</b>	34.7 C	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Pressure	<b>Condition</b>	701 mmHg	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Noise	<b>Condition</b>	0.7 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Freq.	<b>Condition</b>	83.4 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Flow	<b>Condition</b>	0.73 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Battery Backup	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Zero Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass

---

## *Site Inventory by Site Visit*

---

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

---

*LRL117-Sandy Grenville-10/25/2012*

1	10/25/2012	DAS	Campbell	000344	CR300	2123
2	10/25/2012	Ozone	ThermoElectron Inc	000701	49i A1NAA	1030244808
3	10/25/2012	Ozone Standard	ThermoElectron Inc	000327	49i A3NAA	0622717852
4	10/25/2012	Zero air pump	Werther International	06904	C 70/4	000821901

# Ozone Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
ThermoElectron Inc	1030244808		LRL117	Sandy Grenville	10/25/2012	Ozone	000701

<b>Slope:</b>	0.96660	<b>Slope:</b>	0.00000
<b>Intercept</b>	0.56306	<b>Intercept</b>	0.00000
<b>CorrCoff</b>	0.99999	<b>CorrCoff</b>	0.00000

<b>DAS 1:</b>	<b>DAS 2:</b>		
<b>A Avg % Diff:</b>	<b>A Max % Di</b>	<b>A Avg %Dif</b>	<b>A Max % Di</b>
2.8%	3.4%		

<b>Mfg</b>	ThermoElectron Inc	<b>Parameter</b>	ozone
<b>Serial Number</b>	49C-73104-373	<b>Tfer Desc.</b>	Ozone transfer
<b>Tfer ID</b>	01100		
<b>Slope</b>	1.01297	<b>Intercept</b>	0.09498
<b>Cert Date</b>	1/23/2012	<b>CorrCoff</b>	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.33	0.23	1.10	ppb	
primary	2	36.30	35.74	34.53	ppb	-3.39%
primary	3	66.22	65.27	63.76	ppb	-2.31%
primary	4	86.54	85.33	83.20	ppb	-2.50%
primary	5	215.29	212.43	205.90	ppb	-3.07%

<b>Sensor Component</b>	Cell B Noise	<b>Condition</b>	1.5 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Tmp.	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Fullscale Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Inlet Filter Condition	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Line Loss	<b>Condition</b>	Not tested	<b>Status</b>	pass
<b>Sensor Component</b>	Offset	<b>Condition</b>	-0.10	<b>Status</b>	pass
<b>Sensor Component</b>	Span	<b>Condition</b>	1.015	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Freq.	<b>Condition</b>	96.3 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Sample Train	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Pressure	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Flow	<b>Condition</b>	0.70 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Tmp.	<b>Condition</b>	32.3 C	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Pressure	<b>Condition</b>	696 mmHg	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Noise	<b>Condition</b>	1.4 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Freq.	<b>Condition</b>	97.3 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Flow	<b>Condition</b>	0.68 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Battery Backup	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Zero Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass

---

## *Site Inventory by Site Visit*

---

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

---

### *GRS420-Eric Hebert-11/01/2012*

1	11/1/2012	DAS	Environmental Sys Corp	none	8832	A4115K
2	11/1/2012	Ozone	ThermoElectron Inc	none	49i A3NAA	1023943903
3	11/1/2012	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	CM08460051
4	11/1/2012	Sample Tower	Aluma Tower	90945	B	none
5	11/1/2012	Zero air pump	Thomas	none	917CA18	0000174

# Ozone Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
ThermoElectron Inc	1023943903		GRS420	Eric Hebert	11/01/2012	Ozone	none

<b>Slope:</b>	0.99614	<b>Slope:</b>	0.00000
<b>Intercept</b>	1.25232	<b>Intercept</b>	0.00000
<b>CorrCoff</b>	0.99994	<b>CorrCoff</b>	0.00000

<b>DAS 1:</b>	<b>DAS 2:</b>		
<b>A Avg % Diff:</b>	<b>A Max % Di</b>	<b>A Avg %Dif</b>	<b>A Max % Di</b>
1.9%	3.1%		

<b>Mfg</b>	ThermoElectron Inc	<b>Parameter</b>	ozone
<b>Serial Number</b>	517112175	<b>Tfer Desc.</b>	Ozone primary stan
<b>Tfer ID</b>	01111		
<b>Slope</b>	1.00987	<b>Intercept</b>	0.07483
<b>Cert Date</b>	3/23/2012	<b>CorrCoff</b>	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.13	0.05	0.98	ppb	
primary	2	37.36	36.92	38.06	ppb	3.09%
primary	3	56.33	55.70	57.18	ppb	2.66%
primary	4	87.05	86.12	87.45	ppb	1.54%
primary	5	109.98	108.83	109.10	ppb	0.25%

<b>Sensor Component</b>	Cell B Noise	<b>Condition</b>	0.8 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Tmp.	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Fullscale Voltage	<b>Condition</b>	1.0008	<b>Status</b>	pass
<b>Sensor Component</b>	Inlet Filter Condition	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Line Loss	<b>Condition</b>	Not tested	<b>Status</b>	pass
<b>Sensor Component</b>	Offset	<b>Condition</b>	0.000	<b>Status</b>	pass
<b>Sensor Component</b>	Span	<b>Condition</b>	1.027	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Freq.	<b>Condition</b>	97.7 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Sample Train	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Pressure	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Flow	<b>Condition</b>	0.69 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Tmp.	<b>Condition</b>	31.5 C	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Pressure	<b>Condition</b>	680 mmHg	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Noise	<b>Condition</b>	0.9 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Freq.	<b>Condition</b>	113.2 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Flow	<b>Condition</b>	0.68 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Battery Backup	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Zero Voltage	<b>Condition</b>	0.0018	<b>Status</b>	pass



---

## *Site Inventory by Site Visit*

---

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

---

### *SHN418-Eric Hebert-11/13/2012*

1	11/13/2012	DAS	Environmental Sys Corp	90643	8816	2529
2	11/13/2012	Ozone	ThermoElectron Inc	none	49i A3NAA	0733726103
3	11/13/2012	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	CM08460008
4	11/13/2012	Sample Tower	Aluma Tower	923307	B	none
5	11/13/2012	Zero air pump	Werther International	none	P 70/4	000756726

# Ozone Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
ThermoElectron Inc	0733726103		SHN418	Eric Hebert	11/13/2012	Ozone	none

<b>Slope:</b>	1.00815	<b>Slope:</b>	0.00000
<b>Intercept</b>	-0.21303	<b>Intercept</b>	0.00000
<b>CorrCoff</b>	0.99995	<b>CorrCoff</b>	0.00000

<b>DAS 1:</b>	<b>DAS 2:</b>		
<b>A Avg % Diff:</b>	<b>A Max % Di</b>	<b>A Avg %Dif</b>	<b>A Max % Di</b>
0.9%	1.8%		

<b>Mfg</b>	ThermoElectron Inc	<b>Parameter</b>	ozone
<b>Serial Number</b>	517112175	<b>Tfer Desc.</b>	Ozone primary stan
<b>Tfer ID</b>	01111		
<b>Slope</b>	1.00987	<b>Intercept</b>	0.07483
<b>Cert Date</b>	3/23/2012	<b>CorrCoff</b>	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.16	0.08	-0.56	ppb	
primary	2	34.62	34.20	34.81	ppb	1.78%
primary	3	65.94	65.22	65.77	ppb	0.84%
primary	4	86.08	85.16	85.55	ppb	0.46%
primary	5	101.82	100.75	101.10	ppb	0.35%

<b>Sensor Component</b>	Cell B Noise	<b>Condition</b>	0.9 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Tmp.	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Fullscale Voltage	<b>Condition</b>	0.9996	<b>Status</b>	pass
<b>Sensor Component</b>	Inlet Filter Condition	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Line Loss	<b>Condition</b>	Not tested	<b>Status</b>	pass
<b>Sensor Component</b>	Offset	<b>Condition</b>	2.1	<b>Status</b>	pass
<b>Sensor Component</b>	Span	<b>Condition</b>	1.027	<b>Status</b>	\
<b>Sensor Component</b>	Cell B Freq.	<b>Condition</b>	108.4 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>	See comments	<b>Status</b>	pass
<b>Sensor Component</b>	Sample Train	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Pressure	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Flow	<b>Condition</b>	0.69 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Tmp.	<b>Condition</b>	35.7 C	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Pressure	<b>Condition</b>	665 mmHg	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Noise	<b>Condition</b>	0.7 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Freq.	<b>Condition</b>	70.0 kHz	<b>Status</b>	Fail
<b>Sensor Component</b>	Cell A Flow	<b>Condition</b>	0.71 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Battery Backup	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Zero Voltage	<b>Condition</b>	0.0033	<b>Status</b>	pass

---

## *Site Inventory by Site Visit*

---

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

---

### *BWR139-Eric Hebert-11/17/2012*

1	11/17/2012	DAS	Campbell	000431	CR3000	2536
2	11/17/2012	Ozone	ThermoElectron Inc	000731	49i A1NAA	1105347309
3	11/17/2012	Ozone Standard	ThermoElectron Inc	000376	49i A3NAA	0726124693
4	11/17/2012	Sample Tower	Aluma Tower	missing	B	none
5	11/17/2012	UPS	APC	06093	RS800	unknown
6	11/17/2012	Zero air pump	Werther International	06877	C 70/4	000815258

# Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347309		BWR139	Eric Hebert	11/17/2012	Ozone	000731

<b>Slope:</b>	0.99669	<b>Slope:</b>	0.00000
<b>Intercept</b>	0.06569	<b>Intercept</b>	0.00000
<b>CorrCoff</b>	0.99992	<b>CorrCoff</b>	0.00000

<b>DAS 1:</b>	<b>DAS 2:</b>
<b>A Avg % Diff:</b>	<b>A Avg %Dif</b>
<b>A Max % Di</b>	<b>A Max % Di</b>
0.5%	1.0%

<b>Mfg</b>	ThermoElectron Inc	<b>Parameter</b>	ozone
<b>Serial Number</b>	517112175	<b>Tfer Desc.</b>	Ozone primary stan
<b>Tfer ID</b>	01111		
<b>Slope</b>	1.00987	<b>Intercept</b>	0.07483
<b>Cert Date</b>	3/23/2012	<b>CorrCoff</b>	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.25	0.17	-0.09	ppb	
primary	2	23.74	23.43	23.45	ppb	0.09%
primary	3	62.42	61.73	61.99	ppb	0.42%
primary	4	86.18	85.26	85.70	ppb	0.52%
primary	5	107.78	106.65	105.60	ppb	-0.98%

<b>Sensor Component</b>	Cell B Noise	<b>Condition</b>	0.9 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Tmp.	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Fullscale Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Inlet Filter Condition	<b>Condition</b>	Moderately clean	<b>Status</b>	pass
<b>Sensor Component</b>	Line Loss	<b>Condition</b>	Not tested	<b>Status</b>	pass
<b>Sensor Component</b>	Offset	<b>Condition</b>	0.000	<b>Status</b>	pass
<b>Sensor Component</b>	Span	<b>Condition</b>	1.023	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Freq.	<b>Condition</b>	82.7 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Sample Train	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Pressure	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Flow	<b>Condition</b>	0.74 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Tmp.	<b>Condition</b>	31.5 C	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Pressure	<b>Condition</b>	752 mmHg	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Noise	<b>Condition</b>	1.0 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Freq.	<b>Condition</b>	90.1 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Flow	<b>Condition</b>	0.75 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Battery Backup	<b>Condition</b>	Functioning	<b>Status</b>	pass
<b>Sensor Component</b>	Zero Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass

---

## *Site Inventory by Site Visit*

---

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

---

### *BFT142-Sandy Grenville-11/29/2021*

1	11/29/2021	DAS	Campbell	000498	CR3000	3815
2	11/29/2021	Ozone	ThermoElectron Inc	000629	49i A1NAA	1009241784
3	11/29/2021	Ozone Standard	ThermoElectron Inc	000219	49i A3NAA	06227833
4	11/29/2021	UPS	APC	05003	XS800	unknown
5	11/29/2021	Zero air pump	Werther International	06897	C 70/4	000821893

# Ozone Data Form

<b>Mfg</b>	<b>Serial Number</b>	<b>Ta</b>	<b>Site</b>	<b>Technician</b>	<b>Site Visit Date</b>	<b>Parameter</b>	<b>Owner ID</b>
ThermoElectron Inc	1009241784		BFT142	Sandy Grenville	11/29/2021	Ozone	000629

<b>Slope:</b>	1.00277	<b>Slope:</b>	0.00000
<b>Intercept</b>	-0.04122	<b>Intercept</b>	0.00000
<b>CorrCoff</b>	0.99997	<b>CorrCoff</b>	0.00000

<b>DAS 1:</b>	<b>DAS 2:</b>		
<b>A Avg % Diff:</b>	<b>A Max % Di</b>	<b>A Avg %Dif</b>	<b>A Max % Di</b>
0.5%	1.3%		

<b>Mfg</b>	ThermoElectron Inc	<b>Parameter</b>	ozone
<b>Serial Number</b>	49C-73104-373	<b>Tfer Desc.</b>	Ozone transfer
<b>Tfer ID</b>	01100		
<b>Slope</b>	1.01297	<b>Intercept</b>	0.09498
<b>Cert Date</b>	1/23/2012	<b>CorrCoff</b>	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.04	-0.05	-0.37	ppb	
primary	2	35.70	35.14	35.60	ppb	1.31%
primary	3	65.75	64.81	64.78	ppb	-0.05%
primary	4	86.18	84.98	85.50	ppb	0.61%
primary	5	111.14	109.62	109.60	ppb	-0.02%

<b>Sensor Component</b>	Cell B Noise	<b>Condition</b>	0.8 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Tmp.	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Fullscale Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Inlet Filter Condition	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Line Loss	<b>Condition</b>	Not tested	<b>Status</b>	pass
<b>Sensor Component</b>	Offset	<b>Condition</b>	0.20	<b>Status</b>	pass
<b>Sensor Component</b>	Span	<b>Condition</b>	1.041	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Freq.	<b>Condition</b>	78.2 kHz	<b>Status</b>	Fail
<b>Sensor Component</b>	System Memo	<b>Condition</b>	See comments	<b>Status</b>	pass
<b>Sensor Component</b>	Sample Train	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Pressure	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Flow	<b>Condition</b>	0.70 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Tmp.	<b>Condition</b>	32.9 C	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Pressure	<b>Condition</b>	777 mmHg	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Noise	<b>Condition</b>	0.9 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Freq.	<b>Condition</b>	80.8 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Flow	<b>Condition</b>	0.68 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Battery Backup	<b>Condition</b>	Functioning	<b>Status</b>	pass
<b>Sensor Component</b>	Zero Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass

---

## *Site Inventory by Site Visit*

---

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

---

### *CND125-Sandy Grenville-11/29/2012*

1	11/29/2012	DAS	Campbell	000499	CR3000	3816
2	11/29/2012	Ozone	ThermoElectron Inc	000728	49i A1NAA	1105347306
3	11/29/2012	Ozone Standard	ThermoElectron Inc	000543	49i A3NAA	0929938240
4	11/29/2012	Zero air pump	Werther International	06868	C 70/4	000814284

# Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347306		CND125	Sandy Grenville	11/29/2012	Ozone	000728

<b>Slope:</b>	1.01781	<b>Slope:</b>	0.00000
<b>Intercept</b>	0.18162	<b>Intercept</b>	0.00000
<b>CorrCoff</b>	0.99997	<b>CorrCoff</b>	0.00000

<b>DAS 1:</b>	<b>DAS 2:</b>
<b>A Avg % Diff:</b>	<b>A Avg % Dif</b>
<b>A Max % Di</b>	<b>A Max % Di</b>
1.9%	2.3%

<b>Mfg</b>	ThermoElectron Inc	<b>Parameter</b>	ozone
<b>Serial Number</b>	49C-73104-373	<b>Tfer Desc.</b>	Ozone transfer
<b>Tfer ID</b>	01100		
<b>Slope</b>	1.01297	<b>Intercept</b>	0.09498
<b>Cert Date</b>	1/23/2012	<b>CorrCoff</b>	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.10	0.00	0.47	ppb	
primary	2	35.56	35.01	35.59	ppb	1.66%
primary	3	65.48	64.54	65.72	ppb	1.83%
primary	4	85.63	84.43	85.80	ppb	1.62%
primary	5	111.38	109.86	112.40	ppb	2.31%

<b>Sensor Component</b>	Cell B Noise	<b>Condition</b>	0.7 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Tmp.	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Fullscale Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Inlet Filter Condition	<b>Condition</b>	Clean	<b>Status</b>	pass
<b>Sensor Component</b>	Line Loss	<b>Condition</b>	Not tested	<b>Status</b>	pass
<b>Sensor Component</b>	Offset	<b>Condition</b>	0.000	<b>Status</b>	pass
<b>Sensor Component</b>	Span	<b>Condition</b>	1.023	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Freq.	<b>Condition</b>	100.7 kHz	<b>Status</b>	pass
<b>Sensor Component</b>	System Memo	<b>Condition</b>	See comments	<b>Status</b>	pass
<b>Sensor Component</b>	Sample Train	<b>Condition</b>	Good	<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Pressure	<b>Condition</b>		<b>Status</b>	pass
<b>Sensor Component</b>	Cell B Flow	<b>Condition</b>	0.76 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Tmp.	<b>Condition</b>	32.8 C	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Pressure	<b>Condition</b>	740 mmHg	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Noise	<b>Condition</b>	0.6 ppb	<b>Status</b>	pass
<b>Sensor Component</b>	Cell A Freq.	<b>Condition</b>	79.8 kHz	<b>Status</b>	Fail
<b>Sensor Component</b>	Cell A Flow	<b>Condition</b>	0.69 lpm	<b>Status</b>	pass
<b>Sensor Component</b>	Battery Backup	<b>Condition</b>	N/A	<b>Status</b>	pass
<b>Sensor Component</b>	Zero Voltage	<b>Condition</b>	N/A	<b>Status</b>	pass